

METERING ICF PACKAGE CHANGES

PROCEDURE CONSULTATION

SECOND STAGE PARTICIPANT RESPONSE TEMPLATE

Participant: intelliHUB

Submission Date: 01.08.2019

Table of Contents

- 1. Context 3
- 2. MSATS Procedures: CATS 3
- 3. MSATS Procedures: WIGS..... 4
- 4. Metrology Procedure: Part A..... 5
- 5. Metrology Procedure: Part B..... 6
- 6. Service Level Procedure Meter Data Provider Services 7
- 7. Service Level Procedure Meter Provider Services 8
- 8. Service Level Procedure Embedded Network Manager 8
- 9. Exemption Procedure Meter Installation Malfunctions 9
- 10. Other Issues Related to Consultation Subject Matter 10

1. Context

This template is to assist stakeholders in giving feedback about the changes detailed in the initial draft procedures associated with the Metering ICF Package Changes consultation.

The changes being proposed are because of NER rule changes which have occurred requiring changes to AEMO’s Retail Electricity Market Procedures and the following proposed changes by proponents and AEMO to implement recommended process improvements.

2. MSATS Procedures: CATS

Section	Description	Participant Comments
2.1.(l)	New section added to clarify the communication of the identification of incorrect NMI	No Comment
2.4.(c)	Updated to define timeframes for updating datastreams in MSATS	No Comment
2.4.(d)	Updated to define timeframes for updating datastreams in MSATS	No Comment
2.4.(e)	Updated to define timeframes for updating datastreams in MSATS	No Comment
2.4.(f)	Updated to define timeframes for updating datastreams in MSATS	No Comment
2.4.(h)	Updated to define timeframes for updating datastreams in MSATS	No Comment

Section	Description	Participant Comments
2.5.(a)	New section added to define the dates MPs must use when updating MSATS about remote de-energisations	No Comment
2.5.(b)	New section added to define the dates MPs must use when updating MSATS about remote re- energisations	No Comment
4.18	Updated to clarify the LNSP's obligations in relation to creating Embedded Network Codes and ENM's obligations in relation to application of the Embedded Network Code and data provided to AEMO upon appointment.	No Comment

3. MSATS Procedures: WIGS

Section	Description	Participant Comments
Version	Updated to align version numbering with MSATS: CATS procedures	No Comment

4. Metrology Procedure: Part A

Section	Description	Participant Comments
3.1.(a)	Update to remove the word 'relevant'	No Comment
3.1.(b)	Update to remove the word 'relevant'; add requirements of AS60044.3 or IEC61869.1 and IEC61869.2; and detail what each topic the part of the standard covers	No Comment
3.1.(c)	Update to remove the word 'relevant'; add requirements of IEC61869.1 and IEC61869.3; and detail what each topic the part of the standard covers	No Comment
3.1.(d)	Update to include International Standards covered in 3.1.(b) and 3.1.(c).	No Comment
12.5.(a)	Removal of obsolete standard AS2490	No Comment
12.5.(b)	New section added to detail Sample Test Plan settings	No Comment
12.5.(c)	New section added to specify when a test sample is deemed to have passes the verification test	No Comment
12.5.(d)	New section added to specify when the steps to be followed after each round of	No Comment

Section	Description	Participant Comments
	verification	
12.5.(e)	Update to specify that verification tests must be conducted at least one every 12 months	No Comment

5. Metrology Procedure: Part B

Section	Description	Participant Comments
2.6	Update to include additional substitution type 69	No Comment
5.3.9	Addition of substitution type 69: Linear Interpolation	No Comment

6. Service Level Procedure Meter Data Provider Services

Section	Description	Participant Comments
2.4.1.(ix)	New section added to define an obligation to activate datastreams when energy is recorded from a metering installation while the NMI status is not Active	No Comment
2.4.1.(x)	New section added to define an obligation to deliver validated metering data to market participants when datastreams are active	No Comment
4.2.(g)	Amend outdated rule reference	No Comment
6.4.1.(c)	Amend outdated rule reference	No Comment
7.3.(b)	Amend outdated rule reference	No Comment

7. Service Level Procedure Meter Provider Services

Section	Description	Participant Comments
4.2.(a)(iii)	Amend outdated rule reference	No Comment
5.2.(a)	Updated to incorporate additional clause reference for timeframes for metering installation malfunction identification and rectification.	No Comment

8. Service Level Procedure Embedded Network Manager

Section	Description	Participant Comments
2.1.2.(d)	New section added to define an obligation that the EN for which the ENM has been appointed has an exemption by the AER.	No Comment
4.2.1.	Updated to clarify ENM's obligations with respect to DLFs.	No Comment
4.2.2.	Updated to clarify ENM's obligations with respect to DLFs.	No Comment

Section	Description	Participant Comments
4.3.3.(a)	Updated to clarify ENM's obligations with respect to Network Tariff Codes.	No Comment

9. Exemption Procedure Meter Installation Malfunctions

Section	Description	Participant Comments
1.1.	Updated to incorporate additional clause reference for timeframes for metering installation malfunction identification and rectification.	No Comment
2.2.	Updated to incorporate additional clause reference for timeframes for metering installation malfunction identification and rectification.	No Comment
Appendix A	Updated to incorporate additional clause reference for timeframes for metering installation malfunction identification and rectification.	No Comment
Appendix B	Updated to incorporate additional clause reference for timeframes for metering installation malfunction identification and rectification.	No Comment

10. Other Issues Related to Consultation Subject Matter

Participant Comments
N/A