



---

# NEM Event – Directions Report 6 to 10 March 2020

---

**February 2021**

---

# Important notice

## PURPOSE

Where the Australian Energy Market Operator (AEMO) intervenes in the National Electricity Market (NEM) through the use of directions, AEMO must publish a report in accordance with National Electricity Rules (NER) clauses 4.8.9(f) and 3.13.6A(a). This report satisfies those NER obligations and is based on information available to AEMO at 18 August 2020.

Unless otherwise indicated, terms in this report have the same meanings as those defined in the NER.

All references to time in this report are based on Australian Eastern Standard Time (AEST).

## Disclaimer

AEMO has made every reasonable effort to ensure the quality of the information in this report but cannot guarantee its accuracy or completeness. Any views expressed in this report are those of AEMO unless otherwise stated and may be based on information given to AEMO by other persons.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this report:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

## ABBREVIATIONS

Abbreviation	Expanded name
AEMO	Australian Energy Market Operator
DI	Dispatch Interval
MN	Market Notice
NEM	National Electricity Market
NER	National Electricity Rules
PS	Power Station
SA	South Australia
GT	Gas Turbine
ST	Steam Turbine

# Contents

<b>1.</b>	<b>Summary</b>	<b>4</b>
<b>2.</b>	<b>Intervention assessment</b>	<b>5</b>
2.1	The need for intervention	5
2.2	Assessment of market response and latest time to intervene	5
<b>3.</b>	<b>Intervention process</b>	<b>5</b>
3.1	Adequacy of responses to AEMO inquiries	6
3.2	Participant ability to comply with the intervention	6
<b>4.</b>	<b>Dispatch and pricing outcomes</b>	<b>6</b>
4.1	Changes to dispatch outcomes due to the directions	6
4.2	Direction costs	6
<b>5.</b>	<b>Conclusions and further actions</b>	<b>7</b>

## Tables

Table 1	Summary of the South Australia directions between 6 and 10 March 2020	4
Table 2	Participant offers	5
Table 3	Summary of latest time to intervene	5

# 1. Summary

To ensure adequate system strength for secure operation of the South Australian power system, certain combinations of synchronous generating units must be in service at all times.<sup>1</sup>

Clause 4.8.9 of the National Electricity Rules (NER) allows AEMO to intervene in the market by issuing directions or clause 4.8.9 instructions, if AEMO is satisfied that it is necessary to maintain or re-establish the power system to a secure, satisfactory, or reliable operating state. Section 116 of the National Electricity Law allows AEMO to issue directions to take certain action if AEMO considers that it is necessary to maintain power system security or for reasons of public safety.

Between 6 and 10 March 2020, AEMO issued seven directions in one event to South Australian Market Participants to maintain power system security. These directions are summarised in Table 1.

**Table 1 Summary of the South Australia directions between 6 and 10 March 2020**

Direction	Directed Participant	Event No.	Issue time	Cancellation time	Direction instruction
Torrens Island PS B unit 2	AGL SA Generation Pty Ltd	1	1800 hrs, 6 March 2020	0400 hrs, 10 March 2020	Remain synchronised and follow dispatch targets from 0100 hrs, 7 March 2020
Torrens Island PS B unit 4	AGL SA Generation Pty Ltd	1	1800 hrs, 6 March 2020	1500 hrs, 9 March 2020	Synchronise and follow dispatch targets from 0230 hrs, 7 March 2020
Pelican Point Gas Turbine (GT) 12 and Steam Turbine (ST) 18	Pelican Point Power Limited (ENGIE)	1	1900 hrs, 6 March 2020	1600 hrs, 7 March 2020	Remain synchronised and follow dispatch targets from 0300 hrs, 7 March 2020
Pelican Point GT12 and ST18	Pelican Point Power Limited (ENGIE)	1	1530 hrs, 7 March 2020	1700 hrs, 8 March 2020	Remain synchronised and follow dispatch targets from 0200 hrs, 8 March 2020
Pelican Point GT12 and ST18	Pelican Point Power Limited (ENGIE)	1	1800 hrs, 8 March 2020	1700 hrs, 9 March 2020	Remain synchronised and follow dispatch targets from 0230 hrs, 9 March 2020
Pelican Point GT12 and ST18	Pelican Point Power Limited (ENGIE)	1	1600 hrs, 9 March 2020	1400 hrs, 10 March 2020	Remain synchronised and follow dispatch targets from 2100 hrs, 9 March 2020
Torrens Island PS B unit 4	AGL SA Generation Pty Ltd	1	1600 hrs, 9 March 2020	1430 hrs, 10 March 2020	Remain synchronised and follow dispatch targets from 0100 hrs, 10 March 2020

<sup>1</sup> AEMO Transfer Limit Advice – System Strength, available at [https://aemo.com.au/-/media/files/electricity/nem/security\\_and\\_reliability/congestion-information/transfer-limit-advice-system-strength.pdf?la=en](https://aemo.com.au/-/media/files/electricity/nem/security_and_reliability/congestion-information/transfer-limit-advice-system-strength.pdf?la=en).

# 2. Intervention assessment

## 2.1 The need for intervention

To ensure adequate system strength for secure operation of the South Australian power system, certain combinations of synchronous generating units must be in service at all times. If market conditions lead to market participants seeking to decommit synchronous generation AEMO is required to intervene to maintain the required level of synchronous units. The need for intervention, and options considered, were assessed against the set of viable plant combinations available at the time the directions were issued.

The requirement to intervene for the direction event in this report arose when the bid in Table 2 was submitted.

**Table 2 Participant offers**

Event No.	Unit	Offer date	Bid
1	Torrens Island PS B unit 2	1032 hrs, 5 March 2020	Initial bid to de-commit from 0100 hrs, 7 March 2020 <sup>A</sup>

A. Initial bid: 1030~F~00 INITIAL BID~

## 2.2 Assessment of market response and latest time to intervene

Under NER clause 4.8.5A(a) and (c), AEMO must notify the market of any anticipated power system security or reliability issue, and the latest time for market response before AEMO would need to intervene. For each of the direction events, AEMO issued this market notification as listed in Table 3.

AEMO contacted all participants who operate suitable generating units in South Australia to confirm their availability and the latest time to intervene. Those participants indicated that no market response would be provided but identified units that would be available if directed.

For this direction event, AEMO assessed the latest time to intervene taking account of the advised lead times. The latest time to intervene is shown in Table 3.

**Table 3 Summary of latest time to intervene**

Event No.	Latest time to respond	Market Notice
1	1800 hrs, 6 March 2020	MN 74783

# 3. Intervention process

AEMO considers that it followed all applicable processes under NER clause 4.8 for the management of the directions between 6 and 10 March 2020<sup>2</sup>.

<sup>2</sup> AEMO. Power system operating procedure SO\_OP 3707, "Procedures For Issue Of Directions And Clause 4.8.9 Instructions", 06 September 2019, available at [https://aemo.com.au/-/media/files/electricity/nem/security\\_and\\_reliability/power\\_system\\_ops/procedures/so\\_op\\_3707-procedures-for-issue-of-directions-and-clause-4-8-9-instructions.pdf?la=en](https://aemo.com.au/-/media/files/electricity/nem/security_and_reliability/power_system_ops/procedures/so_op_3707-procedures-for-issue-of-directions-and-clause-4-8-9-instructions.pdf?la=en).

### 3.1 Adequacy of responses to AEMO inquiries

NER clause 4.8.5A(d) permits AEMO to request information from Scheduled Network Service Providers, Scheduled Generators, Semi-Scheduled Generators, and Market Customers.

AEMO is satisfied with the timeliness, adequacy, and effectiveness of all responses to its requests for information prior to issuing the directions between 6 and 10 March 2020.

### 3.2 Participant ability to comply with the intervention

NER clause 4.8.9(d) requires that a Registered Participant must immediately notify AEMO of its inability to comply, or intention not to comply, with a direction or clause 4.8.9 instruction.

AEMO is satisfied with all participants complying with the directions listed in Table 1.

## 4. Dispatch and pricing outcomes

### 4.1 Changes to dispatch outcomes due to the directions

The directions resulted in approximately 15,774 megawatt hours (MWh) of synchronous generation being directed into the market.

Intervention pricing did not apply for these events.

Under clause 3.8.1 of the NER, AEMO must operate a central dispatch process to balance power system supply and demand, using its reasonable endeavours to maintain power system security in accordance with NER Chapter 4 and the power system security standards. AEMO notes that in the absence of directions for system security, the central dispatch process would have produced an outcome which would have resulted in the operation of the power system in an insecure state and would therefore have been an infeasible dispatch solution.

### 4.2 Direction costs

The compensation recovery costs for the directions between 6 and 10 March 2020 were \$1,544,870. Direction compensation recovery data can be found on the AEMO website.<sup>3</sup>

---

<sup>3</sup> AEMO. Direction Compensation Recovery, available at <https://aemo.com.au/en/energy-systems/electricity/national-electricity-market-nem/data-nem/settlements-data/direction-compensation-recovery>.

# 5. Conclusions and further actions

Between 6 and 10 March 2020, AEMO issued seven directions to South Australian Market Participants to maintain power system security, in response to a forecast lack of system strength in the region.

AEMO is satisfied that all applicable procedures and processes were followed in assessing the need for intervention, determining the latest time to intervene, enacting and managing the intervention and seeking market response from all generators capable of meeting the system strength requirements. The market was informed after each direction was issued.

AEMO is also satisfied with the timeliness and adequacy of participant responses and communication throughout.