

POWER SYSTEM INCIDENT REPORT TRIP OF DEDERANG–WODONGA AND WODONGA–JINDERERA 330 KV LINES ON 4 FEBRUARY 2011

PREPARED BY: Electricity System Operations Planning and Performance

VERSION: 1.0

DATE: 2 June 2011

FINAL

Disclaimer

Purpose

This report has been prepared by the Australian Energy Market Operator Limited (AEMO) for the sole purpose of meeting obligations in accordance with clause 4.8.15 (c) of the National Electricity Rules.

No reliance or warranty

This report contains data provided by third parties and might contain conclusions or forecasts and the like that rely on that data. This data might not be free from errors or omissions. While AEMO has used due care and skill, AEMO does not warrant or represent that the data, conclusions, forecasts or other information in this report are accurate, reliable, complete or current or that they are suitable for particular purposes. You should verify and check the accuracy, completeness, reliability and suitability of this report for any use to which you intend to put it, and seek independent expert advice before using it, or any information contained in it.

Limitation of liability

To the extent permitted by law, AEMO and its advisers, consultants and other contributors to this report (or their respective associated companies, businesses, partners, directors, officers or employees) shall not be liable for any errors, omissions, defects or misrepresentations in the information contained in this report, or for any loss or damage suffered by persons who use or rely on such information (including by reason of negligence, negligent misstatement or otherwise). If any law prohibits the exclusion of such liability, AEMO's liability is limited, at AEMO's option, to the re-supply of the information, provided that this limitation is permitted by law and is fair and reasonable.

Abbreviations and Symbols

Abbreviation	Term
AEMO	Australian Energy Market Operator Ltd
EST	Eastern Standard Time
kV	kilovolt
MW	megawatt
MWh	megawatt hour (also MW·h)
NEM	National Electricity Market
EMS	Energy Management System
MMS	Market Management System

© 2011 Australian Energy Market Operator Ltd. All rights reserved.

1 Introduction

At 2030 hrs on 4 February 2011, the Dederang–Wodonga 330 kV line tripped. The line auto-reclosed at the Dederang end only. At the same time, the 060 Wodonga–Jindera 330 kV line opened at Jindera. As a result, 59 MW of customer load at Wodonga was interrupted until the Dederang–Wodonga line was manually closed at Wodonga at 2032 hrs. Lightning was reported in the area at the time of the incident. The 060 Wodonga–Jindera 330 kV line forms part of the interconnection between NSW and Victoria.

This report has been prepared to assess the adequacy of the provision and response of facilities and services and the appropriateness of actions taken to restore and maintain power system security.

Information for this report has been obtained largely from SP AusNet, TransGrid, and data from AEMO's Market Management System (MMS) and Energy Management System (EMS).

All references to time in this report refer to National Electricity Market time (Eastern Standard Time).

2 Summary of Events

At 2030 hrs on Friday 4 February 2011, the Dederang–Wodonga 330 kV line tripped and auto-reclosed at the Dederang end only. At the same time, the 060 Wodonga–Jindera 330 kV line opened at Jindera, interrupting supply to Wodonga 330 kV substation. Figures 1 and 2 show an overview of the 330 kV network between Dederang and Jindera before and after the incident. Lightning and thunderstorm activity were reported in the area at the time.

The auto-reclose of Dederang–Wodonga 330 kV line at Wodonga was unsuccessful as it requires a synchronising check, which was not possible because Wodonga lost supply when the Wodonga–Jindera line opened at Jindera at the same time.

This incident resulted in the interruption of 59 MW of customer load at Wodonga. This load was restored after the Dederang–Wodonga line was manually closed at Wodonga at 2032 hrs. The 060 Wodonga–Jindera line was also returned to service shortly after at 2035 hrs.




Figure 1 – Overview of the 330 kV network between Dederang and Jindera (before the incident)




Figure 2 – Overview of the 330 kV network between Dederang and Jindera (immediately after the incident)

3 Immediate Actions

At 2126 hrs, AEMO issued a Market Notice 34390 declaring the simultaneous loss of both the Dederang–Wodonga and Wodonga–Jindera 330 kV lines as a single credible contingency.

Investigations by TransGrid revealed that the No. 1 protection system of the Jindera–Wodonga 330 kV line at Jindera operated at the same time (that is, at 2030 hrs) the Dederang–Wodonga 330 kV line tripped. Investigations further revealed that circuit breakers 0602A and 0602B of Jindera–Wodonga 330 kV line at Jindera opened due to the operation of the No. 1 protection system. This protection system uses distance protection in a blocking scheme, relying on a blocking signal from the remote end to ensure correct discrimination. The distance protection at Jindera operated in accelerated zone 2 time in the absence of a blocking signal from the Wodonga end.

SP AusNet advised that a wiring error was found in protection circuits of the Jindera–Wodonga 330 kV line at Wodonga, which prevented the blocking signals being sent to Jindera. This error was subsequently corrected and tested to confirm correct operation. SP AusNet believes this error may have been introduced when the protection signalling function was upgraded from the old power line carrier system to the new optical ground wire (OPGW) communications system.

On 25th February 2011 at 1033 hrs, AEMO issued a Market Notice 34646 cancelling the declaration of the simultaneous loss of both the Dederang–Wodonga and Wodonga–Jindera 330 kV lines as a single credible contingency.

4 Power System Security Assessment

There were no power system security violations flagged in AEMO's real-time power system security monitoring applications during the incident. The power system frequency remained within the frequency operating standards. All affected equipment was returned to service promptly after the incident.

5 Follow-up Actions

Nil.

6 Conclusions

At 2030 hrs on 04 February 2011, the Dederang–Wodonga 330 kV line tripped at both ends and then auto-reclosed at Dederang. This line trip is attributable to the lightning activity in the vicinity. The 060 Wodonga–Jindera 330 kV line opened at the Jindera end at the same time, interrupting 59 MW of customer load at Wodonga and blocking the auto-reclose of the Dederang–Wodonga 330 kV line. The customer load was restored when the Dederang–Wodonga 330 kV line was manually closed at Wodonga at 2032 hrs. The Wodonga–Jindera line tripped due to the absence of a protection blocking signal from Wodonga caused by a wiring error in protection at Wodonga. This error has since been corrected.

7 Recommendations

Nil.