

Test Report

for

Felicity Smart Infrastructure Pty Ltd

166 Plateau Rd, Bilgola, NSW, 2107 Australia

LED Street Light

Model: GYRO-P-40-600

Laboratory: Leading Testing Laboratories

NVLAP CODE: 200960-0

3rd Floor, Bld. 2, NO. 96 Longchuanwu Rd Qianjiang Economy Dev. Zone, YuhangDist,
Hangzhou, Zhejiang Province, China 311100

Tel: +86571 86376106

www.ledtestlab.com

Report No.: HZ20020023q

The laboratory that conducted the testing detailed in this report has been accredited for SSL by NVLAP.

Test specifications:


Date of Receipt : Feb. 29, 2020

Date of Test : Apr. 07, 2020

Test item : Input Voltage, Running Current, Power Factor, Load (watts), THD A%

Reference Standard : IESNA LM-79-2008 - Approved Method for the Electrical and Photometric Measurements of Solid-State Lighting Products
Unmetered Load Guideline - Determination of Device Load and Annual Energy Consumption for Unmetered Device Types_V1.0

Review by:



Engineer: April Zou
Apr. 08, 2020

Approved by:



Manager: Jim Zhang
Apr. 08, 2020

Note: This report does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

Test Results

Test ambient temperature was 25.0 °C.

There are 10 pcs samples provided by manufacturer and no seasoning to them.

The samples are installed straight down, no dimmer in the test circuit.

The parameters are read by YOKOGAWA Digital Power Meter WT210, the accuracy of power is ±0.1W.

The stabilization time of the each sample was 120 minutes, and the total operating time including stabilization was 121 minutes.

Sample No.	Input Voltage (V)	Input Frequency (Hz)	Input Current (A)	Input Power (W)	Power Factor	THD A%
1	250.02	50	0.2943	71.68	0.9739	7.36
2	250.01	50	0.2992	72.62	0.9738	6.98
3	250.03	50	0.2964	72.47	0.9773	7.92
4	250.04	50	0.2953	72.03	0.9755	7.55
5	249.97	50	0.2999	73.03	0.9748	7.04
6	249.95	50	0.2931	71.54	0.9757	8.02
7	249.95	50	0.2984	72.67	0.9743	7.13
8	250.03	50	0.2939	71.67	0.9759	7.98
9	250.01	50	0.3007	73.41	0.9767	7.07
10	250.04	50	0.2999	73.15	0.9760	6.97
Average	250.01	50	0.2971	72.43	0.9754	7.40

Table 1: Electrical Parameters Results

Sample Photo



Equipment Under Test(EUT)

Name : LED Street Light
Model : GYRO-P-40-600
Electrical Ratings : 220-240V, 50/60Hz, 75W
Manufacturer : Felicity Smart Infrastructure Pty Ltd
Address : 166 Plateau Rd, Bilgola, NSW, 2107Australia

Prepared by: Leading Testing Laboratories
 3rd Floor, Bld. 2, NO. 96 Longchuanwu Rd Qianjiang Economy Dev. Zone, YuhangDist,
 Hangzhou, Zhejiang Province, China 311100
 Tel: +86 571 86376106 www.ledtestlab.com

Equipment List

Test Equipment	Model	Equipment No.	Calibration Date	Calibration Due date
Digital Power Meter	WT210	HZTE008-01	Aug. 02, 2019	Aug. 01, 2020
AC Power Supply	PCR 500L	HZTE001-07	Aug. 02, 2019	Aug. 01, 2020
Temperature and humidity recorder	JR900	HZTE018-02	Aug. 02, 2019	Aug. 01, 2020

Table 2: Test Equipment List

Test Methods

Seasoning of SSL Product

For the purpose of rating new SSL products, SSL products shall be tested with no seasoning. Therefore, no seasoning was performed.

Ambient Conditions

The ambient temperature in which measurements are being taken shall be maintained at $25\text{ }^{\circ}\text{C} \pm 1\text{ }^{\circ}\text{C}$, measured at a point not more than 1 m from the SSL product and at the same height as the SSL product. The temperature sensor shall be shielded from direct optical radiation from the SSL product and optical radiation from any other source.

Stabilization of SSL Product

Before measurements are taken, the SSL product under test shall be operated long enough to reach stabilization and temperature equilibrium. The time required for stabilization depends on the type of SSL products under test. The stabilization time typically ranges from 30 min (small integrated LED lamps) to 2 or more hours for large SSL luminaires). It can be judged that stability is reached when the variation (maximum – minimum) of at least 3 readings of the light output and electrical power over a period of 30 min, taken 15 minutes apart, is less than 0.5 %.

*** End of Report ***

This report is considered invalidated without the Special Seal for Inspection of the LTL. This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of LTL, this test report shall not be copied except in full and published as advertisement.