

Mr David Ripper
Senior Metrology Engineer
Australian Energy Market Operator LTD
500 Collins Street
Melbourne, Vic 3000
30th April 2021

F.A.O Mr David Ripper

Re. Inclusion of AEC Luminaire Load onto National Electricity Load Table

We would like to request that the following luminaires with credentials as noted below be included on the NEM Load Table:

Model Tested	Device Type Description	Test Report Ref	Nominal Power	System Power	External Marking
AEC Italo 1 0F2 STA 3.3-2M	AEC Italo 1 0F2 STA 3.3-2M (QLD 2021)	21-0235	19W	19.5W	L19

Please note that in addition to the exact device noted in the above table, there are additional devices in our range that are electrically identical and may be used in unmetered installation in the future. The reason being that AEC produce many luminaires with identical light engines i.e. the same LED boards, LED drivers and SPD device.

All luminaires under this submission are controlled by integral photocell as per the test.

Please also find attached with this submission:

- Letter from Sunshine Coast Council;
- Power test documentation;
- Luminaire specification sheets.

You will notice that the luminaire coding on the test report has an extra string of text 'cl 2' featured at the end. This just refers to insulation class 2. This has no impact on the load of the luminaire.

Please get in touch if you require anything further to process this request.

Regards,
Steven J. Hare



General Manager