



Light Emission Distribution Laboratory

Division of Photometry & Electrical Testing Pty. Ltd ABN 11 166 255 134
Unit 4, 140 George St. Hornsby NSW 2077 Australia
Ph: +61 2 9476 3097 E: sales@ledlab.com.au



Accredited for compliance with ISO/IEC 17025 – For Testing. Accreditation No. 19541

Test Report: 210354LCP

Testing of Wireless NB-IOT Lighting Controller Power for AEMO's NEM Load Table and other tests on optical systems

for CIMCON Intelligent wireless NB-IOT lighting controller

Type of product: NB-IOT Wireless Lighting Controller

Prepared for: Sylvania Schröder, Bldg 4A, Parklands Estate, 21-23 South Street, Rydalmere NSW 2116 Australia

Model number: iSLC3100-7P-N-AD-G-IO-CATC-05-SW

Description: CIMCON Intelligent wireless NB-IOT lighting controller to control ON/OFF switching, dimming control, GPS, power metering, sensor inputs, status and health monitoring of Streetlight.

Test objective and Method

Determination of the device supply operating parameters Voltage, Current, Power and Power Factor when tested at nominal test voltages of 250V. By the method of LEDLab Electrical Parameter Determination and AEMO Unmetered_Load_Guideline_v1_0.

Test configuration

The ten nodes supplied by the client were mounted into the test jig and operated at 25°C ambient temperature at 250VAC, 50Hz, until the monitored sample stabilised (30 minutes). Twenty readings were taken ten seconds apart and the average found. The average value is multiplied by the Calibration Correction given in the latest NATA endorsed calibration report. The other nine units having operated for the same or more time are switched one by one to the Wattmeter for their twenty readings. Note that, 5 samples were supplied with their relays ON and the 5 others with their relays OFF.

Client contact: Swati Dhembre, Bldg 4A Parklands Estate | 21-23 South St Rydalmere, NSW 2116, Australia.

Conclusion

The Average Load (W) with relay ON is 2.03W at 0.47 Power Factor.

The Average Load (W) with relay OFF is 1.43W at 0.38 Power Factor.

Tested by: David Orwin On 07/04/2021 Authorised Signatory

Date: 09/04/2021

Alain Yetendje

Results

Time till stabilisation: 30min

Electrical Measurements

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|---|-----------------------|----------------------|-----------------|--------------|
| Sample 1 | | | | |
| Average | 249.997 | 0.016 | 1.452 | 0.385 |
| Min | 249.040 | 0.016 | 1.433 | 0.384 |
| Max | 251.380 | 0.016 | 1.477 | 0.388 |
| Calibration correction (see Newton 4 th calibration) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.06 | 0.0156 | 1.45 | 0.385 |

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|---|-----------------------|----------------------|-----------------|--------------|
| Sample 2 | | | | |
| Average | 250.014 | 0.016 | 1.380 | 0.385 |
| Min | 248.620 | 0.015 | 1.358 | 0.384 |
| Max | 250.790 | 0.016 | 1.449 | 0.388 |
| Calibration correction (see Newton 4 th calibration) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.08 | 0.0153 | 1.38 | 0.385 |

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|---|-----------------------|----------------------|-----------------|--------------|
| Sample 3 | | | | |
| Average | 250.534 | 0.016 | 1.415 | 0.385 |
| Min | 249.710 | 0.016 | 1.395 | 0.384 |
| Max | 251.320 | 0.016 | 1.441 | 0.388 |
| Calibration correction (see Newton 4 th calibration) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.60 | 0.0157 | 1.42 | 0.385 |

The tests and measurements covered by this document are traceable to Australian national standards of measurement. This report only applies to the items tested as received from the client and shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab).

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|---|-----------------------|----------------------|-----------------|--------------|
| Sample 4 | | | | |
| Average | 250.144 | 0.017 | 1.467 | 0.385 |
| Min | 249.020 | 0.017 | 1.454 | 0.384 |
| Max | 251.450 | 0.017 | 1.491 | 0.388 |
| Calibration correction (see Newton 4 th calibre) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.21 | 0.0165 | 1.47 | 0.385 |

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|---|-----------------------|----------------------|-----------------|--------------|
| Sample 5 | | | | |
| Average | 250.089 | 0.016 | 1.432 | 0.385 |
| Min | 249.210 | 0.016 | 1.404 | 0.384 |
| Max | 250.560 | 0.017 | 1.588 | 0.388 |
| Calibration correction (see Newton 4 th calibre) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.15 | 0.0162 | 1.43 | 0.385 |

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|---|-----------------------|----------------------|-----------------|--------------|
| Sample 6 | | | | |
| Average | 250.403 | 0.020 | 2.089 | 0.470 |
| Min | 249.570 | 0.020 | 2.030 | 0.467 |
| Max | 251.080 | 0.021 | 2.184 | 0.476 |
| Calibration correction (see Newton 4 th calibre) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.46 | 0.0197 | 2.09 | 0.470 |

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|---|-----------------------|----------------------|-----------------|--------------|
| Sample 7 | | | | |
| Average | 250.112 | 0.020 | 1.955 | 0.470 |
| Min | 249.380 | 0.020 | 1.946 | 0.467 |
| Max | 250.680 | 0.020 | 2.006 | 0.476 |
| Calibration correction (see Newton 4 th calibre) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.17 | 0.0195 | 1.96 | 0.470 |

The tests and measurements covered by this document are traceable to Australian national standards of measurement.
This report only applies to the items tested as received from the client and shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab).

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|----------|-----------------------|----------------------|-----------------|--------------|
| Sample 8 | | | | |
| Average | 249.972 | 0.020 | 2.095 | 0.470 |
| Min | 248.640 | 0.020 | 2.076 | 0.467 |
| Max | 251.070 | 0.021 | 2.111 | 0.476 |

| | | | | |
|---|---------|---------|---------|--------|
| Calibration correction (see Newton 4 th calibre) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.03 | 0.0200 | 2.10 | 0.470 |

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|----------|-----------------------|----------------------|-----------------|--------------|
| Sample 9 | | | | |
| Average | 250.262 | 0.020 | 1.992 | 0.470 |
| Min | 249.260 | 0.020 | 1.978 | 0.467 |
| Max | 250.770 | 0.020 | 2.013 | 0.476 |

| | | | | |
|---|---------|---------|---------|--------|
| Calibration correction (see Newton 4 th calibre) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 250.32 | 0.0197 | 1.99 | 0.470 |

| | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|-----------|-----------------------|----------------------|-----------------|--------------|
| Sample 10 | | | | |
| Average | 249.866 | 0.020 | 2.031 | 0.470 |
| Min | 248.630 | 0.019 | 1.856 | 0.467 |
| Max | 251.070 | 0.021 | 2.115 | 0.476 |

| | | | | |
|---|---------|---------|---------|--------|
| Calibration correction (see Newton 4 th calibre) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Instrument impedance correction (N4) | | 0.00024 | 0.0000 | |
| Final value | 249.93 | 0.0202 | 2.03 | 0.470 |

Electrical operating parameters of CIMCON intelligent wireless NB-IOT Lighting Controller (iSLC3100-7P-

| Sample No. | Serial No. | Relay State (ON/OFF) | Supply Voltage (Vrms) | Input Current (Arms) | Input Power (W) | Power Factor |
|------------|------------|----------------------|-----------------------|----------------------|-----------------|--------------|
| Sample 1 | 1342177281 | OFF | 249.997 | 0.016 | 1.452 | 0.385 |
| Sample 2 | 1342177289 | OFF | 250.014 | 0.015 | 1.380 | 0.385 |
| Sample 3 | 1342177286 | OFF | 250.534 | 0.016 | 1.415 | 0.385 |
| Sample 4 | 1342177288 | OFF | 250.144 | 0.017 | 1.467 | 0.385 |
| Sample 5 | 1342177287 | OFF | 250.089 | 0.016 | 1.432 | 0.385 |
| Sample 6 | 1342177641 | ON | 250.403 | 0.020 | 2.090 | 0.470 |
| Sample 7 | 1342177639 | ON | 250.112 | 0.019 | 1.955 | 0.470 |
| Sample 8 | 1342177638 | ON | 249.972 | 0.020 | 2.095 | 0.470 |
| Sample 9 | 1342177637 | ON | 250.262 | 0.020 | 1.992 | 0.470 |
| Sample 10 | 1342177681 | ON | 249.866 | 0.020 | 2.031 | 0.470 |

Illustration 1: Electrical operating parameters of CIMCON Intelligent wireless NB-IOT lighting controller (iSLC3100-7P-N-AD-G-IO-CATC-05-SW)

Uncertainties

At a Confidence Level of 95% with a Coverage Factor of 2

Supply Voltage: $\pm 0.07\%$

Supply Current: $\pm 0.14\%$

Supply Power: $\pm 0.19\%$

Power Factor: ± 0.005

Ambient Temperature: $\pm 1^\circ\text{C}$

Test Equipment Used

Power meter: Newton 4th Power Analyser KinetiQ Model PPA2520 SN 133-00467

Power meter integration time (s): 5

Calibration Report: PlusEs report no. 2020002794

Luminaire thermometer: AMA S No. 1086110-0.1°



Illustration 2: Nodes (Relay ON/Relay OFF)



Illustration 3: Label



Illustration 4: Setup

The tests and measurements covered by this document are traceable to Australian national standards of measurement. This report only applies to the items tested as received from the client and shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab).