


Monthly Constraint Report

April 2025

A report for the National Electricity Market on Constraint results.





Important notice

Purpose

This publication has been prepared by AEMO to provide information about constraint equation performance and related issues, as at the date of publication.

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.



Contents

| | | |
|-----|---|----|
| 1 | Introduction | 5 |
| 2 | Constraint Equation Performance | 5 |
| 2.1 | Top 10 binding constraint equations | 5 |
| 2.2 | Top 10 binding impact constraint equations | 6 |
| 2.3 | Top 10 violating constraint equations | 6 |
| 2.4 | Top 10 binding interconnector limit setters | 8 |
| 2.5 | Constraint Automation Usage | 9 |
| 2.6 | Binding Dispatch Hours | 9 |
| 2.7 | Binding Constraint Equations by Limit Type | 11 |
| 2.8 | Binding Impact Comparison | 11 |
| 2.9 | Pre-dispatch RHS Accuracy | 12 |
| 3 | Generator / Transmission Changes | 14 |
| 3.1 | Constraint Equation Changes | 14 |

Tables

| | | |
|---------|--|----|
| Table 1 | Top 10 binding network constraint equations | 5 |
| Table 2 | Top 10 binding impact network constraint equations | 6 |
| Table 3 | Reasons for constraint equation violations | 7 |
| Table 4 | Reasons for constraint equation violations | 7 |
| Table 5 | Top 10 binding interconnector limit setters | 8 |
| Table 6 | Top 10 largest Dispatch / Pre-dispatch differences | 12 |
| Table 7 | Generator and transmission changes | 14 |

Figures

| | | |
|----------|--|----|
| Figure 1 | Interconnector binding dispatch hours | 10 |
| Figure 2 | Regional binding dispatch hours | 10 |
| Figure 3 | Binding by limit type | 11 |
| Figure 4 | Binding Impact comparison | 12 |
| Figure 5 | Constraint equation changes | 15 |
| Figure 6 | Constraint equation changes per month compared to previous two years | 15 |



1 Introduction

This report details constraint equation performance and transmission congestion related issues for April 2025. Included are investigations of violating constraint equations, usage of the constraint automation and performance of Pre-dispatch constraint equations. Transmission and generation changes are also detailed along with the number of constraint equation changes.

2 Constraint Equation Performance

2.1 Top 10 binding constraint equations

A constraint equation is binding when the power system flows managed by it have reached the applicable thermal or stability limit or the constraint equation is setting a Frequency Control Ancillary Service (FCAS) requirement. Normally there is one constraint equation setting the FCAS requirement for each of the eight services at any time. This leads to many more hours of binding for FCAS constraint equations - as such these have been excluded from the following table.

Table 1 Top 10 binding network constraint equations

| Constraint Equation ID (System Normal Bold) | Description | #DIs (Hours) | Limit Type |
|--|--|------------------|-----------------|
| V>NIL_FCSPS | Basslink limit from Vic to Tas for load enabled for FCSPS | 3220 (268.33) | Other |
| Q_STR_7COK_HASF_2 | No limit to Haughton Solar Farm if $Stan \geq 2 + Stan + Cal \geq 3 + Glad \geq 2 + (Stan + Cal + Glad) \geq 7$, $NQLD > 250 \& 270(AVG)$, $Ross_FN > 100 \& 120(AVG)$, Haughton Syncon is ON, Zero otherwise. | 2701 (225.08) | System Strength |
| N>NIL_94T | Out= Nil, avoid O/L Molong to Orange North (94T) on trip of Nil, Feedback | 2107 (175.58) | Thermal |
| Q_STR_8C_7C2K_RGUSF | No limit to Rugby Run SF to if $Stan \geq 3 + Cal \geq 1 + Glad \geq 2 + (Stan + Cal + Glad) \geq 8 +$ one SVC(Dysart/ Nebo/Strathmore)OS OR $Stan \geq 2 + Cal \geq 1 + Glad \geq 2 + (Stan + Cal + Glad) \geq 7 + Kar \geq 2 +$ Dysart SVC OS/Haughton Syncon ON, $NQLD > 350 \& 370(AVG)$, $Ross_FN > 150 \& 170(AVG)$, Zero otherwise | 2036 (169.66) | System Strength |
| Q_STR_7COK_HASF_4 | Limit to Haughton Solar Farm output depends on the number units online in Stanwell, Callide B, Callide C, Gladstone and Kareeya generators and Haughton Syncon, North Queensland demand, Zero if it does not meet minimum generator online. | 1382 (115.16) | System Strength |
| N>NIL_969 | Out= Nil, avoid O/L Gunnedah to Tamworth (969) on trip of Nil, Feedback. Metering is used as specified in OMS20 [Note: swamped with 96M or 9UJ or 9UH is O/S] | 1359 (113.25) | Thermal |
| N>NIL_901 | Out= Nil, avoid O/L West Wyalong to Temora 132kV (901) line on trip of Nil, Feedback | 1321 (110.08) | Thermal |
| N>NIL_9R6_991 | Out= Nil, avoid O/L Wagga North to Wagga (9R6) 132kV line on trip of Wagga North to Murrumburrah (991) 132kV line, Feedback | 1161 (96.75) | Thermal |
| VS_600_TEST | Out = Nil, Vic to SA on Heywood limit of 600 MW, limit for testing of Heywood interconnection upgrade | 1089 (90.75) | Other |
| S>NIL_MHNW1_MHNW2 | Out= Nil, avoid O/L Monash-North West Bend #2 132kV on trip of Monash-North West Bend #1 132kV line, Feedback | 1057 (88.08) | Thermal |

2.2 Top 10 binding impact constraint equations

Binding constraint equations affect electricity market pricing. The binding impact is used to distinguish the severity of different binding constraint equations.

The binding impact of a constraint is derived by summarising the marginal value for each dispatch interval (DI) from the marginal constraint cost (MCC) re-run¹ over the period considered. The marginal value is a mathematical term for the binding impact arising from relaxing the RHS of a binding constraint by one MW. As the market clears each DI, the binding impact is measured in \$/MW/DI.

The binding impact in \$/MW/DI is a relative comparison and a helpful way to analyse congestion issues. It can be converted to \$/MWh by dividing the binding impact by 12 (as there are 12 DIs per hour). This value of congestion is still only a proxy (and always an upper bound) of the value per MW of congestion over the period calculated; any change to the limits (RHS) may cause other constraints to bind almost immediately after.

Table 2 Top 10 binding impact network constraint equations

| Constraint Equation ID (System Normal Bold) | Description | ∑ Marginal Values | Limit Type |
|--|---|-------------------|-----------------|
| N>NIL_94T | Out= Nil, avoid O/L Molong to Orange North (94T) on trip of Nil, Feedback | 4,056,528 | Thermal |
| N>NIL_969 | Out= Nil, avoid O/L Gunnedah to Tamworth (969) on trip of Nil, Feedback. Metering is used as specified in OM520 [Note: swamped with 96M or 9UJ or 9UH is O/S] | 1,230,877 | Thermal |
| N>NIL_9R6_991 | Out= Nil, avoid O/L Wagga North to Wagga (9R6) 132kV line on trip of Wagga North to Murrumburrah (991) 132kV line, Feedback | 1,166,799 | Thermal |
| S_DALNTH1_LE_ZERO | Dalrymple BESS (BDU registration) Energy limit <= 0 MW | 822,500 | Unit Zero |
| N_DARLSF_FLT_65 | Limit Darlington Pt Solar Farm upper limit to 65 MW to manage post contingent voltage oscillation | 814,425 | System Strength |
| N_FINLYSF_FLT_40 | Limit Finley solar farm upper limit to 40 MW to manage post contingent voltage oscillation | 780,205 | System Strength |
| N_LIMOSF2_FLT_10 | Limit Limondale 2 solar farm upper limit to 10 MW to manage post contingent voltage oscillation | 767,518 | System Strength |
| V_BANNERTSF_FLT_45 | Limit Bannerton Solar Farm upper limit to 45 MW to manage post contingent voltage oscillation | 685,456 | System Strength |
| N_SUNRSF_FLT_60 | Limit Sunraysia solar farm upper limit to 60 MW to manage post contingent voltage oscillation | 651,788 | System Strength |
| N_LIMOSF1_FLT_50 | Limit Limondale 1 solar farm upper limit to 50 MW to manage post contingent voltage oscillation | 644,777 | System Strength |

2.3 Top 10 violating constraint equations

A constraint equation is violating when NEMDE is unable to dispatch the entities on the left-hand side (LHS) so the summated LHS value is less than or equal to, or greater than or equal to, the right-hand side (RHS) value (depending on the

¹ The MCC re-run relaxes any violating constraint equations and constraint equations with a marginal value equal to the constraint equation's violation penalty factor (CVP) x market price cap (MPC). The calculation caps the marginal value in each DI at the MPC value valid on that date. MPC is increased annually on 1st July.

mathematical operator selected for the constraint equation). The following table includes the FCAS constraint equations. Reasons for the violations are covered in 2.3.1.

Table 3 Top 10 violating constraint equations

| Constraint Equation ID (System Normal Bold) | Description | #DIs (Hours) | Limit Type |
|--|---|-----------------|-----------------|
| Q_STR_7COK_CKWF_1 | No limit to Clarke Creek Wind Farm if $Stan \geq 2 + Stan + Cal \geq 3 + Glad \geq 2 + (Stan + Cal + Glad) \geq 7 + (Haughton \text{ syncon ON or Kareeya} \geq 2)$, $NQLD > 250 \& 270(AVG)$, $Ross_FN > 100 \& 120(AVG)$, Clarke Creek Syncon is ON, Zero otherwise. | 8 (0.66) | System Strength |
| Q_STR_7COK_CKWF_3 | Limit Clarke Creek Windfarm output depends on the number units online in Stanwell, Callide B, Callide C, Gladstone and Kareeya generators and Clarke Creek Syncon, North Queensland demand, Zero if it does not meet minimum generator online. | 8 (0.66) | System Strength |
| N_BHBESS_G_OINV | Broken Hill Battery inverter limit of zero. Constraint to violate if Broken Hill Battery as a generator and inverter availability greater than zero. Swamp out otherwise. DS only | 7 (0.58) | System Strength |
| N_BHBESS_L_OINV | Broken Hill Battery inverter limit of zero. Constraint to violate if Broken Hill Battery as a load and inverter availability greater than zero. Swamp out otherwise. DS only | 7 (0.58) | System Strength |
| V_GANWRSF_OINV | Gannawarra Solar Farm inverter limit of zero. Constraint to violate if Gannawarra Solar Farm inverter availability greater than zero. Swamp out otherwise. DS only | 6 (0.5) | System Strength |
| Q_STR_7COK_KBWF_12 | Limit Kaban WF output depends on the number units online in Stanwell, Callide B, Callide C, Gladstone and Kareeya generators and Haughton Syncon, North Queensland demand, Zero if it does not meet minimum generator online. | 4 (0.33) | System Strength |
| Q_STR_7COK_KBWF_14 | Limit Kaban WF output depends on the number units online in Stanwell, Callide B, Callide C, Gladstone and Kareeya generators and Haughton Syncon, North Queensland demand, Zero if it does not meet minimum generator online. | 4 (0.33) | System Strength |
| Q_STR_7COK_KBWF_4 | Limit 80% to Kaban WF if $Stan \geq 2 + Stan + Cal \geq 3 + Glad \geq 2 + (Stan + Cal + Glad) \geq 7$, $Kar \geq 2$, $NQLD > 350 \& 370(AVG)$, $Ross_FN > 150 \& 170(AVG)$ (100% if Haughton Syncon ON or at night), 25% if $Kar < 0$ or if $NQLD > 250 \& 270(AVG)$, $Ross_FN > 100 \& 120(AVG)$ (40% if Syncon ON), Zero otherwise. | 4 (0.33) | System Strength |
| Q-X>RS2TX_TX_TX_C | Out= Two Ross 275/132 KV transformers, avoid O/L on the remaining Ross 275/132 KV transformer on trip of another Ross 275/132 KV transformer with 132 KV network between Ross and Woree closed, Feedback | 3 (0.25) | Thermal |
| Q_STR_7COK_MEWF_12 | Limit Mt Emerald WF output depends on the number units online in Stanwell, Callide B, Callide C, Gladstone and Kareeya generators and Haughton Syncon, North Queensland demand, Zero if it does not meet minimum generator online. | 3 (0.25) | System Strength |

2.3.1 Reasons for constraint equation violations

Table 4 Reasons for constraint equation violations

| Constraint Equation ID (System Normal Bold) | Description |
|--|--|
| Q_STR_7COK_CKWF_1 | Constraint equation violated for 2 consecutive DIs on 1/04/2025 1345 hrs and 1350 hrs and for 6 consecutive DIs on 1/04/2025 1450 hrs to 1515 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Clark Creek Wind Farm exceeding its MVAR limit. |
| Q_STR_7COK_CKWF_3 | Constraint equation violated for 2 consecutive DIs on 1/04/2025 1345 hrs and 1350 hrs and for 6 consecutive DIs on 1/04/2025 1450 hrs to 1515 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Clark Creek Wind Farm exceeding its MVAR limit. |
| N_BHBESS_G_OINV | Constraint equation violated for 3 non-consecutive DIs on 7/04/2025 0605 hrs, 13/04/2025 2055 hrs and 13/04/2025 2100 hrs and for 4 consecutive DIs on 30/04/2025 0905 hrs to 0920 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Broken Hill Battery inverter availability exceeding its limit. |

| Constraint Equation ID (System Normal Bold) | Description |
|--|--|
| N_BHBESS_L_OINV | Constraint equation violated for 3 non-consecutive DIs on 7/04/2025 0605 hrs, 13/04/2025 2055 hrs and 13/04/2025 2100 hrs and for 4 consecutive DIs on 30/04/2025 0905 hrs to 0920 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Broken Hill Battery inverter availability exceeding its limit. |
| V_GANWRSF_OINV | Constraint equation violated for 5 non-consecutive DIs on 1/04/2025 0625 hrs to 2/04/2025 0635 hrs and for 1 DI on 12/04/2025 0635 hrs with a violation degree of 0.01 MW. Constraint equation violated due to Gannawarra Solar Farm inverter availability exceeding its limit. |
| Q_STR_7COK_KBWF_12 | Constraint equation violated for 4 consecutive DIs on 1/04/2025 1345 hrs to 1400 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Kaban Wind Farm exceeding its MVAR limit. |
| Q_STR_7COK_KBWF_14 | Constraint equation violated for 4 consecutive DIs on 1/04/2025 1345 hrs to 1400 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Kaban Wind Farm exceeding its MVAR limit. |
| Q_STR_7COK_KBWF_4 | Constraint equation violated for 4 consecutive DIs on 1/04/2025 1345 hrs to 1400 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Kaban Wind Farm exceeding its MVAR limit. |
| Q-X>RS2TX_TX_TX_C | Constraint equation violated for 3 consecutive DIs on 29/04/2025 2115 hrs, 2120 hrs and 2125 hrs with a max violation degree of 3.37 MW occurring at 29/04/2025 2125 hrs. Constraint equation violated due to hand-dressed non-zero MVA values on outage/offloaded transformers at Ross. |
| Q_STR_7COK_MEWF_12 | Constraint equation violated for 3 consecutive DIs on 1/04/2025 1345 hrs, 1350 hrs and 1355 hrs with a violation degree of 0.001 MW. Constraint equation violated due to Mt Emerald Wind Farm exceeding its MVAR limit. |

2.4 Top 10 binding interconnector limit setters

Binding constraint equations can set the interconnector limits for each of the interconnectors on the constraint equation left-hand side (LHS). Table 5 lists the top (by binding hours) interconnector limit setters for all the interconnectors in the NEM and for each direction on that interconnector.

Table 5 Top 10 binding interconnector limit setters

| Constraint Equation ID (System Normal Bold) | Interconnect or | Description | #DIs (Hours) | Average Limit (Max) |
|--|---------------------|--|------------------|------------------------|
| V_T_NIL_FCSPS | T-V-MNSP1 Import | Basslink limit from Vic to Tas for load enabled for FCSPS | 2395 (199.58) | -443.67 (-477.99) |
| VS_600_TEST | V-SA Export | Out = Nil, Vic to SA on Heywood limit of 600 MW, limit for testing of Heywood interconnection upgrade | 1072 (89.33) | 550.88 (699.28) |
| VS_600_TEST | V-S-MNSP1 Export | Out = Nil, Vic to SA on Heywood limit of 600 MW, limit for testing of Heywood interconnection upgrade | 831 (69.25) | 133.36 (185.79) |
| S>NIL_MHNW1_MHNW2 | V-S-MNSP1 Export | Out= Nil, avoid O/L Monash-North West Bend #2 132kV on trip of Monash-North West Bend #1 132kV line, Feedback | 830 (69.17) | 160.3 (186.98) |
| N>Q-NIL_757_758 | N-Q-MNSP1 Export | Out= Nil, Avoid overloading 757 or 758 (T174 Terranora to H4 Mudgeeraba) 110kV line on trip of the other 758 or 757 (T174 Terranora to H4 Mudgeeraba line), Flow North, Feedback | 603 (50.25) | 96.43 (97.0) |
| N::N_03+4_2 | VIC1-NSW1 Export | Out= Lower Tumut - Yass (03) and Collector - Marulan (4) 330kV lines, stability limit (SNOWY-NSW) for critical fault on a 330kV line between Yass and Bannaby/Marulan | 529 (44.08) | 61.72 (757.4) |
| SVML^NIL_MH-CAP_ON | V-S-MNSP1 Import | Out=NIL, SA to Vic on ML upper transfer limit to manage voltage collapse at Monash (Note: applies when capacitor banks at Monash are available and I/S for switching.) | 485 (40.42) | -150.68 (-172.62) |
| F_MAIN++APD_TL_L60 | T-V-MNSP1 Import | Out = Nil, Lower 60 sec Service Requirement for a Mainland Network Event-loss of APD potlines due to undervoltage following a fault on MOPS-HYTS-APD 500 kV line, Basslink able to transfer FCAS | 457 (38.08) | -336.26 (-478.0) |

| Constraint Equation ID (System Normal Bold) | Interconnect or | Description | #Dis (Hours) | Average Limit (Max) |
|--|---------------------|---|-----------------|------------------------|
| F_MAIN++APD_TL_L5 | T-V-MNSP1 Import | Out = Nil, Lower 5 min Service Requirement for a Mainland Network Event-loss of APD potlines due to undervoltage following a fault on MOPS-HYTS-APD 500 kV line, Basslink able to transfer FCAS | 455 (37.92) | -404.15 (-478.0) |
| N>>NIL_85_86_S | NSW1-QLD1 Import | Out= NIL, avoid O/L Uralla to Tamworth (85) on trip of Armidale to Tamworth (86) line, Feedback | 429 (35.75) | -839.07 (-1155.35) |

2.5 Constraint Automation Usage

The constraint automation is an application in AEMO's energy management system (EMS) which generates thermal overload constraint equations based on the current or planned state of the power system. It is currently used by on-line staff to create thermal overload constraint equations for power system conditions where there were no existing constraint equations or the existing constraint equations did not operate correctly.

The following section details the reason for each invocation of the non-real time constraint automation constraint sets and the results of AEMO's investigation into each case.

Non-real time constraint automation was not used.

2.5.1 Further Investigation

Non-real time constraint automation was not used.


2.6 Binding Dispatch Hours

This section examines the number of hours of binding constraint equations on each interconnector and by region. The results are further categorized into five types: system normal, outage, FCAS (both outage and system normal), constraint automation and quick constraints.

In the following graph the export binding hours are indicated as positive numbers and import with negative values.




Figure 1 Interconnector binding dispatch hours



The regional comparison graph below uses the same categories as in Figure 1 as well as non-conformance, network support agreement and ramping. Constraint equations that cross a region boundary are allocated to the sending end region. Global FCAS covers both global and mainland requirements.


Figure 2 Regional binding dispatch hours



2.7 Binding Constraint Equations by Limit Type

The following pie charts show the percentage of dispatch intervals for April 2025 that the different types of constraint equations bound.


Figure 3 Binding by limit type



2.8 Binding Impact Comparison

The following graph compares the cumulative binding impact (calculated by summing the marginal values from the MCC re-run – the same as in section 2.2) for each month for the current year (indicated by type as a stacked bar chart) against the cumulative values from the previous two years (the line graphs). The current year is further categorised into system normal (NIL), outage, network support agreement (NSA) and negative residue constraint equation types.

Figure 4 Binding Impact comparison



2.9 Pre-dispatch RHS Accuracy

Pre-dispatch RHS accuracy is measured by the comparing the dispatch RHS value and the pre-dispatch RHS value forecast four hours in the future. The following table shows the pre-dispatch accuracy of the top ten largest differences for binding (in dispatch or pre-dispatch) constraint equations. This excludes FCAS constraint equations, constraint equations that violated in Dispatch, differences larger than ± 9500 (this is to exclude constraint equations with swamping logic) and constraint equations that only bound for one or two Dispatch intervals. AEMO investigates constraint equations that have a Dispatch/Pre-dispatch RHS difference greater than 5% and ten absolute difference which have either bound for greater than 25 dispatch intervals or have a greater than \$1,000 binding impact. The investigations are detailed in 2.9.1.

Table 6 Top 10 largest Dispatch / Pre-dispatch differences

| Constraint Equation ID (System Normal Bold) | Description | #DIs | % + Max Diff | % + Avg Diff |
|---|---|------|-----------------|----------------|
| V^SML_ARWBBA_1 | Out = Ballarat to Waubra to Ararat 220kV line (or any line section between Ballarat and Ararat), avoid voltage collapse for loss of Bendigo to Kerang 220kV line | 50 | 13,120% (81.48) | 447% (29.53) |
| V^SML_BUDP_3 | Out = Buronga to Balranald (X3) or Balranald to Darlington Pt (X5) 220 kV line, avoid voltage collapse for loss of Bendigo to Kerang 220kV line | 51 | 9,786% (69.53) | 307% (21.6) |
| V^SML_HORC_3 | Out = Horsham to Murra Warra to Red Cliffs 220kV line OR Murra Warra to Red Cliffs 220kV line, avoid voltage collapse for loss of Bendigo to Kerang 220kV line | 79 | 6,793% (58.01) | 156% (18.19) |
| V_S_HEYWOOD_UFLS | Out= Nil, Limit Heywood flows when SA under frequency load shedding (UFLS) is insufficient (i.e. when UFLS blocks in SA <1000 MW) to manage for double-circuit loss of Heywood IC. Note: Constraint is swamped if UFLS blocks ≥ 1000 MW. | 189 | 1,829% (9,482) | 878% (5,152) |
| N>N_LSDU_9U6_1 | Out= one of Lismore 132 to Dunoon 132kV line (9U6 or 9U7), avoid O/L the remaining 132kV line, NSW to Qld limit | 36 | 256% (74.13) | 36.65% (22.27) |

| Constraint Equation ID (System Normal Bold) | Description | #Dis | % + Max Diff | % + Avg Diff |
|--|--|------|---------------------|--------------------|
| V::N_NIL_V2 | Out = NIL, prevent transient instability for fault and trip of a HWTS-SMETS 500 kV line, VIC accelerates. Yallourn W G1 on 500kV. | 32 | 210% (200.48) | 31.01% (77.44) |
| I_6F_SN_150 | Discretionary limit of 150 MW on Bunday to Buronga (6F) 330 kV Line (SA to NSW) | 15 | 121.4% (1,027) | 61.35% (517) |
| Q>NIL_EMCM_6056 | Out= NIL, avoid thermal overload on Emerald to Comet (6056) 66 kV Feeder | 81 | 119.11% (61.18) | 40.02% (21.79) |
| V:T_HAPM_BL_1 | Out = Hadspen to Palmerston 220 kV line, limit Basslink flow VIC to TAS at low TAS fault levels to avoid inverter commutation instability following trip of remaining Hadspen to Palmerston 220 kV line, Tamar CCGT out of service | 58 | 100.43% (305.89) | 48.37% (158.13) |

2.9.1 Further Investigation

The following constraint equation(s) have been investigated:

V^SML_ARWBBA_1: Investigated and no improvement can be made to the constraint equation at this stage.

V^SML_BUDP_3: Investigated and no improvement can be made to the constraint equation at this stage.

V^SML_HORC_3: Investigated and no improvement can be made to the constraint equation at this stage.

V_S_HEYWOOD_UFLS: Investigated and no improvement can be made to the constraint equation at this stage. Changes to the status of the reactive devices between DS/PD contributes to the PD accuracy.

N>N_LSDU_9U6_1: Under investigation and will be improved if possible.

V::N_NIL_V2: Investigated and no improvement can be made to the constraint equation at this stage

Q>NIL_EMCM_6056: Investigated and no improvement can be made to the constraint equation at this stage.
N>>NIL_998: Investigated and no improvement can be made to the constraint equation at this stage.

V:T_HAPM_BL_1: Investigated and no improvement can be made to the constraint equation at this stage.

3 Generator / Transmission Changes

One of the main drivers for changes to constraint equations is from power system change, whether this is the addition or removal of plant (either generation or transmission). The following table details changes that occurred in April 2025.

Table 7 Generator and transmission changes

| Project | Date | Region | Notes |
|--------------------------|---------------|----------|--|
| Latrobe Valley Bess BDU | 8 April 2025 | Victoria | New Battery |
| Clarke Creek Wind Farm 2 | 23 April 2025 | Qld | New Generator |
| Mortlake Cut-in | 29 April 2025 | Victoria | Haunted Gully - Tarrone No.1 500 kV transmission line has been cut in at Mortlake Power Station (MOPS) to form the following transmission line sections: <ul style="list-style-type: none">• MOPS - Tarrone No.1 500 kV transmission line• MOPS - Haunted Gully No.1 500 kV transmission line |

3.1 Constraint Equation Changes


The following pie chart indicates the regional location of constraint equation changes. For details on individual constraint equation changes refer to the Weekly Constraint Library Changes Report² or the constraint equations in the MMS Data Model³.

² AEMO. *NEM Weekly Constraint Library Changes Report*. Available at: http://www.nemweb.com.au/REPORTS/CURRENT/Weekly_Constraint_Reports/

³ AEMO. *MMS Data Model*. Available at: <https://www.aemo.com.au/energy-systems/market-it-systems/nem-guides/wholesale-it-systems-software>



Figure 5 Constraint equation changes



The following graph compares the constraint equation changes for the current year versus the previous two years. The current year is categorised by region.

Figure 6 Constraint equation changes per month compared to previous two years

