

Affected Dispatch Interval Report

Trading Month March 2026

Prepared in accordance with
clause 7.11C.3 of the WEM Rules





1 Introduction

The Australian Energy Market Operator (AEMO) has prepared this report under clause 7.11C.3 of the Wholesale Electricity Market Rules (WEM Rules).

Clause 7.11C.3 of the WEM Rules requires AEMO to publish a report as soon as practicable after determining a Dispatch Interval is an Affected Dispatch Interval outlining:

- the reasons for determining that a Dispatch Interval was an Affected Dispatch Interval.
- whether that determination was correct; and
- what action will be taken to minimise the risk of a similar event in future.

In this report:

- the reporting period covers the period specified on the title page,
- terms that are capitalised but not defined have the meaning given in the WEM Rules; and,
- date references are to Trading Days, not calendar days, unless otherwise stated.

2 Affected Dispatch Interval(s)

This section provides details of the Dispatch Intervals AEMO has determined to be Affected Dispatch Intervals in accordance with 7.11C.2. In accordance with clause 7.11C.3(b) at the time of publication of this report AEMO considers the determination correct.

Trading Day	12 March 2026	
Dispatch Interval(s)	Affected Dispatch Interval	Replacement Market Schedule Run
	12/03/2026 15:30	Case File Corrected
	12/03/2026 15:35	Case File Corrected
	12/03/2026 15:50	Case File Corrected
Reasons for Determination [7.11C.3(a)]	<p>A procedural error during a routine site transfer caused a single SCADA Tag to flatline. The Case Files for the affected intervals were updated with the corrected Dispatch Inputs and were re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs under Clause 7.11B.1B(bA).</p> <p>AEMO has determined that these are Affected Dispatch Intervals as the market outcomes were based on manifestly incorrect information, which directly resulted in material impacts to Market Clearing Prices.</p>	
Determination Outcome [7.11C.3(b)]	Correct	
Actions Taken [7.11C.3(c)]	AEMO has reviewed and uplifted its systems and operational processes to ensure any future seamless site transfer.	