

Affected Dispatch Interval Report

Trading Month January 2025

Prepared in accordance with
clause 7.11C.3 of the WEM Rules





1 Introduction

The Australian Energy Market Operator (AEMO) has prepared this report under clause 7.11C.3 of the Wholesale Electricity Market Rules (WEM Rules).

Clause 7.11C.3 of the WEM Rules requires AEMO to publish a report as soon as practicable after determining a Dispatch Interval is an Affected Dispatch Interval outlining:

- the reasons for determining that a Dispatch Interval was an Affected Dispatch Interval.
- whether that determination was correct; and
- what action will be taken to minimise the risk of a similar event in future.

In this report:

- the reporting period covers the period specified on the title page,
- terms that are capitalised but not defined have the meaning given in the WEM Rules; and,
- date references are to Trading Days, not calendar days, unless otherwise stated.

2 Affected Dispatch Interval(s)

This section provides details of the Dispatch Intervals AEMO has determined to be Affected Dispatch Intervals in accordance with 7.11C.2. In accordance with clause 7.11C.3(b) at the time of publication of this report AEMO considers the determination correct.

| | | |
|-----------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|
| Trading Day | 20 January 2025 | |
| Dispatch Interval(s) | Affected Dispatch Interval | Replacement Market Schedule Run |
| | Intervals commencing 20/01/2024 15:50 16:05 – 16:25 17:25 – 17:40 17:50 – 18:35 18:45 – 19:25 19:35 19:45 – 20:00 20:15 – 20:35 20:55 – 21:00 inclusive. | Replaced with the original Dispatch Interval with corrected Dispatch Inputs as per clause 7.11B.1B(bA) in the WEM Rules. |
| Reasons for Determination [7.11C.3(a)] | <p>A series of constraints were invoked with the incorrect classification. These varied between:</p> <ul style="list-style-type: none"> • Incorrect Intervention Pricing Flag • Incorrect Constraint type <p>Both of these are classified as Manifestly Incorrect Dispatch Inputs.</p> <p>AEMO has determined that the intervals when the Incorrect Intervention Pricing Flag was used are Affected Dispatch Intervals where they directly resulted in material impacts to Market Clearing Prices..</p> | |
| Determination Outcome [7.11C.3(b)] | Correct | |
| Actions Taken [7.11C.3(c)] | <p>AEMO Control Room processes have been reviewed and updated to ensure that the intervention pricing flag is applied on the correct AEMO Intervention Event constraints.</p> | |

| Trading Day | 21 January 2025 | | | | | | | | | | | |
|-----------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|---------------------------------|---------------------------------|--------------------------------------------------------------------------------------------------------------------------|-------|-------|---------------|-------|------------|--|--|
| Dispatch Interval(s) | <table border="1"> <thead> <tr> <th>Affected Dispatch Interval</th> <th>Replacement Market Schedule Run</th> </tr> </thead> <tbody> <tr> <td>Intervals commencing 21/01/2024</td> <td rowspan="5">Replaced with the original Dispatch Interval with corrected Dispatch Inputs as per clause 7.11B.1B(bA) in the WEM Rules.</td> </tr> <tr> <td>11:30</td> </tr> <tr> <td>11:55</td> </tr> <tr> <td>12:20 – 12:30</td> </tr> <tr> <td>13:00</td> </tr> <tr> <td>inclusive.</td> <td></td> </tr> </tbody> </table> | Affected Dispatch Interval | Replacement Market Schedule Run | Intervals commencing 21/01/2024 | Replaced with the original Dispatch Interval with corrected Dispatch Inputs as per clause 7.11B.1B(bA) in the WEM Rules. | 11:30 | 11:55 | 12:20 – 12:30 | 13:00 | inclusive. | | |
| Affected Dispatch Interval | Replacement Market Schedule Run | | | | | | | | | | | |
| Intervals commencing 21/01/2024 | Replaced with the original Dispatch Interval with corrected Dispatch Inputs as per clause 7.11B.1B(bA) in the WEM Rules. | | | | | | | | | | | |
| 11:30 | | | | | | | | | | | | |
| 11:55 | | | | | | | | | | | | |
| 12:20 – 12:30 | | | | | | | | | | | | |
| 13:00 | | | | | | | | | | | | |
| inclusive. | | | | | | | | | | | | |
| Reasons for Determination [7.11C.3(a)] | <p>A single constraint set was invoked with the incorrect classification of:</p> <ul style="list-style-type: none"> Intervention Pricing Flag <p>This is classified as a Manifestly Incorrect Dispatch Input.</p> <p>AEMO has determined that the intervals when the Incorrect Intervention Pricing Flag was used are Affected Dispatch Intervals where they directly resulted in material impacts to Market Clearing Prices.</p> | | | | | | | | | | | |
| Determination Outcome [7.11C.3(b)] | Correct | | | | | | | | | | | |
| Actions Taken [7.11C.3(c)] | AEMO Control Room processes have been reviewed and updated to ensure that the intervention pricing flag is applied on the correct AEMO Intervention Event constraints. | | | | | | | | | | | |

| | | |
|-----------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|
| Trading Day | 23 January 2025 | |
| Dispatch Interval(s) | Affected Dispatch Interval | Replacement Market Schedule Run |
| | Intervals commencing 23/01/2024 11:10 – 12:00 12:20 – 12:30 15:30 – 15:45 16:00 16:10 16:50 – 17:00 17:10 17:35 17:45 – 17:50 18:10 18:20 18:35 18:55 19:05 19:45 – 19:50 20:15 – 20:25 20:35 inclusive. | Replaced with the original Dispatch Interval with corrected Dispatch Inputs as per clause 7.11B.1B(bA) in the WEM Rules. |
| Reasons for Determination [7.11C.3(a)] | A single constraint set was invoked with the incorrect classification of: <ul style="list-style-type: none"> Intervention Pricing Flag This is classified as a Manifestly Incorrect Dispatch Input. | |
| | AEMO has determined that the intervals when the Incorrect Intervention Pricing Flag was used are Affected Dispatch Intervals where they directly resulted in material impacts to Market Clearing Prices. | |
| Determination Outcome [7.11C.3(b)] | Correct | |
| Actions Taken [7.11C.3(c)] | AEMO Control Room processes have been reviewed and updated to ensure that the intervention pricing flag is applied on the correct AEMO Intervention Event constraints. | |