

# Affected Dispatch Interval Report

## Trading Month August 2025

Prepared in accordance with  
clause 7.11C.3 of the WEM Rules





# 1 Introduction

The Australian Energy Market Operator (AEMO) has prepared this report under clause 7.11C.3 of the Wholesale Electricity Market Rules (WEM Rules).

Clause 7.11C.3 of the WEM Rules requires AEMO to publish a report as soon as practicable after determining a Dispatch Interval is an Affected Dispatch Interval outlining:

- the reasons for determining that a Dispatch Interval was an Affected Dispatch Interval.
- whether that determination was correct; and
- what action will be taken to minimise the risk of a similar event in future.

In this report:

- the reporting period covers the period specified on the title page,
- terms that are capitalised but not defined have the meaning given in the WEM Rules; and,
- date references are to Trading Days, not calendar days, unless otherwise stated.

## 2 Affected Dispatch Interval(s)

This section provides details of the Dispatch Intervals AEMO has determined to be Affected Dispatch Intervals in accordance with 7.11C.2. In accordance with clause 7.11C.3(b) at the time of publication of this report AEMO considers the determination correct.

<b>Trading Day</b>	25 August 2025	
<b>Dispatch Interval(s)</b>	<b>Affected Dispatch Interval</b>	<b>Replacement Market Schedule Run</b>
	25/08/2025 21:20	Case File corrected.
	25/08/2025 21:25	
	25/08/2025 21:30	
	25/08/2025 21:35	
	25/08/2025 22:40	
	25/08/2025 22:55	
	25/08/2025 23:00	
	25/08/2025 23:05	
<b>Reasons for Determination [7.11C.3(a)]</b>	<p>During the intervals listed above, the following occurred:</p> <ul style="list-style-type: none"> <li>• Seven constraints were invoked with an incorrect classification of “Intervention Pricing Flag”; and</li> <li>• One constraint was incorrectly entered.</li> </ul> <p>The Case Files of the Affected Dispatch Intervals were updated with the correct Dispatch Inputs and were re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs for these intervals.</p> <p>AEMO has determined these are Affected Dispatch Intervals as the market outcomes were based on manifestly incorrect information, directly resulting in material impacts to Market Clearing Prices.</p>	
<b>Determination Outcome [7.11C.3(b)]</b>	Correct	
<b>Actions Taken [7.11C.3(c)]</b>	AEMO Control Room processes continue to be reviewed and updated to ensure that the intervention pricing flag is applied on the correct AEMO Intervention Event constraints.	