

# Affected Dispatch Interval Report

Trading Month October 2025

Prepared in accordance with  
clause 7.11C.3 of the WEM Rules





# 1 Introduction

The Australian Energy Market Operator (AEMO) has prepared this report under clause 7.11C.3 of the Wholesale Electricity Market Rules (WEM Rules).

Clause 7.11C.3 of the WEM Rules requires AEMO to publish a report as soon as practicable after determining a Dispatch Interval is an Affected Dispatch Interval outlining:

- the reasons for determining that a Dispatch Interval was an Affected Dispatch Interval.
- whether that determination was correct; and
- what action will be taken to minimise the risk of a similar event in future.

In this report:

- the reporting period covers the period specified on the title page,
- terms that are capitalised but not defined have the meaning given in the WEM Rules; and,
- date references are to Trading Days, not calendar days, unless otherwise stated.

## 2 Affected Dispatch Interval(s)

This section provides details of the Dispatch Intervals AEMO has determined to be Affected Dispatch Intervals in accordance with 7.11C.2. In accordance with clause 7.11C.3(b) at the time of publication of this report AEMO considers the determination correct.

|   |  |  |
|---|--|--|
| <b>Trading Day</b>                            | 3 October 2025   |  |
| <b>Dispatch Interval(s)</b>                   | <b>Affected Dispatch Interval</b>  | <b>Replacement Market Schedule Run</b> |
|   | 03/10/2025 14:10   | 03/10/2025 14:10                       |
|   | 03/10/2025 14:15   | 03/10/2025 14:15                       |
|   | 03/10/2025 14:20   | 03/10/2025 14:20                       |
|   | 03/10/2025 14:25   | 03/10/2025 14:25                       |
| <b>Reasons for Determination [7.11C.3(a)]</b> | <p>A SCADA tag for a single Facility flatlined. As this input contributes to the calculation of total Operational Demand, the error resulted in manifestly incorrect data being used to produce load forecasts, which are used by the Dispatch Algorithm to produce Market Schedules.</p> <p>In the absence of a suitable replacement Market Schedule under clauses 7.11B.1B(a), 7.11B.1B(b), and 7.11B.1B(bA) of the ESM Rules, AEMO cannot determine the variation of Market Clearing Prices, however, reasonably considers the manifestly incorrect data to have materially impacted Market Clearing Prices. The intervals will be replaced with themselves and are determined to be Affected Dispatch Intervals in accordance with clause 7.11B.1B(c).</p> |  |
| <b>Determination Outcome [7.11C.3(b)]</b>     | Correct  |  |
| <b>Actions Taken [7.11C.3(c)]</b>             | The issue with the flatlined tag has been resolved by the Facility.  |  |
| <b>Trading Day</b>                            | 5 October 2025   |  |



| Dispatch Interval(s) | Affected Dispatch Interval | Replacement Market Schedule Run |
|----------------------|----------------------------|---------------------------------|
|                      | 05/10/2025 08:00           | 05/10/2025 08:00                |
|                      | 05/10/2025 08:05           | 05/10/2025 08:05                |
|                      | 05/10/2025 08:10           | 05/10/2025 08:10                |
|                      | 05/10/2025 08:15           | 05/10/2025 08:15                |
|                      | 05/10/2025 08:20           | 05/10/2025 08:20                |
|                      | 05/10/2025 08:25           | 05/10/2025 08:25                |
|                      | 05/10/2025 08:30           | 05/10/2025 08:30                |
|                      | 05/10/2025 08:35           | 05/10/2025 08:35                |
|                      | 05/10/2025 08:40           | 05/10/2025 08:40                |
|                      | 05/10/2025 08:45           | 05/10/2025 08:45                |
|                      | 05/10/2025 08:50           | 05/10/2025 08:50                |
|                      | 05/10/2025 08:55           | 05/10/2025 08:55                |
|                      | 05/10/2025 09:00           | 05/10/2025 09:00                |
|                      | 05/10/2025 09:05           | 05/10/2025 09:05                |
|                      | 05/10/2025 09:10           | 05/10/2025 09:10                |
|                      | 05/10/2025 09:15           | 05/10/2025 09:15                |
|                      | 05/10/2025 09:20           | 05/10/2025 09:20                |
|                      | 05/10/2025 09:25           | 05/10/2025 09:25                |
|                      | 05/10/2025 09:30           | 05/10/2025 09:30                |
|                      | 05/10/2025 09:35           | 05/10/2025 09:35                |
|                      | 05/10/2025 09:40           | 05/10/2025 09:40                |
|                      | 05/10/2025 09:45           | 05/10/2025 09:45                |
|                      | 05/10/2025 09:50           | 05/10/2025 09:50                |
|                      | 05/10/2025 09:55           | 05/10/2025 09:55                |
|                      | 05/10/2025 10:00           | 05/10/2025 10:00                |
|                      | 05/10/2025 10:05           | 05/10/2025 10:05                |
|                      | 05/10/2025 10:10           | 05/10/2025 10:10                |
|                      | 05/10/2025 10:15           | 05/10/2025 10:15                |
|                      | 05/10/2025 10:20           | 05/10/2025 10:20                |
|                      | 05/10/2025 10:25           | 05/10/2025 10:25                |
|                      | 05/10/2025 10:30           | 05/10/2025 10:30                |
|                      | 05/10/2025 10:35           | 05/10/2025 10:35                |
|                      | 05/10/2025 10:40           | 05/10/2025 10:40                |
|                      | 05/10/2025 10:45           | 05/10/2025 10:45                |
|                      | 05/10/2025 10:50           | 05/10/2025 10:50                |
|                      | 05/10/2025 10:55           | 05/10/2025 10:55                |
|                      | 05/10/2025 11:00           | 05/10/2025 11:00                |
|                      | 05/10/2025 11:05           | 05/10/2025 11:05                |
|                      | 05/10/2025 11:10           | 05/10/2025 11:10                |
|                      | 05/10/2025 11:15           | 05/10/2025 11:15                |
|                      | 05/10/2025 11:20           | 05/10/2025 11:20                |
|                      | 05/10/2025 11:25           | 05/10/2025 11:25                |
|                      | 05/10/2025 11:30           | 05/10/2025 11:30                |

|                  |                  |
|------------------|------------------|
| 05/10/2025 11:35 | 05/10/2025 11:35 |
| 05/10/2025 11:40 | 05/10/2025 11:40 |
| 05/10/2025 11:45 | 05/10/2025 11:45 |
| 05/10/2025 11:50 | 05/10/2025 11:50 |
| 05/10/2025 11:55 | 05/10/2025 11:55 |
| 05/10/2025 12:00 | 05/10/2025 12:00 |
| 05/10/2025 12:05 | 05/10/2025 12:05 |
| 05/10/2025 12:10 | 05/10/2025 12:10 |
| 05/10/2025 12:15 | 05/10/2025 12:15 |
| 05/10/2025 12:20 | 05/10/2025 12:20 |
| 05/10/2025 12:25 | 05/10/2025 12:25 |
| 05/10/2025 12:30 | 05/10/2025 12:30 |
| 05/10/2025 12:35 | 05/10/2025 12:35 |
| 05/10/2025 12:40 | 05/10/2025 12:40 |
| 05/10/2025 12:45 | 05/10/2025 12:45 |
| 05/10/2025 12:50 | 05/10/2025 12:50 |
| 05/10/2025 12:55 | 05/10/2025 12:55 |
| 05/10/2025 13:00 | 05/10/2025 13:00 |
| 05/10/2025 13:05 | 05/10/2025 13:05 |
| 05/10/2025 13:10 | 05/10/2025 13:10 |
| 05/10/2025 13:15 | 05/10/2025 13:15 |
| 05/10/2025 13:20 | 05/10/2025 13:20 |
| 05/10/2025 13:25 | 05/10/2025 13:25 |
| 05/10/2025 13:30 | 05/10/2025 13:30 |
| 05/10/2025 13:35 | 05/10/2025 13:35 |
| 05/10/2025 13:40 | 05/10/2025 13:40 |
| 05/10/2025 13:45 | 05/10/2025 13:45 |
| 05/10/2025 13:50 | 05/10/2025 13:50 |
| 05/10/2025 13:55 | 05/10/2025 13:55 |
| 05/10/2025 14:00 | 05/10/2025 14:00 |
| 05/10/2025 14:05 | 05/10/2025 14:05 |
| 05/10/2025 14:10 | 05/10/2025 14:10 |
| 05/10/2025 14:15 | 05/10/2025 14:15 |
| 05/10/2025 14:20 | 05/10/2025 14:20 |
| 05/10/2025 14:25 | 05/10/2025 14:25 |
| 05/10/2025 14:30 | 05/10/2025 14:30 |
| 05/10/2025 14:35 | 05/10/2025 14:35 |
| 05/10/2025 14:40 | 05/10/2025 14:40 |
| 05/10/2025 14:45 | 05/10/2025 14:45 |
| 05/10/2025 14:50 | 05/10/2025 14:50 |
| 05/10/2025 14:55 | 05/10/2025 14:55 |
| 05/10/2025 15:00 | 05/10/2025 15:00 |
| 05/10/2025 15:05 | 05/10/2025 15:05 |
| 05/10/2025 15:10 | 05/10/2025 15:10 |

|  |                  |                  |
|--|------------------|------------------|
|  | 05/10/2025 15:15 | 05/10/2025 15:15 |
|  | 05/10/2025 15:20 | 05/10/2025 15:20 |
|  | 05/10/2025 15:25 | 05/10/2025 15:25 |
|  | 05/10/2025 15:30 | 05/10/2025 15:30 |
|  | 05/10/2025 15:35 | 05/10/2025 15:35 |
|  | 05/10/2025 15:40 | 05/10/2025 15:40 |
|  | 05/10/2025 15:45 | 05/10/2025 15:45 |
|  | 05/10/2025 15:50 | 05/10/2025 15:50 |
|  | 05/10/2025 15:55 | 05/10/2025 15:55 |
|  | 05/10/2025 16:00 | 05/10/2025 16:00 |
|  | 06/10/2025 03:35 | 06/10/2025 03:35 |
|  | 06/10/2025 03:40 | 06/10/2025 03:40 |
|  | 06/10/2025 03:45 | 06/10/2025 03:45 |
|  | 06/10/2025 03:50 | 06/10/2025 03:50 |
|  | 06/10/2025 03:55 | 06/10/2025 03:55 |
|  | 06/10/2025 04:00 | 06/10/2025 04:00 |
|  | 06/10/2025 07:40 | 06/10/2025 07:40 |
|  | 06/10/2025 07:45 | 06/10/2025 07:45 |
|  | 06/10/2025 07:50 | 06/10/2025 07:50 |
|  | 06/10/2025 07:55 | 06/10/2025 07:55 |

|  |  |
|--|--|
| <b>Reasons for Determination</b><br>[7.11C.3(a)] | <p>A SCADA tag for a single Facility flatlined. As this input contributes to the calculation of total Operational Demand, the error resulted in manifestly incorrect data being used to produce load forecasts, which are used by the Dispatch Algorithm to produce Market Schedules.</p> <p>In the absence of a suitable replacement Market Schedule under clauses 7.11B.1B(a), 7.11B.1B(b), and 7.11B.1B(bA) of the ESM Rules, AEMO cannot determine the variation of Market Clearing Prices, however, reasonably considers the manifestly incorrect data to have materially impacted Market Clearing Prices. The intervals will be replaced with themselves and are determined to be Affected Dispatch Intervals in accordance with clause 7.11B.1B(c).</p> |
| <b>Determination Outcome</b><br>[7.11C.3(b)]     | Correct  |
| <b>Actions Taken</b><br>[7.11C.3(c)]             | The issue with the flatlined tag has been resolved by the Facility.  |

|                             |                                   |  |
|-----------------------------|-----------------------------------|--|
| <b>Trading Day</b>          | 6 October 2025                    |  |
| <b>Dispatch Interval(s)</b> | <b>Affected Dispatch Interval</b> | <b>Replacement Market Schedule Run</b> |
|                             | 06/10/2025 08:00                  | 06/10/2025 08:00                       |
|                             | 06/10/2025 08:05                  | 06/10/2025 08:05                       |
|                             | 06/10/2025 08:10                  | 06/10/2025 08:10                       |

|                  |                  |
|------------------|------------------|
| 06/10/2025 08:15 | 06/10/2025 08:15 |
| 06/10/2025 08:20 | 06/10/2025 08:20 |
| 06/10/2025 08:25 | 06/10/2025 08:25 |
| 06/10/2025 08:30 | 06/10/2025 08:30 |
| 06/10/2025 08:35 | 06/10/2025 08:35 |
| 06/10/2025 08:40 | 06/10/2025 08:40 |
| 06/10/2025 08:45 | 06/10/2025 08:45 |
| 06/10/2025 08:50 | 06/10/2025 08:50 |
| 06/10/2025 08:55 | 06/10/2025 08:55 |
| 06/10/2025 09:00 | 06/10/2025 09:00 |
| 06/10/2025 09:05 | 06/10/2025 09:05 |
| 06/10/2025 09:10 | 06/10/2025 09:10 |
| 06/10/2025 09:15 | 06/10/2025 09:15 |
| 06/10/2025 09:20 | 06/10/2025 09:20 |
| 06/10/2025 09:25 | 06/10/2025 09:25 |
| 06/10/2025 09:30 | 06/10/2025 09:30 |
| 06/10/2025 09:35 | 06/10/2025 09:35 |
| 06/10/2025 09:40 | 06/10/2025 09:40 |
| 06/10/2025 09:45 | 06/10/2025 09:45 |
| 06/10/2025 09:50 | 06/10/2025 09:50 |
| 06/10/2025 09:55 | 06/10/2025 09:55 |
| 06/10/2025 10:00 | 06/10/2025 10:00 |
| 06/10/2025 10:05 | 06/10/2025 10:05 |
| 06/10/2025 10:10 | 06/10/2025 10:10 |
| 06/10/2025 10:15 | 06/10/2025 10:15 |
| 06/10/2025 10:20 | 06/10/2025 10:20 |
| 06/10/2025 10:25 | 06/10/2025 10:25 |
| 06/10/2025 10:30 | 06/10/2025 10:30 |
| 06/10/2025 10:35 | 06/10/2025 10:35 |
| 06/10/2025 10:40 | 06/10/2025 10:40 |
| 06/10/2025 10:45 | 06/10/2025 10:45 |
| 06/10/2025 10:50 | 06/10/2025 10:50 |
| 06/10/2025 10:55 | 06/10/2025 10:55 |
| 06/10/2025 11:00 | 06/10/2025 11:00 |
| 06/10/2025 11:05 | 06/10/2025 11:05 |
| 06/10/2025 11:10 | 06/10/2025 11:10 |
| 06/10/2025 11:15 | 06/10/2025 11:15 |
| 06/10/2025 11:20 | 06/10/2025 11:20 |
| 06/10/2025 11:25 | 06/10/2025 11:25 |
| 06/10/2025 11:30 | 06/10/2025 11:30 |
| 06/10/2025 11:35 | 06/10/2025 11:35 |
| 06/10/2025 11:40 | 06/10/2025 11:40 |
| 06/10/2025 11:45 | 06/10/2025 11:45 |
| 06/10/2025 11:50 | 06/10/2025 11:50 |

|  |                  |                  |
|--|------------------|------------------|
|  | 06/10/2025 11:55 | 06/10/2025 11:55 |
|  | 06/10/2025 12:00 | 06/10/2025 12:00 |
|  | 06/10/2025 12:05 | 06/10/2025 12:05 |
|  | 06/10/2025 12:10 | 06/10/2025 12:10 |
|  | 06/10/2025 12:15 | 06/10/2025 12:15 |
|  | 06/10/2025 12:20 | 06/10/2025 12:20 |
|  | 06/10/2025 12:25 | 06/10/2025 12:25 |
|  | 06/10/2025 12:30 | 06/10/2025 12:30 |
|  | 06/10/2025 12:35 | 06/10/2025 12:35 |
|  | 06/10/2025 12:40 | 06/10/2025 12:40 |
|  | 06/10/2025 12:45 | 06/10/2025 12:45 |
|  | 06/10/2025 12:50 | 06/10/2025 12:50 |
|  | 06/10/2025 12:55 | 06/10/2025 12:55 |
|  | 06/10/2025 13:00 | 06/10/2025 13:00 |
|  | 06/10/2025 13:05 | 06/10/2025 13:05 |
|  | 06/10/2025 13:10 | 06/10/2025 13:10 |
|  | 06/10/2025 13:15 | 06/10/2025 13:15 |
|  | 06/10/2025 13:20 | 06/10/2025 13:20 |
|  | 06/10/2025 13:25 | 06/10/2025 13:25 |
|  | 06/10/2025 13:30 | 06/10/2025 13:30 |
|  | 06/10/2025 13:35 | 06/10/2025 13:35 |

|  |   |
|--|---|
| <b>Reasons for Determination</b><br>[7.11C.3(a)] | <p>A SCADAtag for a single Facility flatlined. As this input contributes to the calculation of total Operational Demand, the error resulted in manifestly incorrect data being used to produce load forecasts, which are used by the Dispatch Algorithm to produce Market Schedules.</p> <p>In the absence of a suitable replacement Market Schedule under clauses 7.11B.1B(a), 7.11B.1B(b), and 7.11B.1B(bA) of the ESM Rules, AEMO cannot determine the variation of Market Clearing Prices, however, reasonably considers the manifestly incorrect data to have materially impacted Market Clearing Prices. The intervals will be replaced with themselves and are determined to be Affected Dispatch Intervals in accordance with clause 7.11B.1B(c).</p> |
| <b>Determination Outcome</b><br>[7.11C.3(b)]     | Correct   |
| <b>Actions Taken</b><br>[7.11C.3(c)]             | The issue with the flatlined tag has been resolved by the Facility.   |

|                             |                                   |  |
|-----------------------------|-----------------------------------|--|
| <b>Trading Day</b>          | 16 October 2025                   |  |
| <b>Dispatch Interval(s)</b> | <b>Affected Dispatch Interval</b> | <b>Replacement Market Schedule Run</b> |
|                             | 16/10/2025 11:30                  | 16/10/2025 11:30                       |

|  |                  |                  |
|--|------------------|------------------|
|  | 16/10/2025 11:35 | 16/10/2025 11:35 |
|  | 16/10/2025 11:40 | 16/10/2025 11:40 |
|  | 16/10/2025 11:45 | 16/10/2025 11:45 |
|  | 16/10/2025 11:50 | 16/10/2025 11:50 |
|  | 16/10/2025 11:55 | 16/10/2025 11:55 |
|  | 16/10/2025 12:00 | 16/10/2025 12:00 |
|  | 16/10/2025 12:05 | 16/10/2025 12:05 |
|  | 16/10/2025 12:10 | 16/10/2025 12:10 |

|   |   |
|---|---|
| <b>Reasons for Determination [7.11C.3(a)]</b> | <p>There were varying delays in the transfer of SWIS operational data for an unspecified number of Facilities and network elements to AEMO from Western Power. The error resulted in manifestly incorrect data being used by the Dispatch Algorithm to produce Market Schedules.</p> <p>In the absence of a suitable replacement Market Schedule under clauses 7.11B.1B(a), 7.11B.1B(b), and 7.11B.1B(bA) of the ESM Rules, AEMO cannot determine the variation of Market Clearing Prices, however, reasonably considers the manifestly incorrect data to have materially impacted Market Clearing Prices. The intervals will be replaced with themselves and are determined to be Affected Dispatch Intervals in accordance with clause 7.11B.1B(c).</p> |
| <b>Determination Outcome [7.11C.3(b)]</b>     | Correct   |
| <b>Actions Taken [7.11C.3(c)]</b>             | Communication fault rectified by Western Power.   |

|   |  |  |
|---|--|--|
| <b>Trading Day</b>                            | 21 October 2025  |  |
| <b>Dispatch Interval(s)</b>                   | <b>Affected Dispatch Interval</b>  | <b>Replacement Market Schedule Run</b> |
|   | 21/10/2025 09:25   | 21/10/2025 09:25                       |
|   | 21/10/2025 09:30   | 21/10/2025 09:30                       |
|   | 21/10/2025 09:35   | 21/10/2025 09:35                       |
|   | 21/10/2025 09:40   | 21/10/2025 09:40                       |
|   | 21/10/2025 09:45   | 21/10/2025 09:45                       |
|   | 21/10/2025 09:50   | 21/10/2025 09:50                       |
|   | 21/10/2025 09:55   | 21/10/2025 09:55                       |
|   | 21/10/2025 10:00   | 21/10/2025 10:00                       |
|   | 21/10/2025 10:05   | 21/10/2025 10:05                       |
| <b>Reasons for Determination [7.11C.3(a)]</b> | <p>The floored sent-out MW tags for a single Facility flatlined.</p> <p>As the floored sent-out MW tag input contributes to the calculation of total Operational Demand, the error resulted in manifestly incorrect data being used to produce load forecasts, which are used by the Dispatch Algorithm to produce Market Schedules.</p> |  |

|   |   |
|---|---|
|   | In the absence of a suitable replacement Market Schedule under clauses 7.11B.1B(a), 7.11B.1B(b), and 7.11B.1B(bA) of the ESM Rules, AEMO cannot determine the variation of Market Clearing Prices, however, reasonably considers the manifestly incorrect data to have materially impacted Market Clearing Prices. The intervals will be replaced with themselves and are determined to be Affected Dispatch Intervals in accordance with clause 7.11B.1B(c). |
| <b>Determination Outcome [7.11C.3(b)]</b> | Correct   |
| <b>Actions Taken [7.11C.3(c)]</b>         | The issue with the flatlined tag has been resolved by the Facility.   |

|   |   |  |
|---|---|--|
| <b>Trading Day</b>                            | 21 October 2025   |  |
| <b>Dispatch Interval(s)</b>                   | <b>Affected Dispatch Interval</b>   | <b>Replacement Market Schedule Run</b> |
|   | 21/10/2025 10:10  | Case File corrected.                   |
|   | 21/10/2025 10:15  |  |
|   | 21/10/2025 10:20  |  |
|   | 21/10/2025 10:25  |  |
|   | 21/10/2025 10:30  |  |
|   | 21/10/2025 10:35  |  |
|   | 21/10/2025 10:40  |  |
|   | 21/10/2025 10:45  |  |
|   | 21/10/2025 10:50  |  |
|   | 21/10/2025 10:55  |  |
|   | 21/10/2025 11:00  |  |
|   | 21/10/2025 11:05  |  |
|   | 21/10/2025 11:10  |  |
|   | 21/10/2025 11:15  |  |
|   | 21/10/2025 11:20  |  |
|   | 21/10/2025 11:25  |  |
| 21/10/2025 11:30                              |   |  |
| 21/10/2025 11:35                              |   |  |
| 21/10/2025 11:40                              |   |  |
| <b>Reasons for Determination [7.11C.3(a)]</b> | <p>The floored sent-out MW tags for a single Facility and the MW Available tag for a different single Facility flatlined.</p> <p>As the floored sent-out MW tag input contributes to the calculation of total Operational Demand, the error resulted in manifestly incorrect data being used to produce load forecasts, which are used by the Dispatch Algorithm to produce Market Schedules. There was no change to the Case File that could correct for the floored sent-out MW tag error.</p> <p>For the MW Available tag error, this resulted in manifestly incorrect data being used by the Dispatch Algorithm to produce Market Schedules. The Case Files</p> |  |

|  |  |
|--|--|
|  | <p>were updated with the correct Dispatch Inputs and were re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs for these intervals.</p> <p>AEMO has determined these are Affected Dispatch Intervals as the market outcomes were based on manifestly incorrect information, directly resulting in material impacts to Market Clearing Prices.</p> |
| <b>Determination Outcome</b><br>[7.11C.3(b)] | Correct  |
| <b>Actions Taken</b><br>[7.11C.3(c)]         | The issues with the flatlined tags have been resolved by the respective Facilities.  |

|                             |                                   |  |
|-----------------------------|-----------------------------------|--|
| <b>Trading Day</b>          | 21 October 2025                   |  |
| <b>Dispatch Interval(s)</b> | <b>Affected Dispatch Interval</b> | <b>Replacement Market Schedule Run</b> |
|                             | 21/10/2025 18:10                  | Case File corrected.                   |
|                             | 21/10/2025 18:20                  |  |
|                             | 21/10/2025 18:25                  |  |
|                             | 21/10/2025 18:35                  |  |
|                             | 21/10/2025 18:45                  |  |
|                             | 21/10/2025 18:50                  |  |
|                             | 21/10/2025 18:55                  |  |
|                             | 21/10/2025 19:00                  |  |
|                             | 21/10/2025 19:05                  |  |
|                             | 21/10/2025 19:10                  |  |
|                             | 21/10/2025 19:15                  |  |
|                             | 21/10/2025 19:20                  |  |
|                             | 21/10/2025 19:25                  |  |
|                             | 21/10/2025 19:30                  |  |
|                             | 21/10/2025 19:35                  |  |
|                             | 21/10/2025 19:40                  |  |
|                             | 21/10/2025 19:45                  |  |
|                             | 21/10/2025 19:55                  |  |
|                             | 21/10/2025 20:00                  |  |
|                             | 21/10/2025 20:05                  |  |
|                             | 21/10/2025 20:10                  |  |
|                             | 21/10/2025 20:15                  |  |
|                             | 21/10/2025 20:20                  |  |
|                             | 21/10/2025 20:25                  |  |
|                             | 21/10/2025 20:30                  |  |
|                             | 21/10/2025 20:35                  |  |
|                             | 21/10/2025 20:40                  |  |
|                             | 21/10/2025 21:05                  |  |
|                             | 21/10/2025 21:35                  |  |
|                             | 21/10/2025 22:00                  |  |

21/10/2025 22:15  
 21/10/2025 22:20  
 22/10/2025 03:15  
 22/10/2025 03:20  
 22/10/2025 03:40  
 22/10/2025 03:50  
 22/10/2025 03:55  
 22/10/2025 04:25  
 22/10/2025 04:30  
 22/10/2025 04:35  
 22/10/2025 04:50  
 22/10/2025 05:00  
 22/10/2025 05:05  
 22/10/2025 05:10  
 22/10/2025 05:15  
 22/10/2025 05:20  
 22/10/2025 05:30  
 22/10/2025 05:35  
 22/10/2025 05:40  
 22/10/2025 05:45  
 22/10/2025 05:50  
 22/10/2025 05:55  
 22/10/2025 06:00  
 22/10/2025 06:15  
 22/10/2025 06:20  
 22/10/2025 06:30  
 22/10/2025 06:40  
 22/10/2025 06:45  
 22/10/2025 06:50  
 22/10/2025 07:00  
 22/10/2025 07:05  
 22/10/2025 07:10  
 22/10/2025 07:15  
 22/10/2025 07:35  
 22/10/2025 07:40  
 22/10/2025 07:45  
 22/10/2025 07:50  
 22/10/2025 07:55

**Reasons for Determination [7.11C.3(a)]**

The AMP (current) tag was used, instead of the MW tag, to define constraints for some transmission lines. This caused the overcalculation of contingency risks during the affected intervals.

The Case Files for the Affected Intervals were updated with the correct Dispatch Inputs and were re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs for these intervals.

|  |  |
|--|--|
|  | AEMO has determined these are Affected Dispatch Intervals as the market outcomes were based on manifestly incorrect information, directly resulting in material impacts to Market Clearing Prices. |
| <b>Determination Outcome</b><br>[7.11C.3(b)] | Correct  |
| <b>Actions Taken</b><br>[7.11C.3(c)]         | Enhanced quality assurance processes for tag mapping.  |

|  |   |  |
|--|---|--|
| <b>Trading Day</b>                               | 23 October 2025   |  |
| <b>Dispatch Interval(s)</b>                      | <b>Affected Dispatch Interval</b>   | <b>Replacement Market Schedule Run</b> |
|  | 24/10/2025 00:20  | Case File corrected.                   |
| <b>Reasons for Determination</b><br>[7.11C.3(a)] | <p>The SCADA MW Available tag for a single Facility flatlined. The error resulted in manifestly incorrect data being used by the Dispatch Algorithm to produce Market Schedules.</p> <p>The Case File for the Affected Interval was updated with the correct Dispatch Inputs and was re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs for the interval.</p> <p>AEMO has determined that this is an Affected Dispatch Interval as the market outcomes were based on manifestly incorrect information, directly resulting in material impacts to Market Clearing Prices.</p> |  |
| <b>Determination Outcome</b><br>[7.11C.3(b)]     | Correct   |  |
| <b>Actions Taken</b><br>[7.11C.3(c)]             | The issue with the flatlined tag has been resolved by the Facility.   |  |

|  |   |  |
|--|---|--|
| <b>Trading Day</b>                               | 31 October 2025   |  |
| <b>Dispatch Interval(s)</b>                      | <b>Affected Dispatch Interval</b>   | <b>Replacement Market Schedule Run</b> |
|  | 31/10/2025 11:50  | Case File corrected.                   |
|  | 31/10/2025 11:55  |  |
|  | 31/10/2025 12:00  |  |
| <b>Reasons for Determination</b><br>[7.11C.3(a)] | <p>A single constraint set was invoked with the intervention flag incorrectly set to true instead of false.</p> <p>The Case Files for the Affected Intervals were updated with the intervention pricing flag set to false and were re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs for these intervals.</p> <p>AEMO has determined these are Affected Dispatch Intervals as the market outcomes were based on manifestly incorrect information, directly resulting in material impacts to Market Clearing Prices.</p> |  |



|  |  |
|--|--|
| <b>Determination Outcome</b><br>[7.11C.3(b)] | Correct  |
| <b>Actions Taken</b><br>[7.11C.3(c)]         | AEMO Control Room processes have been reviewed to ensure that the intervention pricing flag is applied on the correct AEMO Intervention Event constraints. |