

Affected Dispatch Interval Report

Trading Month September 2025

Prepared in accordance with
clause 7.11C.3 of the WEM Rules





1 Introduction

The Australian Energy Market Operator (AEMO) has prepared this report under clause 7.11C.3 of the Wholesale Electricity Market Rules (WEM Rules).

Clause 7.11C.3 of the WEM Rules requires AEMO to publish a report as soon as practicable after determining a Dispatch Interval is an Affected Dispatch Interval outlining:

- the reasons for determining that a Dispatch Interval was an Affected Dispatch Interval.
- whether that determination was correct; and
- what action will be taken to minimise the risk of a similar event in future.

In this report:

- the reporting period covers the period specified on the title page,
- terms that are capitalised but not defined have the meaning given in the WEM Rules; and,
- date references are to Trading Days, not calendar days, unless otherwise stated.

2 Affected Dispatch Interval(s)

This section provides details of the Dispatch Intervals AEMO has determined to be Affected Dispatch Intervals in accordance with 7.11C.2. In accordance with clause 7.11C.3(b) at the time of publication of this report AEMO considers the determination correct.

Trading Day	9 September 2025	
Dispatch Interval(s)	Affected Dispatch Interval	Replacement Market Schedule Run
	10/09/2025 03:40	Case File corrected
	10/09/2025 03:45	
	10/09/2025 05:15	
Reasons for Determination [7.11C.3(a)]	<p>A single constraint set was invoked with an incorrect classification of:</p> <ul style="list-style-type: none"> • Intervention Pricing Flag • <p>The Case Files for the affected intervals were updated with the correct Dispatch Inputs and were re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs for these intervals.</p> <p>AEMO has determined these are Affected Dispatch Intervals as the market outcomes were based on manifestly incorrect information, directly resulting in material impacts to Market Clearing Prices.</p>	
Determination Outcome [7.11C.3(b)]	Correct	
Actions Taken [7.11C.3(c)]	AEMO Control Room processes have been reviewed to ensure that the intervention pricing flag is applied on the correct AEMO Intervention Event constraints.	

Trading Day	17 September 2025	
Dispatch Interval(s)	Affected Dispatch Interval	Replacement Market Schedule Run
	17/09/2025 12:35	Case File corrected.
	17/09/2025 12:40	
	17/09/2025 12:45	
Reasons for Determination [7.11C.3(a)]	<p>A single constraint set was invoked with an incorrect classification of:</p> <ul style="list-style-type: none"> • Intervention Pricing Flag <p>The Case Files for the affected intervals were updated with the correct Dispatch Inputs and were re-run using the Dispatch Algorithm to produce the replacement Market Schedule Runs for these intervals.</p> <p>AEMO has determined these are Affected Dispatch Intervals as the market outcomes were based on manifestly incorrect information, directly resulting in material impacts to Market Clearing Prices.</p>	



Determination Outcome [7.11C.3(b)]	Correct
Actions Taken [7.11C.3(c)]	AEMO Control Room processes have been reviewed to ensure that the intervention pricing flag is applied on the correct AEMO Intervention Event constraints.