2026/27 Loss Factor Report

Public

29 May 2026



westernpower

Contents

1. Introduction **1**

2. Basis for Calculation **2**

2.1 Transmission loss factors 2

2.2 Average distribution loss factors 2

2.3 Individual distribution loss factors 2

3. Applicable Reference Services **4**

4. Transmission Loss Factors **6**

5. Average Distribution Loss Factors **12**

6. Individual Distribution Loss Factors **14**

7. Explanation for Changes in Loss Factors **22**

7.1 Transmission loss factors 22

7.2 Individual distribution loss factors 22

Appendix A Individual Transmission Loss Factors by NMI 24

Appendix B Individual Distribution Loss Factors by NMI 30

Appendix C Extinct Loss Factor Codes 41

1. Introduction

This report details the loss factors calculated for the 2026/27 financial year as required by section 2.27 of the Market Rules.

To comply with the obligations under section 2.27 of the Market Rules Western Power has:

- Recalculated all transmission loss factors.
- Recalculated all average distribution loss factors.
- Recalculated all individual distribution loss factors for customers with a Contracted Maximum Demand (CMD) greater than 7,000 kVA.
- Recalculated all individual distribution loss factors for customers with a CMD between 1,000 and 7,000 kVA located greater than 10 km from the electrically closest substation.
- Recalculated the individual distribution loss factors for customers with a CMD between 1,000 and 7,000 kVA located less than 10 km from the electrically closest substation, where an individual distribution loss factor has been elected by the associated retailer.
- Recalculated all individual distribution loss factors for distribution connected generation customers.

2. Basis for Calculation

Western Power calculates loss factors in accordance with the Market Procedure for Determining Loss Factors (the Market Procedure). The following sections provide further detail on the methodology used by Western Power in calculating loss factors.

2.1 Transmission loss factors

Western Power has calculated the transmission loss factors in accordance with section 4.1 of the Market Procedure using the software package T-price.

2.2 Average distribution loss factors

The methodology calculates the average distribution loss factors by:

- Determining losses within the zone substation transformers.
- Determining HV feeder losses.
- Determining distribution transformer losses.
- Determining LV feeder losses (allowing separately for residential and commercial losses).
- Western Power allocates the average distribution losses based on the usage of the various components of the network. An appropriate basis for this allocation is the reference services (offered in Western Power's access arrangement) and in accordance with the Market Procedure Western Power has determined an average loss factor for relevant reference services.

2.3 Individual distribution loss factors

Western Power calculates the individual distribution loss factors in accordance with section 4.2 of the Market Procedure.

The methodology used to calculate the individual distribution loss factors uses the formulae and methodology detailed in Schedule 4 of the Electricity Distribution Regulations 1997.[1] Schedule 4 of the Electricity Distribution Regulations 1997 is reproduced below:

1.	To calculate the loss factor for a distribution connection which is an exit point a corporation must follow the following steps:
(a)	the corporation must determine the line losses assuming the distribution connection was not there and assuming feeder maximum load;
(b)	the corporation must determine the line losses assuming only the distribution connection was there and assuming feeder maximum load;
(c)	the corporation must determine the total line losses assuming all the distribution connections are there (including the distribution connection for which the loss factor is being determined) and assuming feeder maximum load;

[1] For sites supplied from multiple feeders the distribution loss factor has been determined as if the load is evenly split across the feeders. The resultant distribution loss factor is the average of the calculated distribution loss factors.

(d) the corporation must allocate a share of the total line losses calculated under step (c) to the distribution connection for which the loss factor is being determined based on the ratio of the result of step (b) and the sum of the results of steps (a) and (b);

(e) the corporation must calculate the loss factor for the distribution connection by applying the following formula:

$$\text{LFExit} = 1 + \frac{A}{B}$$

where —

A (in kW) is the share of the total line losses allocated to the distribution connection under step (d);

B (in kW) is the contract maximum demand for the distribution connection.

2. To calculate the loss factor for a distribution connection which is an entry point a corporation must follow the following steps:

(a) the corporation must determine the line losses assuming the distribution connection was not there and assuming feeder maximum load;

(b) the corporation must determine the total line losses assuming all the distribution connections are there (including the distribution connection for which the loss factor is being determined) and assuming feeder maximum load;

(c) the corporation must calculate the loss decrease or increase for the distribution connection for which the loss factor is being determined by subtracting the result of step (b) from the result of step (a);

(d) the corporation must calculate the loss factor for the distribution connection by applying the following formula:

$$\text{LFEntry} = 1 + \frac{A}{B}$$

where —

A (in kW) is the loss increase or decrease calculated for the distribution connection under step (c);

B (in kW) is the declared sent-out capacity for the distribution connection.

3. Applicable Reference Services

The Market Procedure requires Western Power to define a subset of reference services as 'Applicable Reference Services'. The following table details the reference services that will be allocated to 'applicable reference services' from 1 July 2026.

Table 3.1: Applicable Reference Services

AA4 Reference services that are 'Applicable Reference Services'
A1 – Anytime Energy (Residential) Exit Service
A2 – Anytime Energy (Business) Exit Service
A3 – Time of Use Energy (Residential) Exit Service
A4 – Time of Use Energy (Business) Exit Service
A5 – High Voltage Metered Demand Exit Service C5 – High Voltage Metered Demand Bi-directional Service
A6 – Low Voltage Metered Demand Exit Service C6 – Low Voltage Metered Demand Bi-directional Service
C1 – Anytime Energy (Residential) Bi-directional Service
C2 – Anytime Energy (Business) Bi-directional Service
C3 – Time of Use (Residential) Bi-directional Service
C4 – Time of Use (Business) Bi-directional Service
A12 – 3 Part Time of Use Energy (Residential) Exit Service C9 – 3 Part Time of Use Energy (Residential) Bi-directional Service
A13 – 3 Part Time of Use Energy (Business) Exit Service C10 – 3 Part Time of Use Energy (Business) Bi-directional Service
A14 – 3 Part Time of Use Demand (Residential) Exit Service C11 – 3 Part Time of Use Demand (Residential) Bi-directional Service
A15 – 3 Part Time of Use Demand (Business) Exit Service C12 – 3 Part Time of Use Demand (Business) Bi-directional Service
A16 – Multi Part Time of Use Energy (Residential) Exit Service C13 – Multi Part Time of Use Energy (Residential) Bi-directional Service
A17 – Multi Part Time of Use Energy (Business) Exit Service C14 – Multi Part Time of Use Energy (Business) Bi-directional Service
A19 – Super Off-peak Energy (Business) Exit Service C17 – Super Off-peak Energy (Business) Bi-directional Service
A18 – Super Off-peak Energy (Residential) Exit Service C16 – Super Off-peak Energy (Residential) Exit Service

AA4 Reference services that are 'Applicable Reference Services'
A21 – Super Off-peak Demand (Business) Exit Service C19 – Super Off-peak Demand (Business) Bi-directional Service
A20 – Super Off-peak Demand (Residential) Exit Service C18 – Super Off-peak Demand (Residential) Bi-directional Service
C23 – LV Distribution Storage Bidirectional Service
C24 – HV Distribution Storage Bidirectional Service
A22 – Low Voltage Electric Vehicle Charging Exit Service C20 – Low Voltage Electric Vehicle Charging Bi-directional Service
A23 – High Voltage Electric Vehicle Charging Exit Service C21 – High Voltage Electric Vehicle Charging Bi-directional Service

4. Transmission Loss Factors

Western Power has calculated the following transmission loss factors for the 2026/27 financial year.

Table 4.1 - Transmission Loss Factors

TLF Code	Description	Applied in 2025/26	To apply in 2026/27
TAPA	Alcoa Pinjarra (Alcoa)	0.9651	0.9660
TAPL	Alcoa Pinjarra (Alinta)	0.9633	0.9653
TBLB	Bluewaters	0.9818	0.9833
TBLS	Boulder (SCE)	1.1601	1.1859
TKRA	Karara Three Springs	0.9972	0.9936
TLWA	Landwehr (Alinta)	0.9879	0.9859
TMBA	Mumbida Wind Farm	0.9214	0.9237
TMDP	Merredin Power Station	1.0403	1.1397
TMGS	Greenough River Solar Farm	0.9402	0.9540
TOLA	Oakley (Alinta)	0.9929	0.9935
TSAV	Transmission SWIN Average	1.0166	1.0206
TUAV	Transmission Urban Average	1.0140	1.0146
TWKG	West Kalgoorlie GTs	1.1006	1.1717
TWOJ	Worsley (Joint Venture)	0.9776	0.9828
TWOW	Worsley (Worsley)	0.9783	0.9840
WAFM	Australian Fused Materials	1.0083	1.0034
WAKW	Kwinana Alcoa	1.0043	0.9976
WALB	Albany	1.0529	1.1344
WAMT	Amherst	1.0156	1.0114
WAPM	Australian Paper Mills	1.0190	1.0136
WARK	Arkana	1.0129	1.0144
WBCH	Beechboro	1.0133	1.0281
WBCT	Balcatta	1.0136	1.0166
WBDE	Baandee	1.0441	1.0500
WBDP	Binningup Desalination Plant	0.9905	0.9920
WBEC	Beckenham	1.0049	1.0039
WBEL	Belmont	1.0093	1.0072
WBGM	Boddington Gold Mine	0.9945	0.9947
WBHK	Broken Hill Kwinana	1.0063	1.0006

TLF Code	Description	Applied in 2025/26	To apply in 2026/27
WBIB	Bibra Lake	1.0119	1.0064
WBKF	Black Flag	1.1852	1.2096
WBLD	Boulder	1.1712	1.1952
WBNP	Beenup	1.0182	1.0248
WBNY	Bounty	1.0720	1.0738
WBOD	Boddington	0.9912	0.992
WBPM	British Petroleum	1.0060	1.0017
WBSI	Marriott Road Barrack Silicon Smelter	0.9949	0.9965
WBSN	Busselton	1.0284	1.0302
WBTN	Bridgetown	1.0051	1.0105
WBTY	Bentley	1.0119	1.0102
WBUH	Bunbury Harbour	0.9987	1.0021
WBWF	Badgingarra Wind Farm	0.9518	0.9513
WBYF	Byford	1.0113	1.0064
WCAP	Capel	1.0228	1.0262
WCAR	Carrabin	1.0883	1.0947
WCBP	Mason Road CSBP	1.0074	1.0013
WCBS	Collie BESS 1	0.9873	1.0006
WCBT	Neoen Collie Stage 2 BESS	0.9873	0.9901
WCBD	Collie ESR4	0.9873	1.0006
WCBE	Collie ESR5	0.9873	1.0006
WCCL	Cockburn Cement Ltd	1.0069	1.0024
WCCT	Cockburn Cement	1.0072	1.0030
WCGW	Collgar Windfarm	0.9727	0.9853
WCKN	Clarkson	1.0088	1.0205
WCKT	Cook Street	1.0169	1.0158
WCLN	Clarence Street	1.0141	1.0111
WCOE	Collie	1.0035	1.0077
WCOL	Collier	1.0151	1.012
WCPN	Chapman	0.9840	0.9705
WCPS	Collie PWS	0.9732	0.9766
WCSF	Cunderdin Solar Farm	0.8884	0.9058
WCTB	Cataby	0.9884	0.9826

TLF Code	Description	Applied in 2025/26	To apply in 2026/27
WCTE	Cottesloe	1.0168	1.0141
WCUN	Cunderdin	1.0571	1.0442
WCVE	Canning Vale	1.0065	1.0035
WDTN	Darlington	1.0134	1.0131
WEDD	Edmund Street	1.0158	1.0107
WEDG	Edgewater	1.0119	1.0204
WEMD	Emu Downs	0.9621	0.961
WENB	Eneabba	0.9800	0.9723
WERF	East Rockingham RRF	1.0064	1.0012
WFFD	Forrestfield	1.0129	1.0133
WFRW	Flat Rocks Wind Farm	1.0196	1.1523
WGGV	Golden Grove	1.0259	1.0221
WGNI	Glen Iris	1.0018	0.9999
WGNL	Gosnells	1.0080	1.004
WGNN	Newgen Neerabup	1.0039	1.0028
WGTN	Geraldton	0.9801	0.9675
WHAY	Hay Street	1.0169	1.0156
WHBK	Henley Brook	1.0122	1.0147
WHFS	Hadfields	1.0139	1.0244
WHZM	Hazelmere	1.0087	1.0094
WJDP	Joondalup	1.0113	1.0232
WJTE	Joel Terrace	1.0166	1.0154
WKAT	Katanning	1.0472	1.1005
WKBS	Kwinana Battery Energy Storage System	0.9968	1.0004
WKBT	Kwinana BESS 2 (KBESS2)	0.9978	1.0010
WKDA	Kalamunda	1.0146	1.0146
WKDL	Kewdale	1.0083	1.0063
WKDN	Kondinin	1.0249	1.0288
WKDP	Kwinana Desalination Plant	1.0055	0.9999
WKEL	Kellerberrin	1.0486	1.0583
WKEM	Kemerton PWS	0.9843	0.9808
WKMC	Cataby Kerr McGee	0.9879	0.9858
WKMK	Kerr McGee Kwinana	1.0029	0.9981

TLF Code	Description	Applied in 2025/26	To apply in 2026/27
WKMM	Muchea Kerr McGee	1.0052	1.0060
WKND	Kwinana Donaldson Road (Western Energy)	1.0029	0.9968
WKOJ	Kojonup	1.0196	1.0735
WKPS	Kwinana PWS	0.9996	0.9961
WKRK	King Rocks Wind Farm	1.0249	1.0288
WKWW	Kwinana Waste to Energy	1.0029	0.9998
WLDE	Landsdale	1.0130	1.0183
WMAG	Manning Street	1.0155	1.0189
WMBR	Mt Barker	1.0544	1.1243
WMCR	Medical Centre	1.0201	1.0188
WMDN	Maddington	1.0073	1.0042
WMDY	Munday	1.0123	1.0126
WMED	Medina	1.0096	1.0038
WMER	Merredin	1.0390	1.0444
WMGA	Mungarra GTs	0.9636	0.9600
WMHA	Mandurah	1.0038	1.0019
WMIL	Milligan Street	1.0126	1.0162
WMJP	Manjimup	1.0106	1.0162
WMJX	Midland Junction	1.0090	1.0096
WMLG	Malaga	1.0106	1.0114
WMOR	Moora	1.0090	1.0077
WMOY	Morley	1.0148	1.0206
WMPS	Muja PWS	0.9824	0.9854
WMRR	Marriot Road	0.9924	0.9941
WMRV	Margaret River	1.0590	1.0585
WMSF	Merredin Solar Farm	1.0059	1.0078
WMSR	Mason Road	1.0064	1.0011
WMSS	Meadow Springs	1.0035	1.0018
WMUC	Muchea	1.0066	1.0072
WMUL	Mullaloo	1.0134	1.0219
WMUR	Murdoch	1.0080	1.0028
WMYR	Myaree	1.0231	1.0171
WNBH	North Beach	1.0151	1.0195

TLF Code	Description	Applied in 2025/26	To apply in 2026/27
WNGK	NewGen Kwinana	0.9979	0.9981
WNGN	Narrogin	1.0104	1.0142
WNOR	Northam	1.0191	1.0020
WNOW	Nowgerup	1.0077	1.0167
WNPH	North Perth	1.0178	1.0166
WOCN	O'Connor	1.0215	1.0156
WOPK	Osborne Park	1.0140	1.0163
WPBY	Padbury	1.0150	1.0226
WPCY	Piccadilly	1.1672	1.1907
WPIC	Picton	0.9993	1.0029
WPJR	Pinjar	1.0015	1.0035
WPKS	Parkeston	1.1785	1.1949
WPLD	Parklands	0.9997	0.9978
WPNJ	Pinjarra	0.9919	0.9914
WRAN	Rangeway	0.9801	0.9691
WRGN	Regans	0.9967	0.9950
WROH	Rockingham	1.0106	1.0052
WRTN	Riverton	1.0092	1.0043
WRVE	Rivervale	1.0096	1.0075
WSNR	Southern River	1.0076	1.0014
WSNX	Southern Cross	1.0788	1.0952
WSPK	Shenton Park	1.0152	1.0142
WSRD	Sutherland	1.0171	1.0166
WSUM	Summer St	1.0160	1.0150
WSVY	Sawyers Valley	1.0163	1.0137
WTLA	Tianqi Lithium	1.0062	1.0014
WTSG	Three Springs	0.9884	0.9847
WWAG	Wagin	1.0526	1.1091
WWAI	Waikiki	1.0120	1.0076
WWCL	Western Collieries	0.9833	0.9891
WWDN	Wembley Downs	1.0205	1.0190
WWDW	Warradarge Wind Farm	0.9781	0.9787
WWEL	Welshpool	1.0081	1.0061

TLF Code	Description	Applied in 2025/26	To apply in 2026/27
WWGA	Wangara	1.0132	1.0203
WWGP	Wagerup	0.9559	0.9593
WWGU	Wagerup Battery	0.9559	0.9859
WWKT	West Kalgoorlie	1.1692	1.1904
WWLN	Willetton	1.0056	1.0027
WWMG	Western Mining	1.0091	1.0040
WWNO	Wanneroo	1.0079	1.0227
WWSD	Westralian Sands	1.0208	1.0246
WWUN	Wundowie	1.0320	1.0213
WWWF	Walkaway Windfarm	0.9125	0.9182
WYCP	Yanchep	1.0079	1.0160
WYDW	Yandin Wind Farm	0.9850	0.9844
WYER	Yerbillon	1.0814	1.0917
WYKE	Yokine	1.0145	1.0176
WYLN	Yilgarn	1.0797	1.0864

5. Average Distribution Loss Factors

Western Power has calculated the following average distribution loss factors (DLF) for the 2026/27 financial year based on the Market Procedure:

Table 5.1 - Average Distribution Loss Factors

Customer Segment	Applicable Reference Services	DLF Code	Applied in 2025/26	To apply in 2026/27
Residential	A1 - Anytime Energy (Residential)	QRT1	1.0700	1.0760
	A3 - Time of Use Energy (Residential)			
	C1 – Anytime Energy (Residential) Bi-directional			
	C3 – Time of Use Energy (Residential) Bi-directional			
	A12 - 3 Part Time of Use Energy (Residential)			
	A14 - 3 Part Time of Use Demand (Residential)			
	A16 - Multi Use Part Time of Use Energy (Residential)			
	C9 - 3 Part Time of Use Energy (Residential) Bi-Directional			
	C11 - 3 Part Time of Use Demand (Residential) Bi-Directional			
	C13 - Multi Use Part Time of Use Energy (Residential) Bi-Directional			
	A18 – Super Off-peak Energy (Residential) Exit Service			
	C16 – Super Off-peak Energy (Residential) Exit Service			
	A20 – Super Off-peak Demand (Residential) Exit Service			
	C18 – Super Off-peak Demand (Residential) Bi-directional Service			
Small Business	A2 - Anytime Energy (Business)	QRT2	1.0470	1.0470
	A4 - Time of Use Energy (Business)			
	C2 – Anytime Energy (Business) Bi-directional			
	C4 – Time of Use Energy (Business) Bi-directional			
	A13 - 3 Part Time of Use Energy (Business)			
	A15 - 3 Part Time of Use Demand (Business)			
	A17 - Multi Use Part Time of Use Energy (Business)			
	C10 - 3 Part Time of Use Energy (Business) Bi-directional			
	C12 - 3 Part Time of Use Demand (Business) Bi-directional			
	C14 - Multi Use Part Time of Use Energy (Business) Bi-directional			
	A19 – Super Off-peak Energy (Business) Exit Service			

Customer Segment	Applicable Reference Services	DLF Code	Applied in 2025/26	To apply in 2026/27
	C17 – Super Off-peak Energy (Business) Bi-directional Service			
	A21 – Super Off-peak Demand (Business) Exit Service			
	C19 – Super Off-peak Demand (Business) Bi-directional Service			
Medium Business High Voltage	A5 - High Voltage Metered Demand	QRT5	1.0190	1.0180
	C5 - High Voltage Metered Demand Bi-Directional			
	A23 – High Voltage Electric Vehicle Charging Exit Service			
	C21 – High Voltage Electric Vehicle Charging Bi-directional Service			
	C24 – HV Distribution Storage Bidirectional Service			
Medium Business Low Voltage	A6 - Low Voltage Metered Demand	QRT6	1.0400	1.0400
	C6 - Low Voltage Metered Demand Bi-Directional			
	A22 – Low Voltage Electric Vehicle Charging Exit Service			
	C20 – Low Voltage Electric Vehicle Charging Bi-directional Service			
	C23 – LV Distribution Storage Bidirectional Service			
Zone Substation Connected	A7 - High Voltage Contract Maximum Demand (Zone Substation Connected)	QZSC	1.0055	1.0055
	Zone Substation Connections			
Transmission Connected (No DLF)		QNLF	1.0000	1.0000
Notional Wholesale Meter		QNWM	1.0850	1.1030
Distribution System Wide Average Loss Factor		QAVG	1.0550	1.0590

6. Individual Distribution Loss Factors

Western Power has calculated the following individual distribution loss factors for the 2026/27 financial year.

Table 6.1 - Individual Distribution Loss Factors

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QAAL	Air Liquide Australia Limited	1.0112	1.0105
QAAM	Scentre Shopping Centre Mangement WA Pty Ltd	1.0083	1.0072
QAHU	Oahu Management ATF Oahu Property Trust	1.0183	1.0179
QALL	ALBEMARLE LITHIUM PTY LTD	1.0096	1.0076
QALM	ALBEMARLE LITHIUM PTY LTD	1.0123	1.0057
QALP	ALBEMARLE LITHIUM PTY LTD	1.0086	1.0057
QAME	Ames Associates Pty Ltd	0.9733	1.1246
QAMM	Western Australian Meat Marketing Co-operative Limited		1.0185
QAMP	Asia Property AU 2 Pty Ltd	1.0077	1.0055
QANF	Anderson Wind Farm	1.0294	1.0136
QAPE	The Trustee for the Commodity Ag Unit Trust	1.0130	1.0086
QAPI	Australasian Property Investments Ltd t/as Floreat Forum Syndicate UT	1.0137	1.0112
QARG	Paddington Gold Mine	1.0238	1.0303
QATP	Acu-Tech Pty Ltd	1.0310	1.0296
QAWF	ALBANY WIND FARM	0.9733	0.9739
QBAS	BASF AUSTRALIA LTD	1.1828	1.1828
QBBW	BREMER BAY WIND FARM	1.3199	1.3326
QBCB	Centuria Property Services Pty Limited	1.0081	1.0084
QBCC	Brookfield Commercial Operations Pty Ltd		1.0070
QBCO	Brookfield Commercial Operations Pty Ltd	1.0106	1.0125
QBCP	Brookfield Commercial Operations Pty Ltd	1.0083	1.0081
QBFB	Blair Fox Pty Ltd	1.0042	1.0038
QBFO	Brookfield Commercial Operations Pty Ltd	1.0101	1.0102
QBFV	GPT Property Management Pty Limited	1.0161	1.0147
QBGB	BGC (AUSTRALIA) PTY LTD		1.0173
QBGM	BGM MANAGEMENT COMPANY PTY LTD	1.0264	1.0466

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QBGQ	BGC (AUSTRALIA) PTY LTD	1.0697	1.0857
QBKS	DOD - CAMPBELL BKS		1.0205
QBMA	Barto Gold Mining Pty Ltd	1.0723	1.0821
QBNB	BGC (AUSTRALIA) PTY LTD	1.0179	1.0183
QBOC	BOC Limited	1.0065	1.0067
QBPA	SOUTHERN PORTS AUTHORITY	1.0083	1.0080
QBKR	BRADKEN RESOURCES PTY LTD	1.0079	1.0078
QBRR	BRADKEN RESOURCES PTY LTD	1.0102	1.0102
QBTF	The Trustee for PSS/CSS A Property Trust & Investa Nominees (2) Pty Ltd	1.0065	1.0066
QBUL	CO OPERATIVE BULK HANDLING LTD	1.0357	1.0354
QBUR	Burswood Nominees Limited as Trustee for the Burswood Property Trust	1.0082	1.0076
QBUS	Burswood Nominees Limited as Trustee for the Burswood Property Trust	1.0077	1.0065
QBWE	Realside 108 SGT Pty Ltd	1.0098	1.0099
QCAS	Castelli nominees pty ltd	1.0185	1.0217
QCBC	COCKBURN CEMENT LIMITED	1.1169	1.0930
QCBH	CO OPERATIVE BULK HANDLING LTD	1.0723	1.0716
QCCE	Coca-Cola Europacific Partners Australia Pty Ltd		1.0095
QCEB	IKEA Pty Ltd		1.0088
QCEM	COCKBURN CEMENT LIMITED	1.0079	1.0080
QCEN	Scentre Shopping Centre Management (WA) Pty Ltd as agent for & on behalf of entities in Sched 1		1.0118
QCHA	Charter Hall Holdings Pty. Limited		1.0082
QCHB	Charter Hall Holdings Pty. Limited		1.0062
QCHC	Charter Hall Holdings Pty. Limited		1.0092
QCHH	CHARTER HALL HOLDINGS PTY. LIMITED	1.0105	1.0106
QCHS	WA Country Health Service	1.0293	1.0249
QCMA	Tronox Mining Australia Limited	1.0609	1.0678
QCPY	CSIRO - Pawsey Centre	1.0129	1.0118
QCSI	CSIRO - Pawsey Centre		1.0066
QCSK	CSIRO KENSINGTON	1.0180	1.0239
QCSW	Tronox Mining Australia Limited	1.0108	1.0113

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QCTE	A RICHARDS PTY LTD	1.0203	1.0203
QCUR	Curtin University B156 - Zone 3	1.0060	1.0060
QCUT	Mushroom Exchange Pty Ltd	1.0091	1.0076
QCVL	Covalent Lithium	1.0123	1.0142
QDAG	DOD - ADSCS GERALDTON	1.0528	1.0520
QDCS	DEPARTMENT OF JUSTICE	1.0089	1.0089
QDER	Luca Castelli pty ltd	1.0199	1.0213
QDFM	Dexus Property Services Pty Ltd	1.0083	1.0081
QDMC	David Moss Corporation Pty Ltd	1.0195	1.0165
QDMP	Derby Meat Processing Co Pty Ltd	1.0335	1.0271
QDOD	DOD - HMAS STIRLING 1	1.0099	1.0133
QDOJ	DEPARTMENT OF JUSTICE	1.0108	1.0098
QDPI	Department of Primary Industries and Regional Development	1.0261	1.0114
QDVC	David Jones	1.0064	1.0090
QDWF	DENMARK COMMUNITY WINDFARM LTD	1.1802	1.2201
QEAP	Equinix Australia Pty Limited	1.0098	1.0089
QEMM	Evolution Mining (Mungari) Pty Ltd	1.0592	1.0465
QEMO	Edna May Operations Pty Ltd	1.0757	1.0696
QEMP	Erceg Management Pty Ltd	1.0078	1.0079
QEMQ	Erceg Management Pty Ltd	1.0113	1.0089
QEPF	Enviro Pipes Pty Ltd	1.0125	1.0090
QEPH	Enviro Pipes Pty Ltd	1.0056	1.0094
QESC	Vicinity Centres PM Pty Ltd	1.0096	1.0098
QEVM	Evolution Mining (Mungari) Pty Ltd	1.0376	1.0461
QEVO	Evolution Mining (Mungari) Pty Ltd		1.0699
QFIE	The Trustee for FLETCHER UNIT TRUST	1.0761	1.0827
QFMR	FMR INVESTMENTS PTY LTD	1.0289	1.0849
QFRO	Fero Group Pty Ltd	1.0132	1.0137
QFUJ	Fujitsu Australia Limited	1.0056	1.0076
QFUR	FURMANITE AUSTRALIA PTY LTD	1.0203	1.0324

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QGDI	PREPETUAL CORPORATE TRUST LIMITED ATF TTF GDI NO.44 Trust GDI NO 44 Pty Ltd ATF TTF GDI NO 44 Trust	1.0082	1.0087
QGES	Perron Investments Pty Ltd & APF Management Pty Ltd (Central Park)	1.0093	1.0096
QGGP	GMA Garnet Pty Ltd	1.2029	1.2018
QGLG	DEPARTMENT OF CULTURE & THE ARTS	1.0158	1.0067
QGMC	Derby Meat Processing Co Pty Ltd	1.0055	1.0055
QGPP	Giuliana Properties Pty Ltd		1.0330
QGRI	The Griffin Coal Mining Company Pty Ltd	1.0352	1.0330
QGTS	REALSIDE MADDINGTON SC PTY LTD	1.0116	1.0115
QGWH	George Weston Foods Limited - Hope Valley	1.0161	1.0118
QGWL	George Weston Foods Limited - Canning Vale		1.0070
QGWN	George Weston Foods Limited - Northam	1.0128	1.0128
QHAP	Hanson Australia Pty Ltd	1.0150	1.0156
QHEL	Healthscope Operations Pty Ltd	1.0194	1.0194
QHFM	Lactalis Australia Pty Ltd	1.0424	1.0431
QHGM	Barto Gold Minning Private Limited	1.0288	1.0166
QHHC	Centuria Property Funds No. 3 Limited	1.0109	1.0111
QHLG	Waste Gas Resources Pty Ltd	1.0069	1.0065
QHMP	FMR INVESTMENTS PTY LTD	1.0904	1.0735
QHPH	Ramsay Health Care Australia Pty Limited	1.0080	1.0078
QHPL	Hanson Australia Pty Ltd	1.0181	1.0158
QGRA	Grand Hotel Management Pty Ltd	1.0108	1.0102
QHVI	HARVEY INDUSTRIES GROUP PTY LTD	1.0851	1.0847
QIAP	IWATANI AUSTRALIA PTY LTD	1.0537	1.0540
QIGP	Insta-Gator Pty Ltd		1.0071
QIRL	ILUKA RESOURCES LTD	1.0266	1.0293
QIRN	Image Resources NL	1.0309	1.0487
QISH	ISPT Pty Ltd	1.0104	1.0106
QISM	ISPT Pty Ltd	1.0074	1.0070
QISP	ISPT Pty Ltd	1.0073	1.0087
QISU	ISPT Pty Ltd	1.0138	1.0134

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QJHP	Ramsay Health Care Australia Pty Limited	1.0101	1.0074
QJOE	BOORTMALT ASIA PACIFIC PTY LTD	1.0099	1.0092
QKBG	NORTHERN STAR (KANOWNA) LIMITED	1.1100	1.1341
QKEM	Kemerton Silica Sand Pty Ltd	1.0135	1.0127
QKEY	IWATANI AUSTRALIA PTY LTD	1.0108	1.0130
QKUD	Evolution Mining (Mungari) Pty Ltd	1.0471	1.0532
QKWF	VERVE ENERGY	1.1306	1.3574
QLEH	The Trustee for Legion Energy Trust	1.0056	1.0056
QLES	Vicinity Centres PM Pty Ltd	1.0087	1.0091
QLET	The Trustee for Legion Energy Trust	1.0099	1.0260
QLGA	LANDFILL GAS & POWER PTY LTD	1.0434	1.0361
QLGD	LANDFILL GAS & POWER PTY LTD	1.0317	1.0279
QLGE	The Trustee for Legion Energy Trust	1.0070	1.0071
QLHT	Westgreen Properties Pty Ltd	1.0092	1.0091
QLJS	Vicinity Centres PM Pty Ltd	1.007	1.0066
QLMR	Evolution Mining (Mungari) Pty Ltd	1.0155	1.1068
QLPM	Giuliana Properties Pty Ltd		1.0232
QLSP	Centuria Property Services Pty Limited	1.0236	1.0186
QMBW	Mt Barker Power Company	1.0572	1.0572
QMGS	Fawkner Property Ltd ATF TTF Fawkner Midland Trust No. 25		1.0064
QMFA	Macco Feeds Australia Macco Feeds	1.0644	1.0497
QMIC	Tronox Pigment Bunbury Ltd	1.0061	1.0055
QMID	BGC (AUSTRALIA) PTY LTD		1.0149
QMIE	BGC (AUSTRALIA) PTY LTD		1.0163
QMIL	MILNE AGRIGROUP PTY LTD	1.0100	1.0102
QMIR	Centuria Property Services Pty Limited	1.0062	1.0062
QMMP	Aus Pie Co Pty Ltd		1.0205
QMPM	Metro Power Company Pty Ltd	1.0112	1.0121
QMRL	Mineral Resources (Equipment) Pty Ltd	1.1366	1.1181
QMRS	Murdoch Retirement Services Pty Ltd	1.0073	1.0071

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QMRY	Murdoch University	1.0078	1.0086
QNDC	NEXTDC Limited	1.0155	1.0087
QNEW	NEWMONT POWER PTY LTD	1.0466	1.0418
QNFM	BDD Australia Pty Ltd		1.0104
QNGF	Norton Gold Fields Pty Ltd	1.0269	1.0472
QNXD	NextDC Limited	1.0074	1.0073
QOFI	Optus Fixed Infrastructure Pty Ltd	1.0099	1.0093
QPAG	Norton Gold Fields Pty Ltd	1.0688	1.0778
QPAN	The Trustee for Success Venture WA Unit Trust	1.0081	1.0082
QPEA	LMS Energy Pty Ltd	1.0039	1.0081
QPEB	LMS Energy Pty Ltd	1.0070	1.0142
QPER	Perpetual Trustee Company Ltd ATF Esplanade Property Trust	1.0105	1.0111
QPFP	Patmore Feeds Pty Ltd	1.1182	1.1138
QPHC	South Metropolitan Health Service	1.0069	1.0150
QPIL	GPT Property Management Pty Limited	1.0151	1.0281
QPPP	Bridgewest Perth Pharma Pty Ltd		1.0225
QPTA	Public Transport Authority of Western Australia	1.0125	1.0090
QPTB	Public Transport Authority of Western Australia	1.0057	1.0059
QPTD	Public Transport Authority of Western Australia	1.0147	1.0104
QPTE	Public Transport Authority of Western Australia	1.0057	1.0057
QPTF	Public Transport Authority of Western Australia		1.0115
QPWQ	PWQ Pty Ltd ATF Quadrant Sub Trust	1.0083	1.0085
QQOA	Quaker Oats Australia Pty Ltd	1.0064	1.0060
QXDC	NEXTDC Limited		1.0065
QRCS	Vicinity Centres PM Pty Ltd	1.0078	1.0070
QRRA	DOD - RAAF PEARCE	1.0745	1.0668
QDAN	Dandaragan Energy Ptd Ltd		1.0879
QSAD	Scentre Shopping Centre Management (WA) Pty Ltd as agent for & on behalf of entities in Sched 1	1.0143	1.0133
QSER	SERCO AUSTRALIA PTY LIMITED	1.0641	1.0688
QSIT	MINDARIE REGIONAL COUNCIL	1.0164	1.0124

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QSPO	Downer EDI Services Pty Ltd	1.0071	1.0080
QSPP	BOOKITJA PTY LTD & IBA NORTHAM SOLAR PTY LTD & NORTHAM SOLAR FARM A PTY LTD	0.9815	0.9794
QSPS	The Trustee for Energy Bay Oscar Fund	1.0079	1.0076
QSPT	Ensign Services (Aust.) Pty. Ltd.		1.0085
QSPW	The Trustee for Energy Bay Oscar Fund	1.012	1.0117
QTAL	Talison Lithium Australia Pty Ltd	1.0152	1.0056
QTCG	TESLA GERALDTON PTY LTD	1.0102	1.0070
QTCK	TESLA KEMERTON PTY LTD	1.0059	1.0059
QTCM	Telstra Limited		1.0072
QTCN	TESLA NORTHAM PTY LTD	0.8968	0.8951
QTES	Tesla Corporation Management Pty Ltd	1.0084	1.0069
QTIF	The Trustee for Legion Energy Trust	1.0112	1.0111
QTLA	Talison Lithium Australia Pty Ltd	1.1598	1.0799
QTMA	Tronox Pigment Bunbury Ltd	1.0063	1.0059
QTMH	FOCUS OPERATIONS PTY LTD	1.1210	1.0969
QTSS	Thornlie Square Shopping Centre Pty Ltd Thornlie Square Shopping Centre	1.0096	1.0092
QVVM	The Trustee for V&V UNIT TRUST & VERNON WALSH PTY LTD	1.0109	1.0107
QWAC	Perth Airport Pty Ltd	1.0096	1.0119
QWAN	IGO FORRESTANIA LIMITED	1.0852	1.0065
QWAS	Western Australian Sports Centre Trust	1.0082	1.0086
QWBE	Wesbeam Pty Ltd	1.0176	1.0171
QWCD	WATER CORPORATION		1.0376
QWCE	WATER CORPORATION	1.0103	1.0062
QWCF	WATER CORPORATION		1.0200
QWCG	WATER CORPORATION	1.0226	1.0128
QWCH	WATER CORPORATION		1.0189
QWCI	WATER CORPORATION		1.0085
QWCL	WATER CORPORATION	1.0110	1.0109
QWCO	WATER CORPORATION	1.0441	1.0390
QWCT	WATER CORPORATION		1.0134

DLF Code	Description	Applied in 2025/26	To apply in 2026/27
QWCW	WATER CORPORATION	1.0347	1.0274
QWCX	WATER CORPORATION	1.0099	1.0094
QWCY	WATER CORPORATION		1.0104
QWCZ	WATER CORPORATION	1.0094	1.0094
QWFL	Wesfarmers Pty Ltd	1.0055	1.0055
QWHF	West Hills Farm P/L	1.1012	1.1228
QWLD	Main Camp WA Pty Ltd	1.3576	1.1954
QWMD	Fletcher Building (Australia) Pty Ltd	1.0470	1.0442
QWMI	Gold Corporation - Coin Manufacturing Division		1.0184
QWPP	Moora Energy Pty Ltd	1.0863	1.0759
QWSI	Dianella Plaza Asset Co Pt Ltd	1.0251	1.0251
QYTE	YT INTERNATIONAL PTY LTD (Forrest Centre).	1.0136	1.0142

7. Explanation for Changes in Loss Factors

In accordance with clause 2.21(b)ii of the Market Procedure Western Power is required to provide an explanation for any changes of more than 0.025 in any transmission or distribution loss factors when compared to the previous year.

In general, loss factors increase with demand at a node and decrease with increasing generation at a node. Loss factors can also be affected by changes in network configuration.

7.1 Transmission loss factors

Table 7.1 is a list of the transmission loss factors that moved by more than 0.025 in 2026/27. Loss factors for the transmission network are calculated based on half hour data for the whole system over the whole year. Individual transmission loss factors are not only affected by the quantity of usage at a node but also the time the usage occurs and being a meshed network, they are also affected by usage at other nearby nodes. Given these changes, Western Power has not been able to determine more specific reasons for each of the identified loss factor movements.

Table 7.1 - Transmission Loss Factors changed by more than 0.025

TLF Code	Description	Applied in 2025/26	To apply from 1 July 2026	Change
TBLS	Boulder (SCE)	1.1601	1.1859	0.0258
TMDP	Merredin Power Station (Nammarkin)	1.0403	1.1397	0.0994
TWKG	West Kalgoorlie GTs	1.1006	1.1717	0.0711
WALB	Albany	1.0529	1.1344	0.0815
WFRW	Flat Rocks Wind Farm	1.0196	1.1523	0.1327
WKAT	Katanning	1.0472	1.1005	0.0533
WKOJ	Kojonup	1.0196	1.0735	0.0539
WMBR	Mt Barker	1.0544	1.1243	0.0699
WWAG	Wagin	1.0526	1.1091	0.0565
WWGU	Wagerup Battery	0.9559	0.9859	0.0300

7.2 Individual distribution loss factors

Table 7.2 is a list of the distribution loss factors that moved by more than 0.025 in 2026/27.

Table 7.2: Distribution Loss Factor changed by more than 0.025

DLF	Customer	DLF variance	Explanation
QWAN	IGO FORRESTANIA LIMITED	-0.0787	NMI Consumption Change: The decrease in the customer's energy consumption has led to a corresponding reduction in the calculated DLF.

DLF	Customer	DLF variance	Explanation
QTLA	Talison Lithium Australia Pty Ltd	-0.0799	NMI Consumption Change: The NMI consumption has reduced substantially this year, which has contributed to the lower DLF result.
QLMR	Evolution Mining (Mungari) Pty Ltd	0.0913	NMI Consumption Change: The DLF customer's energy consumption has increased, resulting in a higher DLF value.
QKWF	VERVE ENERGY	0.2269	Generator Export Change: The customer's generator export has increased compared to the previous year, resulting in a higher DLF value.
QWLD	Main Camp WA Pty Ltd	-0.1622	Network Condition Change: The change in network power flow has resulted in a lower DLF.
QDWF	DENMARK COMMUNITY WINDFARM LTD	0.0399	Network Condition Change: The change in network power flow has resulted in a higher DLF.
QAME	Ames Associates Pty Ltd	0.1513	This year's DLF is higher than last year's due to differences in the input assumptions and network conditions. Previously, no actual generator export data was available, and the calculation was based on the nominated DSOC of 1500 kVA. In addition, the network power flow is higher compared to the previous year. These factors have collectively contributed to an increase in the calculated DLF value.
QFMR	FMR INVESTMENTS PTY LTD	0.0560	NMI Consumption Change: The DLF customer's energy consumption has increased, resulting in a higher DLF value.

Appendix A

Individual Transmission Loss Factors by NMI

A.1 Individual Transmission Loss Factors by NMI

The following NMIs are for customers connected directly to the transmission system along with the transmission loss factor code Western Power has assigned.

Table A.1: Transmission Loss Factors by NMI

NMI	TLF
8001000659	WKMC
8001000776	WWSD
8001001007	WWGP
8001018020	WKEM
8001000126	WWMG
8001018021	WKEM
8002016734	TLWA
8001019590	TOLA
8001000741	TBLS
8001000279	WPKS
8001000616	WKMM
8001000127	WWMG
8001000128	WWMG
8001000109	WMSR
8002016403	WCGW
8002016404	WCGW
8001019478	TWOW

NMI	TLF
8002016506	TMGS
8001000743	TWOW
8001000640	WWCL
8001000646	WGGV
8001000744	TWOJ
8001019484	WEMD
8002016666	WMSF
8001000736	WCBP
8002016124	WKND
8001001212	WWWF
8001001211	WWWF
8001000733	WAKW
8001000129	WCCL
8002016417	WBSI
8002016696	WKBT
8002014313	WPKS
8002016491	TKRA
8002013796	TBLB
8001000764	WSUM
8002016652	WBWF

NMI	TLF
8002016519	TMBA
8002016416	WBSI
8002016407	TWOW
8002016510	TMDP
8002016687	WKWW
8002013337	TBLB
8002112635	WBDP
8002016668	WWDW
8002016706	WFRW
8002013368	WPJR
8001000954	TAPA
8002013375	WBGM
8002013372	WMGA
8002016665	WYDW
8001019485	WEMD
8002016672	WWMG
8001016070	WBEC
8001018932	TAPL
8001019791	WGNI
8001019487	WKDP

NMI	TLF
8001019790	WPLD
8001000291	WAFM
8002016720	WCSF
8002013364	WMPS
8001000732	TAPA
8002013365	WKPS
8001000499	WBPM
8002016724	WCBS
8001019785	TLWA
8002013371	TWKG
8002013379	WKMK
8002016571	WNOW
8002016585	WSRD
8002016671	WWMG
8002016699	WTAL
8002016719	WNOW
8002016415	WBSI
8002013366	WCPS
8002013369	WKPS
8001000116	WBHK

NMI	TLF
8001000500	WBPM
8001000118	WKMK
8002016691	WERF
8001000347	WEDG
8001000641	WWCL
8002016697	WKBS
8002016504	WKPS
8002013343	WNGK
8002015326	WGNN
8002016505	WKPS
8002016730	WCBT
8002016731	WCBD
8002016732	WCBE
8002016735	WWGU

Appendix B

Individual Distribution Loss Factors by NMI

B.1 Individual Distribution loss factors by NMI

The individual distribution loss factors calculated for the 2026/27 financial year are associated with the following NMIs.

Table B.1: Individual Distribution Loss Factors by NMI

NMI	DLF Code	Required or Optional[2]
8001000101	QVML	Optional
8001000107	QCSW	Optional
8001000121	QTAL	Required
8001000122	QPEB	Required
8001000125	QKEM	Required
8001000130	QCEM	Required
8001000158	QLGA	Required
8001000234	QLGD	Required
8001000267	QGWN	Optional
8001000269	QKUD	Required
8001000270	QMID	Required
8001000272	QOFI	Optional
8001000273	QAMM	Optional
8001000281	QWCH	Optional
8001000282	QWCE	Optional
8001000284	QWCW	Required
8001000286	QAAL	Optional
8001000300	QNFM	Optional
8001000325	QWMD	Required
8001000329	QBPA	Optional
8001000333	QDOD	Optional
8001000345	QHVI	Required
8001000356	QTMH	Required
8001000357	QWCO	Required

[2] Individual distribution loss factors have been assessed as either required or optional in accordance with section 3.2.5 of the Market Procedure. The calculation of optional distribution loss factors is at the cost of the retailer

NMI	DLF Code	Required or Optional[2]
8001000359	QHGM	Required
8001000373	QHAP	Required
8001000379	QDAG	Required
8001000414	QBKR	Optional
8001000416	QPPP	Optional
8001000419	QBRR	Optional
8001000425	QDOT	Optional
8001000428	QCBC	Required
8001000431	QEMP	Optional
8001000433	QGGP	Required
8001000438	QMMP	Optional
8001000442	QPHC	Required
8001000451	QHMP	Required
8001000453	QAPE	Required
8001000458	QPGO	Optional
8001000463	QCUT	Optional
8001000493	QARG	Required
8001000515	QMIE	Optional
8001000516	QMRY	Optional
8001000517	QMRY	Optional
8001000527	QWCT	Optional
8001000528	QWCT	Optional
8001000529	QWCF	Optional
8001000530	QWCF	Optional
8001000533	QWAC	Optional
8001000534	QWAC	Optional
8001000539	QFIE	Required
8001000541	QBWE	Required
8001000542	QBWE	Required
8001000546	QGES	Optional
8001000547	QGES	Optional
8001000548	QAMP	Optional

NMI	DLF Code	Required or Optional[2]
8001000549	QAMP	Optional
8001000559	QPWQ	Optional
8001000560	QPWQ	Optional
8001000561	QDVC	Optional
8001000562	QDVC	Optional
8001000565	QMIR	Optional
8001000566	QMIR	Optional
8001000569	QCHA	Optional
8001000573	QPER	Optional
8001000574	QPER	Optional
8001000575	QYTE	Optional
8001000576	QYTE	Optional
8001000577	QGDI	Optional
8001000578	QGDI	Optional
8001000589	QDFM	Optional
8001000590	QDFM	Optional
8001000591	QSPO	Optional
8001000592	QSPO	Optional
8001000593	QBFV	Optional
8001000594	QBFV	Optional
8001000626	QDMP	Optional
8001000627	QDMP	Optional
8001000638	QCCE	Optional
8001000639	QCCE	Optional
8001000642	QTCL	Optional
8001000650	QWBE	Required
8001000651	QWBE	Required
8001000652	QBUR	Optional
8001000653	QBUR	Optional
8001000661	QIRG	Optional
8001000662	QIRG	Optional
8001000667	QLJS	Optional

NMI	DLF Code	Required or Optional[2]
8001000668	QLJS	Optional
8001000669	QKUD	Required
8001000670	QKUD	Required
8001000673	QAAM	Required
8001000674	QAAM	Required
8001000679	QBCB	Optional
8001000680	QBCB	Optional
8001000681	QMGS	Optional
8001000682	QMGS	Optional
8001000687	QRCS	Optional
8001000688	QRCS	Optional
8001000689	QPAN	Optional
8001000690	QPAN	Optional
8001000691	QWHS	Optional
8001000692	QWHS	Optional
8001000693	QWCS	Optional
8001000694	QWCS	Optional
8001000695	QSAD	Optional
8001000696	QSAD	Optional
8001000703	QBTF	Optional
8001000704	QBTF	Optional
8001000705	QTMA	Required
8001000706	QMIC	Required
8001000707	QAWF	Required
8001000708	QAWF	Required
8001000713	QAPI	Optional
8001000714	QAPI	Optional
8001000745	QPAG	Required
8001000756	QGTS	Optional
8001000766	QGMC	Optional
8001000780	QCBH	Required
8001000781	QLNL	Optional

NMI	DLF Code	Required or Optional[2]
8001000790	QWCG	Required
8001000792	QJOE	Optional
8001000819	QBKS	Optional
8001000824	QKBG	Required
8001000829	QWFL	Optional
8001000831	QTCL	Optional
8001000839	QTCM	Optional
8001000863	QRRA	Required
8001000878	QWAN	Required
8001000916	QPEA	Required
8001000927	QCSK	Optional
8001000998	QNEW	Required
8001001009	QBMA	Required
8001001110	QTIF	Optional
8001002178	QLGE	Optional
8001002551	QLHT	Optional
8001002905	QAHU	Optional
8001003155	QCEN	Optional
8001003397	QGLG	Optional
8001003492	QTSS	Optional
8001003787	QBNB	Required
8001006735	QING	Optional
8001006864	QSER	Required
8001007060	QHPL	Required
8001007896	QMFA	Required
8001008047	QWCI	Optional
8001008631	QDCS	Required
8001008755	QISU	Optional
8001008927	QGPP	Optional
8001009350	QDMP	Optional
8001009434	QIGP	Optional
8001009577	QBUL	Required

NMI	DLF Code	Required or Optional[2]
8001010090	QPTA	Optional
8001010318	QESC	Optional
8001010350	QQOA	Optional
8001010802	QWMI	Optional
8001011208	QLSP	Optional
8001011500	QJHP	Optional
8001012464	QCTE	Required
8001013013	QBAS	Required
8001013546	QDPI	Optional
8001014079	QSPM	Optional
8001014469	QHEL	Optional
8001014755	QMIL	Optional
8001015132	QDOJ	Optional
8001016146	QDMC	Required
8001016147	QDMC	Required
8001017136	QEMQ	Optional
8001017152	QWSI	Optional
8001017256	QGRA	Optional
8001017284	QGRI	Required
8001017293	QPIL	Optional
8001017512	QSPT	Optional
8001019433	QHLG	Required
8001020053	QWCD	Optional
8001020078	QPIL	Optional
8001020092	QBGM	Required
8001020102	QLPM	Optional
8001259738	QMRS	Required
8001790061	QCAS	Required
8001993169	QSPW	Optional
8002002527	QCEB	Optional
8002008582	QLES	Optional
8002013336	QKWF	Required

NMI	DLF Code	Required or Optional[2]
8002013376	QCUR	Required
8002013377	QCUR	Required
8002013378	QCUR	Required
8002013389	QHPH	Optional
8002013390	QHPH	Optional
8002016399	QJHP	Optional
8002016406	QWCZ	Required
8002016408	QMBW	Required
8002016420	QTES	Required
8002016475	QZSC	Required
8002016499	QWHF	Required
8002016507	QTCG	Required
8002016508	QTCK	Required
8002016509	QTCN	Required
8002016529	QDWF	Required
8002016562	QZSC	Required
8002016563	QZSC	Required
8002016580	QHFM	Required
8002016638	QDOD	Optional
8002016649	QSPP	Required
8002016650	QMPM	Required
8002016682	QBBW	Required
8002019353	QBGB	Optional
8002027039	QISP	Optional
8002027040	QISP	Optional
8002049183	QDER	Required
8002049586	QSPB	Optional
8002050443	QBFO	Optional
8002050616	QATP	Optional
8002051925	QCUR	Required
8002055189	QSIT	Required
8002067264	QBGQ	Required

NMI	DLF Code	Required or Optional[2]
8002067276	QCHC	Optional
8002081338	QFUJ	Optional
8002085840	QCHB	Optional
8002085923	QEMO	Required
8002095398	QBFO	Optional
8002106501	QWCX	Required
8002118572	QEPF	Optional
8002119358	QVVM	Optional
8002131831	QEMM	Required
8002145821	QFMR	Required
8002148204	QANF	Required
8002150804	QCHS	Required
8002155359	QCSI	Optional
8002156419	QCPY	Optional
8002162137	QWCS	Optional
8002163613	QLEH	Optional
8002166160	QCMA	Required
8002182945	QEAP	Optional
8002183852	QLES	Optional
8002187958	QNXD	Optional
8002191360	QLMR	Required
8002206185	QBOC	Required
8002209093	QWAS	Optional
8002214278	QZSC	Required
8002214282	QZSC	Required
8002214285	QZSC	Required
8002214287	QZSC	Required
8002214288	QZSC	Required
8002214290	QZSC	Required
8002220353	QWCY	Required
8002221497	QFUR	Required
8002224052	QBCP	Optional

NMI	DLF Code	Required or Optional[2]
8002227231	QAAL	Required
8002227767	QAAL	Required
8002247735	QKEY	Required
8002250697	QBUS	Optional
8002250698	QBUS	Optional
8002256750	QHHC	Optional
8002256973	QWCL	Optional
8002263036	QSPS	Optional
8002269579	QBFB	Required
8002276877	QISM	Optional
8002279965	QCHH	Required
8002280539	QZSC	Required
8002280541	QZSC	Required
8002280543	QZSC	Required
8002286669	QFRO	Optional
8002288743	QEPH	Optional
8002292810	QWAS	Optional
8002293689	QPTB	Optional
8002293690	QPTD	Optional
8002299295	QEVM	Required
8002314915	QAMM	Optional
8002315825	QMGS	Optional
8002316600	QIRN	Required
8002317197	QISH	Optional
8002319360	QIRL	Required
8002320406	QDOD	Optional
8002339364	QNDC	Optional
8002344801	QLET	Optional
8002350127	QALL	Required
8002350828	QALM	Required
8002350829	QALP	Required
8002351702	QPTE	Optional

NMI	DLF Code	Required or Optional[2]
8002355219	QNGF	Required
8002355633	QVVM	Optional
8002359093	QBBW	Required
8002361962	QWLD	Required
8002369988	QIAP	Required
8002376165	QBCO	Optional
8002383091	QPFP	Required
8002384923	QGWH	Optional
8002386295	QGWH	Optional
8002393603	QCVL	Required
8002394917	QAME	Required
8002399936	QAAH	Optional
8002401339	QWPP	Required
8002404195	QMRL	Required
8002405801	QTMA	Required
8002406669	QTLA	Required
8002423880	QGWL	Optional
8002425368	QXDC	Required
8002428181	QEVO	Required
8002432897	QBCC	Optional
8002436086	QPTF	Required
8002444368	QDAN	Required

Appendix C

Extinct Loss Factor Codes

C.1 Extinct Loss Factor Codes

The following loss factor codes have not been recalculated for the 2026/27 financial year.

Table C.1: Individual Transmission Loss Factors

TLF code	Reason for not being calculated
N/A	N/A

Table C.2: Individual Distribution Loss Factors

DLF code	Reason for not being calculated
QVIC	Not requested by retailer
QWGS	Not requested by retailer
QSMP	Not requested by retailer
QSAP	Not requested by retailer
QRPH	Not requested by retailer
QDOF	Not requested by retailer
QSMH	Not requested by retailer
QILR	Not requested by retailer
QSJO	Not requested by retailer
QSJG	Not requested by retailer
QVML	Not requested by retailer
QBBM	Not requested by retailer
QSIM	Not requested by retailer
QCBK	Not requested by retailer
QBGP	Not requested by retailer
QWCQ	Not requested by retailer
QWDE	Not requested by retailer
QWCJ	Not requested by retailer
QWCM	Not requested by retailer
QWDB	Not requested by retailer

DLF code	Reason for not being calculated
QWCK	Not requested by retailer
QWCB	Not requested by retailer
QMHS	Not requested by retailer
QNHP	Not requested by retailer
QASA	Not requested by retailer
QWCP	Not requested by retailer
QCPU	Not requested by retailer
QSGJ	Not requested by retailer
QSJM	Not requested by retailer
QWCS	Average value applied
QIRG	Average value applied
QPGO	Average value applied
QWHS	Average value applied
QSPM	Average value applied
QTCL	Average value applied
QDOT	Average value applied
QSPB	Average value applied
QLNL	Average value applied
QING	Average value applied
QAAH	Average value applied
QACT	Not eligible for consideration
QBFM	Not eligible for consideration
QDOF	Not eligible for consideration
QFFM	Not eligible for consideration
QFLM	Not eligible for consideration
QGWF	Not eligible for consideration
QPNK	Not eligible for consideration
QOBA	Not eligible for consideration
QSMR	Not eligible for consideration
QVCO	Not eligible for consideration
QVID	Not eligible for consideration
QWDF	Not eligible for consideration

DLF code	Reason for not being calculated
QWDG	Not eligible for consideration
QWDH	Not eligible for consideration