

MEDIUM TERM PASA PROCESS DESCRIPTION

PREPARED BY: Forecasting & Planning

DOCUMENT REF: 42

VERSION: 4.1

EFFECTIVE DATE: 1 November 2017

DRAFT – PROVIDED AS AN INDICATIVE GUIDE TO EXPECTED CHANGES AS A RESULT OF THE MT PASA REDEVELOPMENT. FUTHER CHANGES MAY BE MADE FOLLOWING COMPLETION OF THE RSIG CONSULTATION AND THE DEVELOPMENT AND INSTALLATION OF THE NEW MODELLING PLATFORM.

Disclaimer

Purpose

This report has been prepared by the Australian Energy Market Operator Limited (**AEMO**) for the sole purpose of meeting obligations in accordance with clause 3.7.2(g) of the National Electricity Rules.

No reliance or warranty

This report contains data provided by third parties and might contain conclusions or forecasts and the like that rely on that data. This data might not be free from errors or omissions. While AEMO has used due care and skill, AEMO does not warrant or represent that the data, conclusions, forecasts or other information in this report are accurate, reliable, complete or current or that they are suitable for particular purposes. You should verify and check the accuracy, completeness, reliability and suitability of this report for any use to which you intend to put it, and seek independent expert advice before using it, or any information contained in it.

Limitation of liability

To the extent permitted by law, AEMO and its advisers, consultants and other contributors to this report (or their respective associated companies, businesses, partners, directors, officers or employees) shall not be liable for any errors, omissions, defects or misrepresentations in the information contained in this report, or for any loss or damage suffered by persons who use or rely on such information (including by reason of negligence, negligent misstatement or otherwise). If any law prohibits the exclusion of such liability, AEMO's liability is limited, at AEMO's option, to the re-supply of the information, provided that this limitation is permitted by law and is fair and reasonable.

© 2017 Australian Energy Market Operator Ltd. All rights reserved

Glossary

ABBREVIATION	ABBREVIATION EXPLANATION
AEMO	Australian Energy Market Operator
ASEFS	Australian Solar Energy Forecasting System
AWEFS	Australian Wind Energy Forecasting System
ESOO	Electricity Statement of Opportunities
LP	Linear Program
LRC	Low Reserve Condition
MMS	Electricity Market Management System
MNSP	Market Network Service Provider (Scheduled Network Service Provider in the National Electricity Rules)
MRL	Minimum Reserve Level
Native demand	The electricity demand met by scheduled, semi-scheduled, non-scheduled and exempt generation.
NEM	National Electricity Market
NEFR	National Electricity Forecasting Report

Rules	National Electricity Rules (the Rules)
PASA	Projected Assessment of System Adequacy <ul style="list-style-type: none">• ST PASA: Short term projected assessment of system adequacy• MT PASA: Medium term projected assessment of system adequacy
POE	Probability of Exceedance
RHS	Right Hand Side of a constraint equation
Timetable	Spot Market Operations Timetable
UIGF	Unconstrained Intermittent Generation Forecast

DRAFT

Contents

1	Introduction	6
2	MT PASA process and Rules requirements	6
3	MT PASA Inputs.....	7
3.1	Market participant inputs	7
3.1.1	Generating unit availabilities for MT PASA	8
3.1.2	Network outages and Interconnector availabilities.....	8
3.1.3	Auxiliary load	8
3.2	AEMO inputs	9
3.2.1	Plant availabilities for MT PASA.....	9
3.2.2	Demand forecasts	10
3.2.3	Power transfer capabilities used in MT PASA	11
4	MT PASA Solution Process	11
4.1	NEM Representation	11
4.2	Overview of Modelling Approach	12
4.3	MT PASA Reliability Run.....	13
4.4	MT PASA Loss of Load Probability (LOLP) assessment	14
4.5	Comparison of Model Features	14
5	MT PASA Outputs.....	18
	Appendix A: MT PASA Process Architecture.....	20
	Appendix B: Medium Term Demand Forecasting Process	21
	Appendix C: Pain Sharing.....	23
	Appendix D: Indicative Graphical Outputs	24

Version Release History

VERSION	DATE	BY	CHANGES
1.0	27/04/2006	SOPP	Initial version
2.0	22/03/2013	Systems Capability	Review document to reflect current processes
3.0	30/05/2013	Systems Capability	Updated Sections 4, 5 and Appendix E to include new run type RELIABILITY_MSR_MUR, reporting of MaxUsefulResponse (MUR) and four new run types associated with interconnector capability reporting.
4.0	25/11/2016	Forecasting & Planning	Review document to reflect current processes
4.1	08/06/2017	Supply Planning	Amended document to reflect new MT PASA solution using probabilistic modelling to take effect from November 2017.

DRAFT

1 Introduction

The National Electricity Rules (the *Rules*) clause 3.7.1 requires the Australian Energy Market Operator (AEMO) to administer the *projected assessment of system adequacy (PASA)* processes.

The *PASA* is the principal method of indicating to the National Electricity Market (NEM) a forecast of power system security and supply reliability for up to two years. The *Rules* require AEMO to administer the *PASA* for two timeframes:

1. *Medium Term PASA (MT PASA)* which covers a 24 month period commencing from the Sunday after the *day* of publication with a daily resolution; and
2. *Short Term PASA (ST PASA)* which covers the period of six *trading days* starting from the end of the *trading day* covered by the most recently *published pre-dispatch schedule* with a *trading interval* resolution.

The *MT PASA* assesses *power system security* and *reliability* under a minimum of 10% Probability of Exceedance (POE) and 50% POE demand conditions based on generator availabilities submitted by *market participants*, with due consideration to planned transmission outages. The *reliability standard* is a measure of the effectiveness, or sufficiency, of installed capacity to meet demand. It is defined in clause 3.9.3C of the *Rules* as the maximum expected *unserved energy (USE)* in a *region* of 0.002% of the total *energy* demanded in that region for a given *financial year*. *USE* is measured in gigawatt hours (GWh).

The *MT PASA* process includes (but is not limited to):

- Information collection from Scheduled Generators, Market Customers, Transmission Network Service Providers and Market Network Service Providers about their intentions for:
 - Generation, transmission and market network service maintenance scheduling.
 - Intended plant availabilities.
 - Energy Constraints.
 - Other plant conditions which could materially impact upon power system security and the reliability of supply.
 - Significant changes to load forecasts.
- Analysis of medium term power system security and reliability of supply.
- Forecasts of supply and demand.
- Provision of information that allows participants to make decisions about supply, demand and outages of transmission networks for the upcoming two year period.
- Publication of sufficient information to allow the market to operate effectively with a minimal amount of intervention by AEMO.

The *MT PASA* process is administered according to the timeline set out in the Spot Market Operations Timetable¹ (*timetable*) in accordance with the *Rules*.

This document fulfils AEMO's obligation under clause 3.7.2(g) of the *Rules* to document the procedure used in administering the *MT PASA*.

2 MT PASA process and Rules requirements

The *PASA* is a comprehensive program for collecting and analysing information to assess medium- and short-term power system security and reliability of supply prospects. This is so that *Registered Participants* are properly informed to enable them to make decisions about *supply*, demand and *outages of transmission networks* in respect of periods up to two years in advance. *MT PASA*

¹ <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Security-and-reliability/Dispatch-information>
<http://www.aemo.com.au/Electricity/Market-Operations/Dispatch/Spot-Market-Operations-Timetable>

assesses the adequacy of expected electricity supply to meet demand across the two-year horizon through regularly identifying and quantifying any projected failure to meet the *reliability standard*.

MT PASA incorporates two separate functions:

1. A high frequency three-hourly information service that gives a regional breakdown of the supply situation over the two-year horizon, taking into account participant submissions on availability.
2. A weekly assessment of system reliability, including provision of information on demand, supply and network conditions.

AEMO must review and *publish* the MT PASA outputs in accordance with the frequency specified in clause 3.7.2(a), covering the 24-month period starting from the Sunday after *day* of publication with a daily resolution. Additional updated versions of MT PASA may be published by AEMO in the event of *changes* which, in the judgement of AEMO, are materially significant and should be communicated to *Registered Participants*.

Each party's responsibilities in preparing MT PASA (summarised in Table 1 below) are also defined in this clause.

Table 1: Rules requirements

Responsible Party	Action	Rules Requirement
AEMO	Prepare following MT PASA <i>inputs</i> : <ul style="list-style-type: none"> • Regional demand forecasts - 10% POE and most probable daily peak load (50% POE) • <i>Network constraints</i> forecasts • <i>Unconstrained intermittent generation forecasts</i> for <i>semi-scheduled generating unit</i> 	3.7.2(c)
<i>Scheduled Generator or Market Participant</i>	Submit to AEMO the following MT PASA <i>inputs</i> : <ul style="list-style-type: none"> • <i>PASA availability</i> of each <i>scheduled generating unit, scheduled load or scheduled network service</i> • Weekly <i>energy constraints</i> applying to each <i>scheduled generating unit or scheduled load</i> 	3.7.2(d)
<i>Network Service Providers</i>	Provide AEMO the following information: <ul style="list-style-type: none"> • Outline of planned <i>network outages</i> • Any other information on planned <i>network outages</i> that is reasonably requested by AEMO 	3.7.2(e)
AEMO	Prepare and <i>publish</i> the MT PASA <i>outputs</i>	3.7.2(f)

3 MT PASA Inputs

Inputs used in the MT PASA process are provided by AEMO and *market participants*. They are discussed in detail below.

3.1 Market participant inputs

Market participants are required to submit the following data in accordance with the *timetable*, covering a 24-month period from the Sunday after the *day* of publication of MT PASA.

3.1.1 Generating unit availabilities for MT PASA

- *Generating unit* PASA availabilities:

MT PASA uses PASA availabilities of generating units. PASA availability includes the generating capacity in service as well as the generating capacity that can be delivered with 24 hours' notice.

- As per clause 3.7.2(d)(1), *Generators* are required to provide the expected daily MW capacity of each *scheduled generating unit* or *scheduled load* for the next two years. The actual level of *generation* available at any particular time will depend on the condition of the generating plant, which includes factors such as age, outages, and wear. Another important factor with respect to output is the reduction in thermal efficiency with increasing temperature².

Generators should take into account the ambient weather conditions expected at the time when the Region where the generating unit is located experiences the 10% Probability of Exceedance (POE) *peak load* defined as Generation Capacity Reference Temperatures. The summer and winter AEMO generation capacity reference temperatures for each region are available in the Background Information worksheet of the Generator Information spreadsheet for each region published on the AEMO website³.

- *Generating unit energy* availabilities:

Generating plant such as hydroelectric power stations cannot generally operate at maximum capacity indefinitely because their energy source may become exhausted. Gas and coal plants can have energy constraints due to contracted fuel arrangements or emissions restrictions. Under clause 3.7.2(d)(2), scheduled generating units with energy constraints (referred to as energy constrained plant) are required to submit their weekly energy limit in MWh for each week for the upcoming 24-month period commencing from the first Sunday after the latest MT PASA run. AEMO may also use other information available such as that provided through the Generator Energy Limitation Framework (GELF) to develop annual energy constraints for MT PASA modelling.

- Wind turbine and large-scale solar availabilities:

To facilitate AEMO to fulfil its obligation in producing *semi-scheduled generating unit* forecasts as per clause 3.7.2(c)(4), participants who operate such units are required to submit wind turbine or solar availability information to AEMO. Based on this information, semi-scheduled profiles are developed by AEMO. This is discussed in more detail in section 3.2.1.

3.1.2 Network outages and Interconnector availabilities

Under clause 3.7.2(e), *Network Service Providers* must provide to AEMO an outline of planned *network outages* and any other information on planned *network outages* reasonably requested by AEMO. This includes interconnector availability information (e.g. Basslink). The planned *network outages* are converted into *network constraints* by AEMO. This process is further discussed in Section 3.2.3.

3.1.3 Auxiliary load

AEMO requires auxiliary load information to reconcile participant bids that are supplied on an “as generated” operational demand basis with demand forecasts that are constructed on a “sent out” operation basis to ensure accurate modelling outcomes.

² <http://www.aemo.com.au/Electricity/Planning/Related-Information/Generation-Information>

³ Generation capacity reference temperatures are available at:

<http://www.aemo.com.au/Electricity/Planning/Related-Information/Generation-Information>

3.2 AEMO inputs

3.2.1 Plant availabilities for MT PASA

AEMO prepares other plant availability data, not provided by *market participants*:

- Semi-scheduled wind and solar generation forecasts:

AEMO is required to produce an *unconstrained intermittent generation forecast* (UIGF) for each *semi-scheduled generating unit* for each *day* in accordance with clause 3.7.2(c)(4).

AEMO develops the UIGF using historically observed wind speed and solar irradiation. The same historic weather conditions are used to forecast demand, ensuring that any correlation between intermittent generation and demand is preserved.

Power factors for individual units, sourced from AEMO's Australian Wind Energy Forecasting System (AWEFS) and the Australian Solar Energy Forecasting System (ASEFS), are applied to convert the wind speed and solar irradiation into generation forecasts for at least five weather reference years.

These generation forecasts are "unconstrained" in the sense that they are based on the raw energy input to a unit's power conversion process and ignore overriding factors that are external to the power conversion process. These factors include the impact of any network constraint on the output or any economic requirement to otherwise operate at reduced levels.

For the Loss of Load Probability Assessment (see section 4.5), a forecast regional distribution of intermittent generation at times of 90th percentile demand is also determined for every half hour based on historical weather observations, forecast intermittent generation capacity, and the power factors discussed above.

- Non-scheduled generation forecasts:

In accordance with clause 3.7.2(f)(2), AEMO is required to prepare and *publish* the aggregated MW allowance (if any) to be made by AEMO for *generation* from *non-scheduled generating systems*.

The non-scheduled generation profiles have two parts: non-scheduled wind and solar generation and other non-scheduled generation. The non-scheduled wind and solar generation forecasts⁴ are produced in the same way as semi-scheduled wind and solar generation forecasts, while the other non-scheduled generation forecasts are consistent with figures published in the National Electricity Forecasting Report (NEFR)⁵.

The non-scheduled generation forecasts for units under 30MW are used as an input to the MT PASA demand forecasting process and are not modelled explicitly. This is discussed in more detail in Section 3.2.2.

- Demand Side Participation (DSP):

DSP includes all short-term reductions in demand in response to temporary price increases (in the case of retailers and customers) or adverse network loading conditions (in the case of networks). An organised, aggregated response may also be possible. From the transmission network perspective, consumers may effectively reduce demand by turning off electricity-using equipment or starting up on-site generators.

MT PASA uses the NEFR's seasonal medium growth reliability response forecasts for demand side participation estimates in the form of five different price-quantity bands

⁴ The non-scheduled wind generation forecasts are reported as TOTALINTERMITTENTGENERATION in the MTPASA.RegionSolution table. A guide to the information contained in the MT PASA is available in the form of a data model at <http://www.aemo.com.au/-/media/Files/PDF/MMS-Data-Model-Report.ashx>

⁵ <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/-/link.aspx?id=80D4B633C2C646B388513FD14536623C&z=z>

- Future generation:

Committed generation projects currently under development with a dispatch type of scheduled, semi-scheduled or significant non-scheduled are also modelled in MT PASA.

Before the unit is registered, PASA availability for a committed scheduled generating unit is estimated based on participant information regarding the commercial use date and seasonal capacity. The Generator information page reports this information⁶.

The unit is entered into a Future Generation table that is referenced during modelling to include all committed but not registered units. Once the unit is registered, it is removed from the Future Generation table. In the case of scheduled units, the *Generator* that owns the unit is responsible for submitting MT PASA unit offer data to AEMO.

In the case of semi-scheduled generators and significant non-scheduled generators, reference weather traces for modelling are developed for the unit for use in modelling through either:

- using a “shadow generator” based on existing intermittent generation in close proximity
- using meteorological data for the generation site, and assuming a power factor based on similar unit type.

3.2.2 Demand forecasts

AEMO develops two separate types of demand forecasts for MT PASA modelling:

- Annual demand profiles, consisting of half-hourly demand points, with energy consumption and maximum demand aligned with the NEFR forecasts.
- Half-hourly demand estimates representing the 50th and 90th percentile demand forecast for that time and day.

The annual demand profiles are used in MT PASA modelling to identify and quantify any projected breach of the reliability standard. For this purpose, both the peak demand and energy consumption are important to capture, and the profile is developed considering past trends, day of the week and public holidays.

The actual demand differs from forecast, mainly due to weather. Statistically, it can be assumed that the forecast error follows a normal distribution. Accordingly, a forecast can be qualified by the probability that actual demand will exceed forecast demand or POE:

- A 10% POE forecast⁷ indicates a 10% chance that actual demand will exceed the forecast value (i.e. Peak demand will be exceeded once in 10 years).
- A 50% POE forecast indicates a 50% chance that actual demand will exceed the forecast value.

The timing and regional spread of these weather events also impacts on demand – hot weather occurring in a single region on a weekend will impact demand (and potentially reliability) differently than a heat wave that has been building for days and with impact felt across multiple regions.

To capture the impact of weather variations on demand, at least sixteen different annual demand profiles (corresponding to model base cases discussed in Section 4.3) are developed for each region, based on different historic weather patterns and POE peak demand forecasts. While this captures a reasonable range of different weather-driven demand conditions, it unavoidably requires assumptions to be made about precisely when the peak demand could occur, based on historical demand patterns even though it is impossible to predict when the peak demand will occur in future.

⁶ <http://aemo.com.au/Electricity/National-Electricity-Market-NEM/Planning-and-forecasting/Generation-information>

⁷The 10% POE and 50% POE Demand forecasts are reported as DEMAND10 and DEMAND50 in the MTPASA.RegionSolution table. A guide to the information contained in the MT PASA is available in the form of a data model at <http://www.aemo.com.au/-/media/Files/PDF/MMS-Data-Model-Report.ashx>

Consequently, it is important that AEMO also considers the loss of load probability in each period of the modelling horizon, assuming that extreme weather conditions were to occur in that period (see Section 4.5 for more detail). This requires forecasts of the 90th percentile demand forecast for that time and day. In other words, determining the forecast value in each half hour that has a 10 percent chance of being exceeded. Each demand period is considered independently of the next – summing the half hours will not produce realistic annual energy consumption forecasts.

Refer to Appendix B for further information on the derivation of MT PASA demand forecasts.

3.2.3 Power transfer capabilities used in MT PASA

For MT PASA, AEMO is required to forecast *network constraints*⁸ known to AEMO at the time under clause 3.7.2(c)(3).

Network constraints used in MT PASA represent technical limits on operating the power system. These limits are expressed as a linear combination of generation and interconnectors, which are constrained to be less than, equal to or greater than a certain limit.

AEMO continues to update and refine *network constraints* through its ongoing modelling projects. MT PASA uses the latest version of ST PASA formulation constraints as a starting base, with additional customised *network constraints* associated with future planned *network* and generation upgrades. AEMO constructs system normal and outage constraint equations for the MT PASA time frame. MT PASA modelling is conducted with approved planned network outage constraints applied.

Information to formulate *network constraint equations* is provided to AEMO by Transmission Network Service Providers (TNSPs) via Network Outage Scheduler (NOS)⁹ and limit advice. The process of producing *network constraint equations* is detailed in the Constraint Formulation Guidelines¹⁰. Within AEMO's market systems, *constraint equations* are marked as system normal if they apply to all plant in service. To model network or plant outages in the power system, separate outage *constraint equations* are formulated and applied with system normal *constraint equations*.

4 MT PASA Solution Process

Information on the proposed probabilistic modelling solution has been included in this section, and represents current thinking on the design. This information may change once AEMO has completed the RSIG consultation and development, installation and testing of the new probabilistic model.


4.1 NEM Representation

The power system model used within the MTPASA simulation will match the model applied for AEMO's wholesale electricity market systems:

⁸ <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Security-and-reliability/Congestion-information>

⁹ <http://nos.prod.nemnet.net.au/nos>

¹⁰ <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Security-and-reliability/Congestion-information>



The salient features of the power system model are:

- Single regional reference node (RRN) within each market region at which all demand within the region is deemed to apply.
- Generators connected to the regional reference node via a “hub and spoke” model. Static transmission loss factors are used to refer price data from the generator connection point to the RRN of the host region.
- Flow between market regions via interconnectors, which provide transport for energy between regions. Losses for flows over interconnectors are modelled using a dynamic loss model.
- Modelling of thermal and stability constraints to be achieved by overlaying constraint equations onto the market-based model.

4.2 Overview of Modelling Approach

MT PASA assessment is carried out at least weekly using two different model runs:

1. Reliability Run to identify and quantify potential reliability standard breaches, and assess aggregate constrained and unconstrained capacity in each region, system performance and network capability
2. Loss of Load Probability assessment to assess days most at risk of load shedding.

These two runs are discussed in more detail in the following sections.

4.3 MT PASA Reliability Run


The MT PASA Reliability Run implements the *reliability standard* by assessing the level of unserved energy and evaluating the likelihood of *reliability standard* breaches through probabilistic modelling. The Reliability Run is conducted weekly.¹¹

The probabilistic approach replaces the previous deterministic approach towards assessing reliability and removes the need to calculate minimum reserve levels.

The MT PASA Reliability Run uses about 200 Monte-Carlo simulations¹² on a set of predefined base cases to assess variability in unserved energy outcomes (see Figure 1). Demand and intermittent generation supply assumptions vary for each base case, driven by different historical weather conditions. Within a base case, the Monte-Carlo simulations vary with respect to:

- unplanned generation outage states based on historical forced outage rates.
- intermittent generation availability (by introducing random error around the projected intermittent generation forecasts based on historically observed variations in intermittent generation output).

Figure 1: MT PASA Reliability Run case construction



In total, over 3,000 simulations are conducted for each year of the reliability assessment horizon.

The objective function associated with a simulation is:

- Minimise total generation cost subject to:
 - Supply = Demand.
 - Unit capacity limits observed.
 - Unit/power station/portfolio energy limits observed.
 - Network constraints observed.

¹¹ The Reliability Run will be conducted on a weekly basis if computation times are sufficiently fast. Alternatively it may be run fortnightly in the absence of material changes to inputs.

¹² Probabilistic modelling involves many repetitions of the simulation model while applying random sampling to certain components of the model. In MT PASA the random sampling is applied to the occurrence of forced outages for generation.

Each simulation produces an estimate of annual USE, with the total 3,000 odd simulations providing insight into the distribution of annual USE. AEMO proposes using a minimum of 50% POE and 10% POE demand levels, weighted appropriately¹³, to assess the expected USE.

If there are material levels of USE in 50% POE results, AEMO will consider running additional demand levels such as 90% POE. AEMO is developing a broader range of POE traces for modelling and will update this document should any changes be made, including weightings.

The expected annual USE value from the simulations can be compared directly against the *reliability standard*. This allows AEMO to accurately assess whether the *reliability standard* can be met. AEMO declares a LRC if the expected value of USE across all simulations exceeds the *reliability standard*.

Pain sharing is not included. Instead, the annual USE reported in a region reflects the source of any supply shortfall and is intended to provide participants with the most appropriate locational signals to drive efficient market responses. (See Appendix C: Pain Sharing for a more detailed explanation).

The outputs are also used to set interconnector flow parameters for the Loss of Load Probability assessment.

4.4 MT PASA Loss of Load Probability (LOLP) assessment

To determine days most at risk of load shedding, AEMO conducts a LOLP assessment for each day in the two-year horizon, assuming that extreme weather conditions were to occur on that day. The main objective is to determine which days have higher relative risk of loss of load to help participants schedule outages outside of these periods, and indicate when AEMO may be required to direct or run any contracted RERT.

The LOLP run is essentially a stress test on the system as it uses the half-hourly 90th percentile demand value for each region concurrently – that is, the demand value with a 10% chance of being exceeded.

An objective function is not required for this run; instead, the calculation is done through a convolution of load process within the model to derive a loss of load probability for each day in the horizon. This is carried out by iterating through all units in the system, accumulating unit outages and calculating their respective probabilities. Capacity interchange from other regions is also taken into account. These capacity limits are calculated based on outputs from the Reliability Run. The LOLP will report the single half hour of each day that has the greatest probability of loss of load.

Intermittent generation in each region will be modelled as a single multi-state generator, based on assessed distribution of wind/solar availability in the region at that time of day, and time of year, under the 90th percentile demand conditions.

4.5 Comparison of Model Features

Table 1 shows the comparison of the key features of the two MT PASA modelling runs.

¹³ USE results from 50% POE and 10% POE runs are aggregated with 69.6% weighting for 50 POE and 30.4% weighting for 10 POE.

Table 1: Comparison of MT PASA run features

MT PASA INPUTS		
PROPERTY	RELIABILITY RUN	LOLP RUN
Horizon	2 years (104 weeks – starting the following Sunday)	
Frequency of Run	Weekly	Weekly
Simulations	Up to 200 per case	Not applicable
Resolution	Half Hourly	Half hourly, returning a single half hour per day based on worst demand/supply conditions
Registration	Using market system registration as a base including regions, interconnectors, generators, transmission loss factors, interconnector loss models, fuel and regional reference node memberships for generators	
Demand	At least eight half hourly 10% POE and 50% POE demand traces	Half hourly 90th percentile demand
Generator Capacity	As per participant MT PASA declarations	
Generator Bid Offers	SRMC calculated from heat rate, fuel price, VOM etc.	Not used
Generator Forced/partial outage modelling	Probabilistic assessment of forced outages over multiple simulations	Convolution of load
Intermittent (Semi Scheduled) Generation	At least eight historical weather traces, correlated to demand traces	Modelled as a single multi-state generator for each region
Non-scheduled Generation	Significant non-scheduled generation based on NEFR estimates	
Network Representation	ST PASA formulation constraints with dynamic right hand side (RHS with network outages)	Network transfer limits from the Reliability Run to be used instead of network constraints

TNSP Limit Data	Equipment ratings inclusive of seasonal variations required for evaluating generic constraint RHS	Not used. Network transfer limits from the Reliability Run to be used instead
Interconnector forced outage modelling	Not modelled	Not modelled
Demand Side Participation	At least five static Price/Quantity bands. Price not required for LOLP run	
Rooftop PV	Correlated to demand trace, but not explicitly modelled.	
MT PASA SOLUTION		
PROPERTY	RELIABILITY RUN	LOLP RUN
Purpose of run	Assess level of unserved energy and the likelihood of reliability standard breaches.	Assess the days at highest risk of loss of load
Type of run	LP minimising total generation cost subject to: Supply = demand Unit capacity limits observed Generator Energy limits observed Network constraints observed	Convolution of Load – a mathematical calculation that iterates through the units to calculate the combined probability of outage for each half hour of the day
MT PASA OUTPUTS		
PROPERTY	RELIABILITY RUN	LOLP RUN
Low Reserve Condition	Forecasts of low reserve conditions based on expected annual USE	N/A
Unserved Energy	Distribution of unserved energy for each day in the horizon.	

Loss of Load Probability		Probability of loss of load on any given day
Interconnector Transfer Capabilities	Interconnector transfer capabilities with network outages for use in LOLP Run	
Network Constraint Impacts	When and where network constraints may become binding on the dispatch of generation or load	
Projected violations of Power System Security	Reporting on any binding and violating constraints that occur during modelling	
Aggregate Capacity for each region	Aggregate capacity allowing for the impact of network constraints – with and without energy constraints	

5 MT PASA Outputs

Under clause 3.7.2(f) of the *Rules*, AEMO must *publish* the MT PASA outputs as part of the MT PASA process¹⁴. The main MT PASA output is the forecast of any low reserve condition¹⁵ and the estimated USE value.

The NER 4.8.4(a) defines an LRC as:

“Low Reserve Condition - when AEMO considers that the balance of generation capacity and demand for the period being assessed does not meet the reliability standard as assessed in accordance with the reliability standard implementation guidelines”.

Table 3 shows each MT PASA output colour coded by the run that is used to determine the value. Outputs (1) – (4) are based on AEMO daily 50% and 10% Probability of Exceedance (POE) peak demand forecasts¹⁶ and corresponding assumptions, and are not determined by modelling. Output (5) is supplied in the three-hourly report as the aggregate value of participant submitted availabilities. Outputs (5A) – (6) (v) are predominantly determined by the Reliability Run, although some details are still to be determined.

Table 3: MT PASA Outputs Specified in NER 3.7.2(f)

MT PASA OUTPUT SPECIFICATIONS NER 3.7.2(f)	MT PASA PUBLICATION	OUTPUT DETAILS
(1) Forecasts of the 10% probability of exceedance peak load and most probable peak load, excluding the relevant aggregated MW allowance referred to in (2) and adjusted to make allowance for scheduled load	AEMO demand forecasts	Peak operational demand - 10% POE and 50% POE demand
(2) The aggregated MW allowance (if any) to be made by AEMO for generation from non-scheduled generating systems in each of the forecasts of the 10% probability of exceedance peak load and most probable peak load referred to in (1)	AEMO demand forecasts	Non Scheduled Generation at times of 10% POE and 50% POE peak operational demand
(3) In respect of each of the forecasts of the 10% probability of exceedance peak load and most probably peak load referred to in (1), a value that is the sum of that forecast and the relevant aggregated MW allowance referred to in (2)	Derived from (1) and (2)	Peak native demand
(4) Forecasts of the most probable weekly energy for each region	AEMO demand forecasts	Total Weekly Energy
(5) Aggregate generating unit PASA availability for each region	3 Hourly Report	Data Fields: PasaAvailabilityScheduled
(5A) Aggregate capacity for each region, after allowing for the impact of network constraints, that can be generated continuously, calculated by adding the following categories:	MT PASA Reliability Run	Still to be determined

¹⁴ http://www.nemweb.com.au/REPORTS/CURRENT/MEDIUM_TERM_PASA_REPORTS/. A guide to the information contained in the MT PASA is available in the form of a data model at <http://www.aemo.com.au/-/media/Files/PDF/MMS-Data-Model-Report.ashx>


¹⁵ <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Data-dashboard>

¹⁶ Note that this is not the same as the 90th percentile demand values used in the LOLP Run.

<p>(i) The capacity of scheduled generating units in the region that are able to operate at the PASA availability</p> <p>(ii) The forecast generation of semi-scheduled generating units in the region as provided by the unconstrained intermittent generation forecasts</p>		
<p>(5B) Aggregate capacity for each region, after allowing for the impact of network constraints, that cannot be generated continuously at the PASA availability of the scheduled generating units in the region due to specified weekly energy constraints; and</p>	<p>MT PASA Reliability Run</p>	<p>Still to be determined.</p>
<p>(6) Identification and quantification of:</p>		
<p>(i) Any projected violations of power system security</p>	<p>MT PASA Reliability Run</p>	<p>Constraint solution outputs identify binding and violating constraints. If any constraints are violated, it indicates that there is a projected violation of power system security.</p>
<p>(ii) Any projected failure to meet the reliability standard assessed in accordance with the RSIG</p>	<p>MT PASA Reliability Run</p>	<p>Estimated USE for each day in each region. Identify LRC based on expected annual USE</p>
<p>(iii) Deleted</p>		
<p>(iv) Forecast interconnector transfer capabilities and the discrepancy between forecast interconnector transfer capabilities and the forecast capacity of the relevant interconnector in the absence of outages on the relevant interconnector only</p>	<p>Constraint library & NOS</p>	<p>AEMO recommends using the Constraint Library and the Network Outage Schedule for accurate and comprehensive information on applicable constraints.</p>
<p>(v) When and where network constraints may become binding on the dispatch of generation or load</p>	<p>MT PASA Reliability Run</p>	<p>Binding constraints can only be assessed through modelling as it is dependent on generation dispatch. Constraints may bind at different times, depending on the demand and intermittent generation reference trace used.</p>


Appendix A: MT PASA Process Architecture

Figure 2: MT PASA Process



Appendix B: Medium Term Demand Forecasting Process

Demand Type	Definition	Description
Underlying	Actual customer consumption	Actual consumption on premises (“behind the meter”) ignoring effect of rooftop PV and battery storage.
Delivered	Underlying – PV – battery	What the consumer (either residential or business) must withdraw from the electricity grid.
Native	Delivered + (network losses)	Total generation that must be fed into the electricity grid.
Operational “sent-out”	Delivered – (Small Non-Scheduled Generation) + (network losses)	Total generation by scheduled / semi-scheduled / significant non-scheduled generators needed to meet system demand.
Operational “as generated”	(Operational “as sent out”) + (auxiliary loads)	Total generation by scheduled / semi-scheduled / significant non-scheduled generators needed to meet system demand and demand on generator premises.



The methodology for creating “As Generated” demand trace inputs is covered below:

- Representative traces are obtained using at least eight years of historical data.
- Derived operational traces (with rooftop PV added) are “grown” to represent future energy consumption and maximum demand. Future Liquefied Natural Gas (LNG) export demand is assumed to have a flat profile across the year and is added to the future Queensland demand traces.
- Projections of future levels of annual underlying energy consumption and maximum demand in each region are obtained from the most recent NEFR
- Estimated auxiliary load is added to the “as sent out” demand to obtain the final “as generated” demand
- Rooftop PV is not modelled in MT PASA but is reported separately. In developing the operational demand traces, rooftop PV contribution in historical year is added to the original reference year trace, the trace “grown” and then forecast rooftop PV is subtracted from the

grown trace and retained for reporting. The impact of battery storage is not considered presently due to low uptake, but may be incorporated in future.

AEMO is seeking to obtain more accurate information from participants on auxiliary load which would enable MT PASA to use “sent out” operational demand, while taking the auxiliary load into account within the model.

Appendix C: Pain Sharing

The pain sharing principle of the NEM states that load shedding should be spread pro rata throughout interconnected regions when this would not increase total load shedding. This is to avoid unfairly penalising one region for a supply deficit spread through several interconnected regions.

Specifically, the Equitable Load Shedding Arrangement¹⁷ states “as far as practicable, any reductions, from load shedding as requested by AEMO and/or mandatory restrictions, in each region must occur in proportion to the aggregate notional demand of the effective connection points in that region, until the remaining demand can be met, such that the power system remains or returns (as appropriate) initially to a satisfactory operating state.”

It is open to interpretation whether the pain sharing principles should apply over the annual period, or be more literally applied to each half hour period where USE may be projected, irrespective of previous incidents. One may argue that, for planning purposes, pain sharing should aim to equalise USE across all NEM regions over the year, taking account of localised USE events that have already occurred. This would be consistent with implementation of the reliability standard, using pain sharing to keep load shedding in all regions to less than 0.002% if at all possible.

Irrespective of the interpretation of the principle, the EY Report on MT PASA stated that pain sharing is problematic in models, since shifting USE between regions will almost inevitably change interconnector losses and thus the total quantity of USE will usually increase. Since the purpose of MT PASA is to accurately assess USE, EY recommended that pain sharing be considered a non-core component of MT PASA design.

AEMO considers that the interests of the markets are best served by providing an accurate assessment of USE in any region where shortfall occurs in order to encourage efficient locational investment signals.

Application of pain sharing to MT PASA modelling results has the potential to obscure the true state of supply issues in a region and thus will not be incorporated into the reliability assessments.

¹⁷ <http://www.aemc.gov.au/getattachment/deafe4fa-c992-4c34-bb74-c8d83cd1ba67/Guidelines-for-Management-of-Electricity-Supply-Sh.aspx>

Appendix D: Indicative Graphical Outputs

The following charts represent proposed outputs from the MT PASA runs. These are subject to change during the MT PASA model development and testing stage and are based on “mock data” As such they do not represent real modelling outcomes.

Figure 4 shows the output from the Reliability Run that indicates whether the reliability standard can be met in each region for each year of the reliability assessment. The red line indicates the *reliability standard*, so any bars that exceed the *reliability standard* indicate a *low reserve condition* exists.

Figure 3: Assessment of Reliability Standard




Figure 4 shows the LOLP assessed for each day. It also provides a breakdown of supply and demand at times of highest LOLP each day to help gain insights into conditions driving the higher LOLP outcomes. The black line represents installed capacity, the red line the 90th percentile demand and the green line the total available capacity. The dashed lines show the components of the available capacity – scheduled generation and intermittent generation.

Figure 4: Demand shown with supply availability and loss of load probability




Figure 5 indicates the extent of unserved energy across the different probabilistic simulations and the periods where unserved energy occurred most often. This helps quantify the USE by showing the frequency and magnitude of load shedding in each simulation. Figure 6 shows a more detailed monthly breakdown of unserved energy by reference year and demand level.

Figure 5: Variations in Unserved Energy by region and reference year across probabilistic modelling simulations
 2018 Unserved Energy from probabilistic modelling runs




Figure 6: Detailed USE breakdown for a single month by reference year and demand level
 January 2018 Unserved Energy by Modelling Reference Year

