POWER SYSTEM OPERATION PROCEDURE: SHORT TERM PROJECTED ASSESSMENT OF SYSTEM ADEQUACY

PREPARED BY:	System Management (WA)
DOCUMENT REF:	SO_OP_WA_3809
VERSION:	6.0
EFFECTIVE DATE:	[Enter date]
STATUS:	DRAFT FOR CONSULTATION

Approved for distribution and use by:

APPROVED BY:	Cameron Parrotte
TITLE:	EGM - WA

VERSION RELEASE HISTORY

Version	Effective Date	Summary of Changes
1	21 September 2006	Power System Operation Procedure (Market Procedure) for Commissioning and Testing
2	17 July 2009	System Management amended changes to the procedure resulting from Procedure Change Report PPCL0009
3	23 June 2011	System Management amended changes to the procedure resulting from Procedure Change Report PPCL0016
4	Balancing Market Commencement Day	System Management replacement of the procedure resulting from Procedure Change Report PPCL0023
5	1 March 2014	System Management amended changes to the procedure resulting from Procedure Change Proposal PPCL 0025
6.0	dd MMM YYYY	Changes resulting from Procedure Change Proposal AEPC_2018_XX

CONTENTS

1	PROCEDURE OVERVIEW	4
1.1	Relationship with the Wholesale Electricity Market Rules	4
1.2	Interpretation	4
1.3	Purpose and application of this Procedure	4
1.4	Associated documents	4
2	TIMETABLE	5
2.1	Timing requirements	5
3	INFORMATION REQUIREMENTS	5
3.1	General requirements	5
3.2	Allowable use of AEMO data	5
3.3	Submission of Revised Data	5
4	SHORT TERM RESERVE MARGIN	5
4.1	General	5
4.2	Assessment of Short Term Reserve Margin	6

LIST OF TABLES

Table 1	Defined Terms	4
Table 2	Background Procedures	4

1 PROCEDURE OVERVIEW

1.1 Relationship with the Wholesale Electricity Market Rules

1.1.1 This Power System Operation Procedure (PSOP): Short Term Projected Assessment of System Adequacy (Procedure) has been developed in accordance with clauses 3.17 of the Wholesale Electricity Market Rules (WEM Rules).

1.1.2 References to particular WEM Rules within the Procedure in bold and square brackets **[Clause XX]** are current as at 13 October 2017. These references are included for convenience only and are not part of this Procedure.

1.2 Interpretation

In this Procedure:

(a) terms that are capitalised but not defined in this Procedure have the meaning given in the WEM Rules;

(b) to the extent that this Procedure is contrary or inconsistent with the WEM Rules, the WEM Rules shall prevail to the extent of the inconsistency;

(c) a reference to the WEM Rules or Market Procedures includes any associated forms required or contemplated by the WEM Rules or Market Procedures; and

(d) words expressed in the singular include the plural or vice versa.

1.2.2 In addition, the following defined term has the meaning given.

Table 1 Defined Terms

Term	Definition
Planning Horizon	Three weeks, starting from 8 AM on the day following the day on which the Short Term PASA study is performed **[Clause 3.17.3]**.
Reserve Margin	The value identified in step 4.1.2.

1.3 Purpose and application of this Procedure

1.3.1 The purpose of this Procedure is to detail the processes to be followed by AEMO, Market Participants and Network Operators when conducting a Medium Term PASA study **[Clause 3.17.10]**.

1.4 Associated documents

1.4.1 The following documents in Table 2 (available on the Market Web Site) provide background information to this Procedure:

Table 2 Background Procedures

Reference	Title	Location
SO_OP_WA_3804	PSOP: Facility Outages	Market Web Site
SO_OP_WA_3808	PSOP: Power System Security	Market Web Site
SO_OP_WA_3806	PSOP: Medium Term PASA	Market Web Site

2 TIMETABLE

2.1 Timing requirements

2.1.1 The timing requirements that AEMO must follow when completing and reviewing a Short Term PASA study, and AEMO's obligation to publish the relevant information are defined in the WEM Rules **[Clauses 3.17.1, 3.17.2** and **3.17.6]**.

3 INFORMATION REQUIREMENTS

3.1 General requirements

3.1.1 AEMO may direct Rule Participants from time to time, to provide the information specified in the WEM Rules, in a manner and timeframe specified by AEMO **[Clause 3.17.5].**

3.1.2 A Rule Participant must provide the information requested in step 3.1.1 within the timeframe specified by AEMO.

3.1.3 AEMO may seek clarification or further details of the information provided in step 3.1.1.

3.1.4 A Rule Participant must provide the information requested in step 3.1.3 within the timeframe specified by AEMO.

3.2 Allowable use of AEMO data

3.2.1 AEMO may utilise its own information in certain circumstances in substitution of information submitted by Rule Participants **[Clause 3.17.8]**, and shall document reasons for doing so in the ST PASA report **[Clause 3.17.9(i)]**.

3.2.2 In addition to information provided by a Rule Participant, AEMO may use information that it develops in accordance with clause 3.17.7 of the WEM Rules, and any other information AEMO considers necessary.

3.3 Submission of Revised Data

3.3.1 When a Rule Participant becomes aware of circumstances relating to material changes to information provided in accordance with step 3.1.1 for the first week of the Planning Horizon, Rule Participants must submit revised data within 24 hours **[Clause 3.17.6]**.

4 SHORT TERM RESERVE MARGIN

4.1 General

4.1.1 AEMO must assess the Reserve Margin for the Short Term PASA Planning Horizon.

4.1.2 The Reserve Margin is excess capacity as detailed in step 4.2.1.

4.1.3 AEMO must indicate in its results those periods within the ST PASA Planning Horizon where the Reserve Margin is less than zero.

4.2 Assessment of Short Term Reserve Margin

4.2.1 AEMO must estimate the applicable Reserve Margin by forecasting:

(a) The capacity of Scheduled Generators, Non-Scheduled Generators and Demand Side Programmes after allowing for outages that AEMO has knowledge of or has been informed of, less

(b) The mean plus two standard deviation system peak load forecast, less

(c) The effects of any generation being constrained due to insufficient transmission capacity remaining in service, less

(d) An allowance for that quantity of generation capacity required to operate as an Ancillary Service, to maintain the frequency standards specified in the PSOP: Power System Security, less

(e) An allowance for Ready Reserve, less

(f) An allowance for the availability of Non-Scheduled Generation and Demand Side Programmes.